



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 05, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRGR20230972

Property Address:

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Early Clear, Grade, and Fill for the associated East Town Crossing Civil Permit submittal (2902 E PIONEER, PUYALLUP, WA 98372)

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: McKee is dewatering R-Tank 1 and the sewer install. All dewatering is staying on site. They are importing and exporting.
See Corrections below.

Corrections:

- 1 No track out! Maintain spalls and keep tires clean.
Keep spalls on site
Need SWPPP on site.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large loop at the top and a series of vertical, wavy lines below it, ending in a horizontal stroke.

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636