



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 05, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRFUP20231289

Property Address: 1006 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: PSE - POTELCO 5807 MILWAUKEE AVE Puyallup, WA 98372

To construct: PERMIT EXT TO 06/09/2024 186054605 - Replace 5 transmission Poles P02, P03, P04, P06, and P09. P02 and P03 are in sidewalk all other cuts at base of pole will be in soft surface right of way. P05a replace existing anchor plate and install sidewalk guy.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Restoration Pending:

Communications must transfer to new poles prior to removal.

-P02 - Expedited communications transfer request - only 31" in the pedestrian access route - sidewalk will need to be replaced once old pole has been pulled

-P03 - Sidewalk panel will need to be replaced once communications lines and risers have transferred

-P04 - Pole set in soft surface, may need restoration once old pole is removed next to sidewalk

-P06 - Set in soft surface

-P09 - Set in soft surface

Corrections:

Sincerely,

Cheryl Trimble



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov

(253) 841-5464