



CITY OF PUYALLUP

Engineering Services

333 S Meridian, Puyallup, WA 98371

Tel: (253) 841-5577 Fax: (253) 840-6678

www.cityofpuyallup.org

April 4, 2024

RE: Certificate of Sewer Availability

Parcel Number: **6021590090**

Site Address: 3601 9th St SW; PUYALLUP, WA 98374

Application: PRCWSA20240533

To Whom It May Concern:

This letter is being provided regarding parcel **6021590090**. Parcel 6021590090 is located within the City of Puyallup and the Puyallup Sanitary Sewer Service Area. The parcel owner has requested that the city provide a certificate of sewer availability for a proposed swimming pool to be constructed on this parcel.

The city will allow the construction of the pool as long as the following requirement is adhered to: *The pool shall be filled with a hose and water truck. The pool cannot be connected to the Fruitland Mutual Water Co.'s water system unless the water service is protected by a reduced pressure backflow assembly (RPBA). Installation, filling, and draining of the pool shall comply with applicable county health department requirements. Pool water shall be dechlorinated and have a neutral PH prior to entering the storm sewer system.*

This parcel is currently connected to city sewer and connection will continue to be allowed.

If you have any questions, please contact me directly at 253-841-5577.

Sincerely,

Linda Lian
Engineer Technician IV
Engineering Division of DPS