



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20240544

FIRE ALARMS

Puyallup, WA

Job Address	Address: 3303 8TH AVE SE, Unit: C, PUYALLUP, WA 98372 Parcel # 0420253070	ISSUED April 08, 2024
Owner	STEP BY STEP FAMILY SUPPORT CENTER PO BOX 488 MILTON, WA 98354	
Applicant	Ronie Dunlap 2111 South 90th Street Tacoma, WA 98444 permits@evergreenfire.com	
Contractor	EVERGREEN FIRE & SECURITY 2111 SOUTH 90TH ST TACOMA, WA 98444 WA L&I #:	
Description of Work	Addition / modification to an existing fire alarm system. Install automatic / manual fire alarm detection and audible visual notification to the 2 detached greenhouses. These devices will be connected to the existing Farenhyt by Silent Knight addressable fire alarm system located in the adjacent Gateway Building. To include adding 10 smoke detectors, 4 pull stations and 6 horn strobes.	
Permit Types	Fire Alarms	
Expiration Date:	October 05, 2024	
Total ESU's		

Building Components:

Quantity	Units	Description
20	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration
		Total Value of Work: \$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Per the agreement with CPFR and City of Puyallup Building Official, both Green Houses will require Fire Alarm monitoring during events using the agreed upon time frame with CPFR operational permit.
 - When the Green House is outside of the operational permit usage, the system will be required to be removed and then returned to service during any event under the operational permit period.
 - Comply with CPFR operational permit and inspection requests.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to

be weatherproof.

- Total coverage is required, subject to field inspection. Comply with NFPA 72. System design is based off agreement with CPFR.
- Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified. A note should be added to the U.L. cert describing the requirements of this system for use.
- Pre-test shall be conducted with a printout for inspector at time of inspection.
- Labeling of all devices above and below ceiling required.
- The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
- Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Ronie Dunlap