

# Hydraulic Calculations

for

Project Name: Centeris UPS & Battery Rms  
Location: 1023 39th Ave SE, Puyallup, WA 98374,  
Drawing Name: Centeris v2

Calculation Date: 4/7/2024


## Design

Remote Area Number: 1  
Remote Area Location: Battery Rm  
Occupancy Classification: Extra Hazard Group I

Density: 0.30gpm/ft<sup>2</sup>  
Area of Application: 2500ft<sup>2</sup> (Actual 1488ft<sup>2</sup>)  
Coverage per Sprinkler: 95ft<sup>2</sup>  
Type of sprinklers calculated: Upright  
No. of sprinklers calculated: 20  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 500.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 1094.22 @ 51.788  
Type of System: Dbl. Interlock Pre-Action  
Volume of Dry/PreAction/Antifreeze/OtherAgent 317.64gal



Name of Contractor: Columbia Fire  
Address: 111 S Findlay St, Seattle, WA 98108  
Phone Number: (206) 232-8569  
Name of designer: Luke Thompson  
Authority Having Jurisdiction: City of Puyallyup

## Notes:

Automatic peaking results Left: N/A Right: N/A


# Hydraulic Graph

Job Name: Centeris UPS & Battery Rms  
Remote Area Number: 1

N 1.85

Date: 4/7/2024

**Water Supply  
Summary Sheet  
Node: 1**





# Summary Of Outflowing Devices

Job Number: 1

Report Description: Extra Hazard Group I (1)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler 833	29.22	27.07	8	13.342		
Sprinkler 834	29.35	27.07	8	13.463		
Sprinkler 835	29.78	27.07	8	13.858		
Sprinkler 836	30.66	27.07	8	14.684		
Sprinkler 837	32.10	27.07	8	16.103		
Sprinkler 854	28.74	28.50	8	12.905		
Sprinkler 855	28.87	28.50	8	13.023		
Sprinkler 856	29.29	28.50	8	13.407		
Sprinkler 857	30.15	28.50	8	14.208		
Sprinkler 858	31.58	28.50	8	15.585		
<b>⇒ Sprinkler 879</b>	<b>28.50</b>	<b>28.50</b>	<b>8</b>	<b>12.691</b>		
Sprinkler 880	28.63	28.50	8	12.808		
Sprinkler 881	29.05	28.50	8	13.186		
Sprinkler 882	29.91	28.50	8	13.975		
Sprinkler 883	31.32	28.50	8	15.332		
Sprinkler 902	28.43	27.07	8	12.629		
Sprinkler 903	28.56	27.07	8	12.746		
Sprinkler 904	28.98	27.07	8	13.122		
Sprinkler 905	29.83	27.07	8	13.907		
Sprinkler 906	31.25	27.07	8	15.258		

⇒ Most Demanding Sprinkler Data

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
879	9'-5	8	28.50	2	(See Notes)	9'-6	100	12.691	.....Route 1..... Sprinkler
880	9'-4½		28.50	2.1570			0.010489	0.017	
						9'-6		0.100	
880	9'-4½	8	28.63	2	(See Notes)	9'-6	100	12.808	Sprinkler
881	9'-4		57.13	2.1570			0.037975	0.017	
						9'-6		0.361	
881	9'-4	8	29.05	2	(See Notes)	9'-6	100	13.186	Sprinkler
882	9'-3½		86.18	2.1570			0.081246	0.017	
						9'-6		0.772	
882	9'-3½	8	29.91	2	(See Notes)	9'-6	100	13.975	Sprinkler
883	9'-3		116.09	2.1570			0.140975	0.017	
						9'-6		1.339	
883	9'-3	8	31.32	2	(See Notes)	3'-8½	100	15.332	Sprinkler, PO(8'-9½)
618	9'-3		147.41	2.1570		8'-9½	0.219318	0.007	
						12'-6		2.740	
618	9'-3		147.05	4		10'-0	100	18.078	Flow (q) from Route 3
568	9'-3		294.46	4.2600			0.028683	0.009	
						10'-0		0.287	
568	9'-3		148.64	4		9'-9	100	18.374	Flow (q) from Route 2
573	9'-2½		443.10	4.2600			0.061087	0.009	
						9'-9		0.596	
573	9'-2½		151.12	4	(See Notes)	272'-1	100	18.978	Flow (q) from Route 4 2T(18'-9½), 5E(9'-4½)
52	10'-6		594.22	4.2600		84'-6	0.105127	-0.560	
						356'-7		37.486	
52	10'-6			6	(See Notes)	6'-11½	100	55.905	E(12'-6½), DPV(26'-4½)
58	3'-7		594.22	6.3570		38'-11	0.014966	3.009	
						45'-10		0.686	
58	3'-7			6	(See Notes)	9'-6	120	59.600	BV(12'-7), E(17'-7), T(37'-8½)
204	1'-1½		594.22	6.3570		67'-11	0.010681	1.057	
						77'-5		0.827	
204	1'-1½			8	(See Notes)	4'-1½	120	61.483	E(21'-1½)
12	-3'-0		594.22	8.2490		21'-1½	0.003003	1.788	
						25'-3		0.076	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
12	-3'-0			8	(See Notes)	127'-8	140	63.347	GV(6'-9½), 2E(30'-6½), PIV(6'-9½), BFP, T(59'-4½)
24	-3'-0		594.22	8.3900		134'-0½	0.002079		
						261'-8½		0.544	
24	-3'-0			12	(See Notes)	994'-9½	140	63.892	3T(98'-3½), 2EE(21'-3½)
8	28'-0		293.18	12.4600		337'-5½	0.000082	-13.438	
						1332'-3		0.109	
8	28'-0		301.04	6	(See Notes)	42'-0	140	50.562	Flow (q) from Route 5 Water Supply
1	26'-0		594.22	6.2800			0.008522	0.867	
						42'-0		0.358	
			500.00					51.788	Hose Allowance At Source
1			1094.22						Total(Pt) Route 1
854	9'-5	8	28.74	2	(See Notes)	9'-6	100	12.905	..... Route 2 ..... Sprinkler
855	9'-4½		28.74	2.1570			0.010653	0.017	
						9'-6		0.101	
855	9'-4½	8	28.87	2	(See Notes)	9'-6	100	13.023	Sprinkler
856	9'-4		57.61	2.1570			0.038566	0.017	
						9'-6		0.366	
856	9'-4	8	29.29	2	(See Notes)	9'-6	100	13.407	Sprinkler
857	9'-3½		86.90	2.1570			0.082507	0.017	
						9'-6		0.784	
857	9'-3½	8	30.15	2	(See Notes)	9'-6	100	14.208	Sprinkler
858	9'-3		117.06	2.1570			0.143159	0.017	
						9'-6		1.360	
858	9'-3	8	31.58	2	(See Notes)	3'-8½	100	15.585	Sprinkler, PO(8'-9½)
568	9'-3		148.64	2.1570		8'-9½	0.222706	0.007	
						12'-6		2.782	
								18.374	Total(Pt) Route 2
902	9'-5½	8	28.43	2	(See Notes)	9'-6	100	12.629	..... Route 3 ..... Sprinkler
903	9'-5		28.43	2.1570			0.010442	0.017	
						9'-6		0.099	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
903	9'-5	8	28.56	2	(See Notes)	9'-6	100	12.746		
904	9'-4½		56.99	2.1570		9'-6	0.037803	0.017		
								0.359		
904	9'-4½	8	28.98	2	(See Notes)	9'-6	100	13.122	Sprinkler	
905	9'-4		85.97	2.1570		9'-6	0.080878	0.017		
								0.768		
905	9'-4	8	29.83	2	(See Notes)	9'-6	100	13.907	Sprinkler	
906	9'-3½		115.80	2.1570		9'-6	0.140338	0.017		
								1.333		
906	9'-3½	8	31.25	2	(See Notes)	3'-8½	100	15.258	Sprinkler, PO(8'-9½)	
658	9'-3½		147.05	2.1570		8'-9½	0.218330	0.007		
						12'-6		2.727		
658	9'-3½			4		9'-9	100	17.992		
618	9'-3		147.05	4.2600		9'-9	0.007939	0.009		
								0.077		
								18.078	Total(Pt) Route 3	
833	9'-4½	8	29.22	2	(See Notes)	9'-6	100	13.342	..... Route 4 ..... Sprinkler	
834	9'-4		29.22	2.1570		9'-6	0.010986	0.017		
								0.104		
834	9'-4	8	29.35	2	(See Notes)	9'-6	100	13.463	Sprinkler	
835	9'-3½		58.58	2.1570		9'-6	0.039770	0.017		
								0.378		
835	9'-3½	8	29.78	2	(See Notes)	9'-6	100	13.858	Sprinkler	
836	9'-3		88.36	2.1570		9'-6	0.085081	0.017		
								0.808		
836	9'-3	8	30.66	2	(See Notes)	9'-6	100	14.684	Sprinkler	
837	9'-2½		119.01	2.1570		9'-6	0.147616	0.017		
								1.402		
837	9'-2½	8	32.10	2	(See Notes)	3'-8½	100	16.103	Sprinkler, PO(8'-9½)	
573	9'-2½		151.12	2.1570		8'-9½	0.229620	0.007		
						12'-6		2.868		
								18.978	Total(Pt) Route 4	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes	
										Node 2
24	-3'-0		293.18	12	(See Notes)	1083'-5½	140	63.892		
8	28'-0		301.04	12.4600		185'-1½	0.000086	-13.438		
						1268'-7		0.109		
								50.562	Total(Pt) Route 5	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**


$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		





# Hydraulic Calculations

for

Project Name: Centeris UPS & Battery Rms  
Location: 1023 39th Ave SE, Puyallup, WA 98374,  
Drawing Name: Centeris v2

Calculation Date: 4/8/2024


## Design

Remote Area Number: 2  
Remote Area Location: UPS Rm  
Occupancy Classification: Ordinary Group II

Density: 0.20gpm/ft<sup>2</sup>  
Area of Application: 1500ft<sup>2</sup> (Actual 2003ft<sup>2</sup>)  
Coverage per Sprinkler: 122ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 21  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 2 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 2: 771.58 @ 47.749  
Type of System: Dbl. Interlock Pre-Action  
Volume of Dry/PreAction/Antifreeze/OtherAgent 338.51gal



Name of Contractor: Columbia Fire  
Address: 111 S Findlay St, Seattle, WA 98108  
Phone Number: (206) 232-8569  
Name of designer: Luke Thompson  
Authority Having Jurisdiction: City of Puyallyup

## Notes:


Automatic peaking results Left: N/A Right: N/A

# Hydraulic Graph

Job Name: Centeris UPS & Battery Rms  
Remote Area Number: 2

N<sup>1.85</sup>

Date: 4/8/2024





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	814	27.15	24.30	8	11.514		
⇒ Sprinkler	<b>815</b>	<b>24.30</b>	<b>24.30</b>	<b>8</b>	<b>9.226</b>		
Sprinkler	816	24.44	24.30	8	9.335		
Sprinkler	830	27.20	21.60	8	11.557		
Sprinkler	831	24.34	21.60	8	9.255		
Sprinkler	832	24.49	21.60	8	9.368		
Sprinkler	839	26.29	21.60	8	10.799		
Sprinkler	840	23.57	21.60	8	8.678		
Sprinkler	841	23.71	21.60	8	8.784		
Sprinkler	859	26.61	16.80	8	11.063		
Sprinkler	860	25.92	21.60	8	10.500		
Sprinkler	861	23.26	21.60	8	8.452		
Sprinkler	862	23.40	21.60	8	8.553		
Sprinkler	875	26.44	16.80	8	10.920		
Sprinkler	876	25.75	21.60	8	10.360		
Sprinkler	877	23.11	21.60	8	8.344		
Sprinkler	878	23.25	21.60	8	8.447		
Sprinkler	886	26.39	16.80	8	10.883		
Sprinkler	887	25.70	21.60	8	10.322		
Sprinkler	888	23.07	21.60	8	8.315		
Sprinkler	889	23.21	21.60	8	8.417		

⇒ Most Demanding Sprinkler Data

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
815	13'-0	8	24.30	1	(See Notes)	2'-11	120	9.226	••••• Route 1 ••••• Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)
512	18'-5½		24.30	1.0490		46'-0	0.186573	-2.359	
						48'-11		9.127	
512	18'-5½			2	(See Notes)	8'-0	100	15.994	
534	18'-5½		24.30	2.1570		8'-0	0.007810	-0.006	
								0.062	
534	18'-5½		24.34	2	(See Notes)	1'-9	100	16.051	Flow (q) from Route 11 T(8'-9½)
567	18'-5½		48.64	2.1570		8'-9½	0.028196	-0.001	
						10'-6½		0.297	
567	18'-5½		93.00	2	(See Notes)	3'-4½	100	16.347	Flow (q) from Route 3 PO(7'-1½)
566	15'-1½		141.64	2.0670		7'-1½	0.250681	1.460	
						10'-6		2.631	
566	15'-1½		142.50	4	(See Notes)	12'-1	100	20.438	Flow (q) from Route 2
563	15'-1		284.14	4.2600		12'-1	0.026849	0.009	
								0.325	
563	15'-1		54.34 + 103.66	4	(See Notes)	16'-0	100	20.771	Flow (q) from Route 13 and 14
561	15'-0½		442.14	4.2600		16'-0	0.060842	0.014	
								0.972	
561	15'-0½		79.44	4	(See Notes)	272'-3	100	21.758	Flow (q) from Route 18 6E(9'-4½), T(18'-9½)
81	10'-6		521.58	4.2600		75'-1½	0.082595	1.974	
						347'-4		28.689	
81	10'-6			6	(See Notes)	6'-11½	100	52.420	E(12'-6½), DPV(26'-4½)
87	3'-7		521.58	6.3570		38'-11	0.011758	3.009	
						45'-10		0.539	
87	3'-7			6	(See Notes)	9'-10½	120	55.969	BV(12'-7), E(17'-7), T(37'-8½)
204	1'-1½		521.58	6.3570		67'-11	0.008392	1.057	
						77'-9½		0.653	
204	1'-1½			8	(See Notes)	4'-1½	120	57.678	E(21'-1½)
12	-3'-0		521.58	8.2490		21'-1½	0.002359	1.788	
						25'-3		0.060	
12	-3'-0			8	(See Notes)	127'-8	140	59.526	GV(6'-9½), 2E(30'-6½), PIV(6'-9½), BFP, T(59'-4½)
44	-3'-0		521.58	8.3900		134'-0½	0.001634		
						261'-8½		0.427	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
44	-3'-0			12	(See Notes)	994'-9½	140	59.953		
27	28'-0		257.34	12.4600		337'-5½	0.000064	-13.438		
						1332'-3		0.086	3T(98'-3½), 2EE(21'-3½)	
27	28'-0		264.24	6	(See Notes)	42'-0	140	46.601	Flow (q) from Route 22 Water Supply	
2	26'-0		521.58	6.2800		42'-0	0.006695	0.867		
									0.281	
			250.00					47.749	Hose Allowance At Source	
2			771.58						Total(Pt) Route 1	
816	13'-0	8	24.44	1	(See Notes)	2'-11	120	9.335	••••• Route 2 ••••• Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)	
505	17'-1½		24.44	1.0490		46'-0	0.188606	-1.774		
						48'-11		9.226		
505	17'-1½			2		8'-0	100	16.788		
537	17'-1½		24.44	2.1570		8'-0	0.007895	-0.006		
								0.063		
537	17'-1½		24.49	2	(See Notes)	1'-9	100	16.845	Flow (q) from Route 12 T(8'-9½)	
569	17'-1½		48.93	2.1570		8'-9½	0.028509	-0.001		
						10'-6½		0.301		
569	17'-1½		93.57	2	(See Notes)	2'-0	100	17.144	Flow (q) from Route 5 PO(7'-1½)	
570	15'-1½		142.50	2.0670		7'-1½	0.253491	0.863		
						9'-1½		2.312		
570	15'-1½			4		14'-4	100	20.319		
566	15'-1½		142.50	4.2600		14'-4	0.007489	0.012		
								0.107		
								20.438	Total(Pt) Route 2	
888	13'-0	8	23.07	1	(See Notes)	2'-11½	120	8.315	••••• Route 3 ••••• Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)	
674	18'-6½		23.07	1.0490		46'-0	0.169466	-2.389		
						48'-11½		8.297		
674	18'-6½			2		8'-0	100	14.223		
646	18'-6		23.07	2.1570		8'-0	0.007094	0.006		
								0.057		
646	18'-6		23.11	2		8'-0	100	14.286	Flow (q) from Route 4	
616	18'-6		46.18	2.1570		8'-0	0.025614	0.006		
								0.205		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
616	18'-6		23.26	2		8'-0	100	14.497		
591	18'-6		69.44	2.1570		8'-0	0.054476	0.006		
								0.436		
591	18'-6		23.57	2	(See Notes)	6'-3	100	14.939	Flow (q) from Route 9 T(8'-9½)	
567	18'-5½		93.00	2.1570		8'-9½	0.093540	0.005		
						15'-0		1.404		
								16.347	Total(Pt) Route 3	
877	13'-0	8	23.11	1	(See Notes)	2'-11½	120	8.344	***** Route 4 ***** Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)	
646	18'-6		23.11	1.0490		46'-0	0.169999	-2.383		
						48'-11½		8.325		
								14.286	Total(Pt) Route 4	
889	13'-0	8	23.21	1	(See Notes)	2'-11	120	8.417	***** Route 5 ***** Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)	
677	17'-2		23.21	1.0490		46'-0	0.171377	-1.804		
						48'-11		8.384		
677	17'-2			2		8'-0	100	14.997	Flow (q) from Route 6	
649	17'-2		23.21	2.1570		8'-0	0.007174	0.006		
						8'-0		0.057		
649	17'-2		23.25	2		8'-0	100	15.060	Flow (q) from Route 8	
621	17'-2		46.46	2.1570		8'-0	0.025905	0.006		
						8'-0		0.207		
621	17'-2		23.40	2		8'-0	100	15.273	Flow (q) from Route 10 T(8'-9½)	
594	17'-1½		69.86	2.1570		8'-0	0.055089	0.006		
						8'-0		0.441		
594	17'-1½		23.71	2	(See Notes)	6'-3	100	15.720	Flow (q) from Route 10 T(8'-9½)	
569	17'-1½		93.57	2.1570		8'-9½	0.094594	0.005		
						15'-0		1.420		
								17.144	Total(Pt) Route 5	
878	13'-0	8	23.25	1	(See Notes)	2'-11	120	8.447	***** Route 6 ***** Sprinkler, 3E(2'-0), PO(5'-0), fd(35'-0)	
649	17'-2		23.25	1.0490		46'-0	0.171939	-1.798		
						48'-11		8.411		
								15.060	Total(Pt) Route 6	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
861	13'-0	8	23.26	1	(See Notes)	2'-11½	120	8.452		
616	18'-6		23.26	1.0490		46'-0	0.172038	-2.377		
						48'-11½		8.422		
								14.497	Total(Pt) Route 7	
862	13'-0	8	23.40	1	(See Notes)	2'-11	120	8.553		
621	17'-2		23.40	1.0490		46'-0	0.173943	-1.792		
						48'-11		8.512		
								15.273	Total(Pt) Route 8	
840	13'-0	8	23.57	1	(See Notes)	2'-11½	120	8.678		
591	18'-6		23.57	1.0490		46'-0	0.176294	-2.371		
						48'-11½		8.631		
								14.939	Total(Pt) Route 9	
841	13'-0	8	23.71	1	(See Notes)	2'-11	120	8.784		
594	17'-1½		23.71	1.0490		46'-0	0.178285	-1.786		
						48'-11		8.722		
								15.720	Total(Pt) Route 10	
831	13'-0	8	24.34	1	(See Notes)	2'-11½	120	9.255		
534	18'-5½		24.34	1.0490		46'-0	0.187107	-2.365		
						48'-11½		9.161		
								16.051	Total(Pt) Route 11	
832	13'-0	8	24.49	1	(See Notes)	2'-11	120	9.368		
537	17'-1½		24.49	1.0490		46'-0	0.189223	-1.780		
						48'-11		9.257		
								16.845	Total(Pt) Route 12	
814	13'-0	8	27.15	1	(See Notes)	0'-5	120	11.514		
508	15'-1		27.15	1.0490		42'-0	0.228996	-0.891		
						42'-5		9.714		
508	15'-1			2	(See Notes)	8'-0	100	20.337		
543	15'-1		27.15	2.1570		8'-0	0.009586	-0.006		
						8'-0		0.077		
543	15'-1		27.20	2	(See Notes)	1'-9	100	20.408		
563	15'-1		54.34	2.1570		8'-9½	0.034618	-0.001		
						10'-6½		0.365		



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
								20.771		
887	13'-0	8	25.70	1	(See Notes)	0'-5	120	10.322		***** Route 14 ***** Sprinkler, E(2'-0), PO(5'-0), fd(35'-0)
680	15'-1½		25.70	1.0490		42'-0	0.206973	-0.920		
					42'-5	8.779				
680	15'-1½			2		8'-0	100	18.180		
652	15'-1½		25.70	2.1570			0.008664	0.006	Flow (q) from Route 15	
					8'-0	0.069				
652	15'-1½		25.75	2		8'-0	100	18.256		
624	15'-1½		51.45	2.1570			0.031288	0.006		
					8'-0	0.250				
624	15'-1½		25.92	2		8'-0	100	18.512	Flow (q) from Route 16	
							0.066559	0.006		
597	15'-1		77.38	2.1570		8'-0		0.532		
597	15'-1		26.29	2	(See Notes)	6'-3	100	19.050	Flow (q) from Route 17 PO(8'-9½)	
						8'-9½	0.114342	0.005		
563	15'-1		103.66	2.1570		15'-0		1.716		
								20.771	Total(Pt) Route 14	
876	13'-0	8	25.75	1	(See Notes)	0'-5	120	10.360	***** Route 15 ***** Sprinkler, E(2'-0), PO(5'-0), fd(35'-0)	
652	15'-1½		25.75	1.0490		42'-0	0.207689	-0.915		
						42'-5		8.810		
								18.256	Total(Pt) Route 15	
860	13'-0	8	25.92	1	(See Notes)	0'-5	120	10.500	***** Route 16 ***** Sprinkler, E(2'-0), PO(5'-0), fd(35'-0)	
624	15'-1½		25.92	1.0490		42'-0	0.210286	-0.909		
						42'-5		8.920		
								18.512	Total(Pt) Route 16	
839	13'-0	8	26.29	1	(See Notes)	0'-5	120	10.799	***** Route 17 ***** Sprinkler, E(2'-0), PO(5'-0), fd(35'-0)	
597	15'-1		26.29	1.0490		42'-0	0.215806	-0.903		
						42'-5		9.154		
								19.050	Total(Pt) Route 17	
886	13'-0	8	26.39	1	(See Notes)	1'-6½	120	10.883	***** Route 18 ***** Sprinkler, 2E(2'-0), PO(5'-0), fd(35'-0)	
668	15'-1		26.39	1.0490		44'-0	0.217361	-0.903		
						45'-6½		9.899		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
668	15'-1			2		8'-0	100	19.879	
638	15'-1		26.39	2.1570		8'-0	0.009099	0.006	
638	15'-1		26.44	2		8'-0	100	19.958	
612	15'-1		52.83	2.1570		8'-0	0.032854	0.006	Flow (q) from Route 19
612	15'-1		26.61	2	(See Notes)	13'-0½	100	20.227	Flow (q) from Route 20 PO(8'-9½)
561	15'-0½		79.44	2.1570		8'-9½	0.069875	0.008	
						21'-9½		1.524	
								21.758	Total(Pt) Route 18
875	13'-0	8	26.44	1	(See Notes)	1'-7	120	10.920	***** Route 19 ***** Sprinkler, 2E(2'-0), PO(5'-0), fd(35'-0)
638	15'-1		26.44	1.0490		44'-0	0.218046	-0.897	
						45'-7		9.935	
								19.958	Total(Pt) Route 19
859	13'-0	8	26.61	1	(See Notes)	1'-7	120	11.063	***** Route 20 ***** Sprinkler, 2E(2'-0), PO(5'-0), fd(35'-0)
612	15'-1		26.61	1.0490		44'-0	0.220681	-0.891	
						45'-7		10.055	
								20.227	Total(Pt) Route 20
830	13'-0	8	27.20	1	(See Notes)	0'-5	120	11.557	***** Route 21 ***** Sprinkler, E(2'-0), PO(5'-0), fd(35'-0)
543	15'-1		27.20	1.0490		42'-0	0.229789	-0.897	
						42'-5		9.747	
								20.408	Total(Pt) Route 21
44	-3'-0		257.34	12	(See Notes)	1083'-5½	140	59.953	***** Route 22 ***** Flow (q) from Route 1 2EE(21'-3½), E(44'-3), T(98'-3½)
27	28'-0		264.24	12.4600		185'-1½	0.000068	-13.438	
						1268'-7		0.086	
								46.601	Total(Pt) Route 22

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

