

Fire Alarm

Cover Sheet

Last Contact Date: **04/18/22**☐ STATE☒ CITY☐

COUNTY: _____

Dept. Name:

City of Puyallup

Official Name:

Contact & Title:

Attention:

AHJ Dept. Name

Street Address:

333 S. Meridian

City, State, Zip:

Puyallup, WA 98371

Phone Number:

253-841-4321 ext.

Fax Number:

E-Mail:

Website:

Office Hours:

Review Number:

Plan Reviewers Contact Info:

If no review is necessary by this office, request that a letter be faxed / sent
US Mail

• Does the State require a separate review for Fire Alarms?

☐ YES ☒ NO

If yes, can you provide a contact number/name? _____

If State Fire Review is required, is a copy of the State Fire Marshal approval letter sent to you?

☐ YES ☒ NO

Or, are we required to send you a copy of the State Fire approval letter?

☐ YES ☒ NO

• Are plans submitted directly or routed from Building Dept. ?

☐ Routed☒ Submitted Direct

Number of Sets of Plans required:

1

CD required (what format & quantity)

Number of Spec Books required:

1

Revision CD Required?

Final/As-Built CD

Resubmittal Requirements:

1

Revised Sheets Only (Sets)

Full Set/s *Note whether copies or all originals

If revised sheets required, what is the process for resubmitting? (Do you integrate the revised sheets into first issue plans?)

• Submittal of plans required in person or via FedEx?

☐ In Person☐ FedEx☐ Either

• Is the contractor information required up front?

☒ YES ☐ NO

• Is submittal of plans via email an option?

☐ YES ☒ NO

If yes, what format do you prefer (ie. tif, pdf, etc) _____

Plan Review Time : 3 (Weeks)

Resubmittal Review Time: 3 (Weeks)

• Are any fees due at submittal ?

☐ YES ☒ NO

If yes, please fax copy of fee schedule. / If set fee, list amount:

\$

• Are any fees due when submitting revisions to plans?

☐ YES☒ NO

If yes, amt owed: \$

• Are any plan review applications and / or checklists required with plan submittal?

☒ YES ☐ NO

If yes, please list: _____

How may we obtain required forms?

☒ Website☐ Fax☐ Mail☒ E-mail

• Is the Owner signature required on applications or checklists?

☐ YES ☒ NO

If yes, please list: _____

• Is your review concurrent with Building and other depts.?

☒ YES ☐ NO

- If any code comments are issued, how may we obtain them?



Website



Fax



Mail



E-mail

- Are there any additional requirements to obtain a final inspection?

Comments:

Alarms

- Do you accept voice Evac in your jurisdiction?

☒ YES☐ NO

- Is class B wiring acceptable for notification appliances?

☒ YES☐ NO

The alarm design team should be notified immediately if the answer to the above 2 questions is untypical because that will significantly change the design. New Sams Clubs and new Super Centers are the only stores that have Voice Evac systems.

- Do you require Low Voltage wiring (50V and below), such as fire alarm, phone, computer, data, and/or security camera cables to be installed in conduit?

☐ YES☒ NO

- If YES: If the cables are plenum rated, is full conduit still required?

☐ YES☒ NO

- If YES, Where is the requirement documented in your Codes? We will need a copy of it.

- Does your jurisdiction accept COMcheck as means of documentation?

☐ YES☐ NO

- If NO: What documentation is required?

- Which versions of the following NFPA chapters are enforced?

NFPA 72
NFPA 101
IBC (any local amendments?)

Year

2016

Year

2018

Year

2018

- FACP location? ok

- Annunciator Keypad location? ok

- Per NFPA 101 a fully sprinklered building with automatic water flow activation, one pull station is required.

Typically this pull station is located in customer service, is this acceptable?

yes

Code references 2009 NFPA 101 are 36.3.4.2 and 9.6.2.6

- HVAC shutdown (individual/global)? individual

- Is it acceptable to use a UL listed combination fire alarm and burglar alarm control panel? **YES**

- Does the EOR who signs the drawings have to have certain NICETT Certification or is an Electrical EOR ok to sign?

PE OK

- Is it acceptable for the duct smoke alarm to be supervisory?

☒ YES☐ NO

- Do you require remote test switches for smoke detectors that are located inside the HVAC unit?

☐ YES☒ NO

- If YES, What Type? ☐ Keyed ☐ Magnetic

- Is it acceptable to provide smoke detectors only in HVAC units which are greater than 2000 CFM?

☒ YES☐ NO

- Where should the smoke detectors be placed?

☒ SA☐ RA☐ BOTH☐ EITHER

- Do roof-top units have to be interlocked (typically not required for retail stores)?

☐ YES☒ NO

- If simultaneous shut-down is required, our standard method is to use an in-house Energy Management System. Is this acceptable?

☒ YES☐ NO

- CO2 sensors are allowed by ASHRAE Standard 62 for air quality control. Is the use of CO2 sensors acceptable?

☐ YES☐ NO

If the next 3 questions are not applicable, please answer N/A for Non-Applicable.

- How long are reviewed/approved plans good before permit must be pulled?

180 days☐ N/A

- From the date of permit issue, how long is permit valid?

180 days☐ N/A

- When must construction start from issuance of permit?

180 days☐ N/A

Is an extension available?

.....

x

YESNO

If yes, how long is the extension good for?

TBD

Are any fees required for the extension and if so what are the required fees?

\$TBD

.....

N/A

- Are the GC or Subs required to submit any type of wet signed / sealed drawings (Including Shop Drawings) above and beyond AOR submittal? ☐ YES ☒ NO
If yes, then number of sets required and submittal timeframe. _____
- When is the first inspection due after the permit is picked up? 180 days
- Do you require plans approved/stamped by your department to be on the construction site? ☒ YES ☐ NO
- Is the Engineer of Record required to complete Construction Observation ☐ YES ☒ NO

Additional Information : _____

