



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 09, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: LEVEL 3

1 SE stairwell interior rated walls approved ok to cover

Corrections:

- 1 SE STAIR WELL
 - 1.complete firestop
 - 2.complete insulation as discussed with contractorLEVEL THREE
 - 1.complete rigid insulation at header as discussed with contractor
- 2
 1. SE stairwell level o, 1, 2, exterior walls and rated walls ok to cover
 2. level three SE stair well complete insulation and putty packs at electrical boxes do not cover

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org