



# Hydraulic Overview



Job Number: 22-3688  
Report Description: Ordinary Group I (1)

Job	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP

System	
Density 0.15 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 922 ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.6 K-Factor 14.85 at 7.032	Hose Streams 250.00
Coverage Per Sprinkler 99 ft <sup>2</sup>	Number Of Sprinklers Calculated 19
System Pressure Demand 43.250	System Flow Demand 313.54
Total Demand 563.54 @ 43.250	Pressure Result +16.323 (27.4%)

Supplies						Check Point Gauges			
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	1950.00	250.00	64.000	20.000				



FPET NICET #106245 LEVEL IV,MSME

**WASHINGTON STATE  
CERTIFICATE OF COMPETENCY  
FIRE PROTECTION SPRINKLER SYSTEMS**

Hussein A. A. Huballa  
8321-1119-C Level 3  
Shinn Mechanical, Inc.  
SHINNMI060QP

*Hussein A. A. Huballa*  
Signature      03/26/2024      Date      Expires 12/31/24


22-3688\_PeirceSTEM-L00-Asbuilt      Water Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)







### Water Supply at Node 1



Hydraulic Graph  
Water Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
59.573 @ 563.54

Required Pressure at System Demand  
43.250 @ 313.54

Required Pressure at System Demand (Including Hose Allowance at Source)  
43.250 @ 563.54



# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	1000	22.33	14.85	5.6	15.895		
Sprinkler	1001	21.11	14.85	5.6	14.208		
Sprinkler	1002	15.73	14.85	5.6	7.886		
Sprinkler	1003	15.82	14.85	5.6	7.979		
Sprinkler	1004	15.35	14.85	5.6	7.512		
Sprinkler	1005	15.44	14.85	5.6	7.602		
Sprinkler	1006	15.14	14.85	5.6	7.312		
Sprinkler	1007	19.79	14.85	5.6	12.483		
Sprinkler	1008	15.23	14.85	5.6	7.393		
Sprinkler	1009	20.01	14.85	5.6	12.771		
Sprinkler	1010	16.15	14.85	5.6	8.316		
Sprinkler	1011	14.87	14.85	5.6	7.051		
Sprinkler	1012	14.96	14.85	5.6	7.135		
Sprinkler	1013	15.76	14.85	5.6	7.924		
➔ Sprinkler	<b>1014</b>	<b>14.85</b>	<b>14.85</b>	<b>5.6</b>	<b>7.032</b>		
Sprinkler	1015	14.94	14.85	5.6	7.115		
Sprinkler	1016	15.55	14.85	5.6	7.711		
Sprinkler	1017	15.27	14.85	5.6	7.439		
Sprinkler	1018	15.25	14.85	5.6	7.416		

➔ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Ordinary Group I (1)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	-15'-0	S	43.250	313.54
1000	0'-5	Spr(-15.895)	15.895	22.33
1001	0'-5	Spr(-14.208)	14.208	21.11
1002	0'-4½	Spr(-7.886)	7.886	15.73
1003	0'-4½	Spr(-7.979)	7.979	15.82
1004	0'-4	Spr(-7.512)	7.512	15.35
1005	0'-4	Spr(-7.602)	7.602	15.44
1006	0'-4	Spr(-7.312)	7.312	15.14
1007	0'-2½	Spr(-12.483)	12.483	19.79
1008	0'-4	Spr(-7.393)	7.393	15.23
1009	0'-4½	Spr(-12.771)	12.771	20.01
1010	0'-4½	Spr(-8.316)	8.316	16.15
1011	0'-3½	Spr(-7.051)	7.051	14.87
1012	0'-3½	Spr(-7.135)	7.135	14.96
1013	0'-4	Spr(-7.924)	7.924	15.76
1014	0'-3½	Spr(-7.032)	7.032	14.85
1015	0'-3½	Spr(-7.115)	7.115	14.94
1016	0'-4	Spr(-7.711)	7.711	15.55
1017	0'-3½	Spr(-7.439)	7.439	15.27
1018	0'-3½	Spr(-7.416)	7.416	15.25
2	-15'-0	PIV(-2.000)	43.110	
3	-15'-0	BFP(-1.275)	41.082	
6	-15'-0	PO(20'-0)	39.797	
7	-8'-9½		36.721	
8	-8'-2	St(-0.221)	36.450	
100	-7'-0	PO(20'-2)	35.723	
101	-4'-9½		25.221	
102	-1'-5	PO(5'-0)	18.459	
103	-1'-4	PO(5'-0)	16.554	
104	-1'-3	PO(5'-0)	14.898	
105	-1'-3	PO(5'-0)	14.669	
106	-0'-3	PO(8'-0)	9.750	
107	-0'-3½	PO(8'-0)	9.306	
108	-0'-3½	PO(8'-0)	8.959	
109	-0'-4	PO(8'-0)	8.757	
110	-0'-4	PO(8'-0)	8.733	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group I (1)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
<b>Route 1</b>							
BL	1.6100	14.85	2.34	120	0.009313	9'-0"	Pf 0.084
1014	0'-3½"	14.85	5.6	7.032	Sprinkler		Pe -0.001
1015	0'-3½"			7.115		9'-0"	Pv
BL	1.6100	29.79	4.69	120	0.033757	8'-11½"	Pf 0.303
1015	0'-3½"	14.94	5.6	7.115	Sprinkler		Pe -0.001
1018	0'-3½"			7.416		8'-11½"	Pv
BL	1.6100	45.04	7.10	120	0.072531	2'-5"	Pf 1.046
1018	0'-3½"	15.25	5.6	7.416	Sprinkler,	12'-0"	Pe 0.271
110	-0'-4"			8.733	E(4'-0"), PO(8'-0)	14'-5"	Pv
FR	2.6350	45.04	2.65	120	0.006585	4'-6½"	Pf 0.030
110	-0'-4"			8.733			Pe -0.006
109	-0'-4"			8.757		4'-6½"	Pv
FR	2.6350	90.14	5.30	120	0.023771	9'-0"	Pf 0.214
109	-0'-4"	45.10		8.757	Flow (q) from Route 2		Pe -0.012
108	-0'-3½"			8.959		9'-0"	Pv
FR	2.6350	136.06	8.00	120	0.050915	7'-0"	Pf 0.356
108	-0'-3½"	45.92		8.959	Flow (q) from Route 3		Pe -0.009
107	-0'-3½"			9.306		7'-0"	Pv
FR	2.6350	182.61	10.74	120	0.087757	5'-1½"	Pf 0.450
107	-0'-3½"	46.55		9.306	Flow (q) from Route 4		Pe -0.007
106	-0'-3"			9.750		5'-1½"	Pv
FR	2.6350	230.31	13.55	120	0.134808	8'-7½"	Pf 4.491
106	-0'-3"	47.69		9.750	Flow (q) from Route 5	24'-8½"	Pe 0.428
105	-1'-3"			14.669	3E(8'-3)	33'-4"	Pv
FR	2.6350	250.09	14.71	120	0.157012	1'-5"	Pf 0.224
105	-1'-3"	19.79		14.669	Flow (q) from Route 6		Pe 0.005
104	-1'-3"			14.898		1'-5"	Pv
FR	2.6350	270.10	15.89	120	0.181042	8'-11½"	Pf 1.625
104	-1'-3"	20.01		14.898	Flow (q) from Route 7		Pe 0.031
103	-1'-4"			16.554		8'-11½"	Pv
FR	2.6350	291.21	17.13	120	0.208083	9'-0"	Pf 1.874
103	-1'-4"	21.11		16.554	Flow (q) from Route 8		Pe 0.031
102	-1'-5"			18.459		9'-0"	Pv
FR	2.6350	313.54	18.45	120	0.238554	5'-8½"	Pf 5.294
102	-1'-5"	22.33		18.459	Flow (q) from Route 9	16'-5½"	Pe 1.468
101	-4'-9½"			25.221	2E(8'-3)	22'-2½"	Pv
CM	3.2600	313.54	12.05	120	0.084610	40'-7"	Pf 9.538
101	-4'-9½"			25.221		36'-8½"	Pe 0.964
100	-7'-0"			35.723	f(-3.000), sCV(7'-1½"), E(9'-5), PO(20'-2)	77'-3½"	Pv
CM	6.3570	313.54	3.17	120	0.003273	1'-2"	Pf 0.224
100	-7'-0"			35.723			Pe 0.503
8	-8'-2"			36.450	St(-0.221)	1'-2"	Pv
DY	6.3400	313.54	3.19	140	0.002493	0'-0"	Pf 0.000
8	-8'-2"			36.450			Pe 0.271
7	-8'-9½"			36.721		0'-0"	Pv
UG	6.3400	313.54	3.19	140	0.002493	86'-3½"	Pf 0.388
7	-8'-9½"			36.721		69'-4"	Pe 2.688
6	-15'-0"			39.797	3E(23'-1½")	155'-7½"	Pv
UG	6.3400	313.54	3.19	140	0.002493	4'-1½"	Pf 1.285
6	-15'-0"			39.797			Pe
3	-15'-0"			41.082	BFP(-1.275)	4'-1½"	Pv
UG	6.3400	313.54	3.19	140	0.002493	11'-2½"	Pf 2.028
3	-15'-0"			41.082			Pe
2	-15'-0"			43.110	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	313.54	3.19	140	0.002493	21'-7"	Pf 0.140
2	-15'-0"			43.110		34'-8"	Pe
1	-15'-0"			43.250	E(23'-1½"), EE(11'-6½"), S	56'-3"	Pv
		250.00			Hose Allowance At Source		
1		563.54					
<b>Route 2</b>							
BL	1.6100	14.87	2.34	120	0.009337	9'-0"	Pf 0.084
1011	0'-3½"	14.87	5.6	7.051	Sprinkler		Pe 0.000
1012	0'-3½"			7.135		9'-0"	Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
BL	1.6100	29.83	4.70	120	0.033844	8'-11½"	Pf 0.304
1012	0'-3½"	14.96	5.6	7.135	Sprinkler		Pe 0.000
1017	0'-3½"			7.439			Pv
BL	1.6100	45.10	7.11	120	0.072725	2'-5" 12'-0" 14'-5"	Pf 1.048
1017	0'-3½"	15.27	5.6	7.439	Sprinkler,		Pe 0.270
109	-0'-4"			8.757	E(4'-0), PO(8'-0)		Pv
<b>Route 3</b>							
BL	1.6100	15.14	2.39	120	0.009656	8'-0"	Pf 0.077
1006	0'-4"	15.14	5.6	7.312	Sprinkler		Pe 0.004
1008	0'-4"			7.393			Pv
BL	1.6100	30.37	4.79	120	0.034987	8'-11½"	Pf 0.314
1008	0'-4"	15.23	5.6	7.393	Sprinkler		Pe 0.004
1016	0'-4"			7.711			Pv
BL	1.6100	45.92	7.24	120	0.075180	1'-0" 12'-0" 13'-0"	Pf 0.977
1016	0'-4"	15.55	5.6	7.711	Sprinkler,		Pe 0.271
108	-0'-3½"			8.959	E(4'-0), PO(8'-0)		Pv
<b>Route 4</b>							
BL	1.6100	15.35	2.42	120	0.009900	9'-0"	Pf 0.089
1004	0'-4"	15.35	5.6	7.512	Sprinkler		Pe 0.000
1005	0'-4"			7.602			Pv
BL	1.6100	30.79	4.85	120	0.035887	8'-11½"	Pf 0.322
1005	0'-4"	15.44	5.6	7.602	Sprinkler		Pe 0.000
1013	0'-4"			7.924			Pv
BL	1.6100	46.55	7.34	120	0.077109	2'-5" 12'-0" 14'-5"	Pf 1.112
1013	0'-4"	15.76	5.6	7.924	Sprinkler,		Pe 0.271
107	-0'-3½"			9.306	E(4'-0), PO(8'-0)		Pv
<b>Route 5</b>							
BL	1.6100	15.73	2.48	120	0.010355	9'-0"	Pf 0.093
1002	0'-4½"	15.73	5.6	7.886	Sprinkler		Pe 0.000
1003	0'-4½"			7.979			Pv
BL	1.6100	31.54	4.97	120	0.037534	8'-11½"	Pf 0.337
1003	0'-4½"	15.82	5.6	7.979	Sprinkler		Pe 0.000
1010	0'-4½"			8.316			Pv
BL	1.6100	47.69	7.52	120	0.080642	2'-5" 12'-0" 14'-5"	Pf 1.163
1010	0'-4½"	16.15	5.6	8.316	Sprinkler,		Pe 0.271
106	-0'-3"			9.750	E(4'-0), PO(8'-0)		Pv
<b>Route 6</b>							
SP	1.0490	19.79	7.34	120	0.127557	3'-2½" 9'-0" 12'-2½"	Pf 1.560
1007	0'-2½"	19.79	5.6	12.483	Sprinkler,		Pe 0.627
105	-1'-3"			14.669	2E(2'-0), PO(5'-0)		Pv
<b>Route 7</b>							
FR	1.0490	20.01	7.43	120	0.130278	3'-10½" 7'-0" 10'-10½"	Pf 1.417
1009	0'-4½"	20.01	5.6	12.771	Sprinkler,		Pe 0.710
104	-1'-3"			14.898	E(2'-0), PO(5'-0)		Pv
<b>Route 8</b>							
FR	1.0490	21.11	7.84	120	0.143787	4'-0" 7'-0" 11'-0"	Pf 1.582
1001	0'-5"	21.11	5.6	14.208	Sprinkler,		Pe 0.764
103	-1'-4"			16.554	E(2'-0), PO(5'-0)		Pv
<b>Route 9</b>							
FR	1.0490	22.33	8.29	120	0.159511	4'-1" 7'-0" 11'-1"	Pf 1.767
1000	0'-5"	22.33	5.6	15.895	Sprinkler,		Pe 0.797
102	-1'-5"			18.459	E(2'-0), PO(5'-0)		Pv

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

### C Value Multiplier

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 22-3688

Report Description: Ordinary Group I (1)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap





# Hydraulic Overview

Job Number: 22-3688  
Report Description: Ordinary Group II (2)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.20 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1032 ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.63 K-Factor 26.00 at 21.336	Hose Streams 250.00
Coverage Per Sprinkler 100 ft <sup>2</sup>	Number Of Sprinklers Calculated 15
	Number Of Nozzles Calculated 0
System Pressure Demand 48.659	System Flow Demand 382.76
Total Demand 632.76 @ 48.659	Pressure Result +10.708 (18.0%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	250.00	64.000	20.000
FPET NICET #106245 LEVEL IV,MSME					
<div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>[Signature]</i>      03/26/2024      Expires 12/31/24</p> <p>Signature      Date</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L01-Asbuilt


Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)







### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure  
20.000 @ 1950.00

Available Flow @ 20 PSI:  
0.00

Available Pressure at System Demand  
59.367 @ 632.76

Required Pressure at System Demand  
48.659 @ 382.76

Required Pressure at System Demand (Including Hose Allowance at Source)  
48.659 @ 632.76



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 2200	26.09	20.00	5.63	21.484			
Sprinkler 2201	26.06	20.00	5.63	21.432			
Sprinkler 2202	25.38	20.00	5.63	20.337			
Sprinkler 2203	25.06	20.00	5.63	19.820			
Sprinkler 2204	24.65	20.00	5.63	19.184			
Sprinkler 2205	24.58	20.00	5.63	19.075			
Sprinkler 2206	24.56	20.00	5.63	19.039			
Sprinkler 2207	25.67	20.00	5.63	20.799			
Sprinkler 2208	25.43	20.00	5.63	20.406			
Sprinkler 2209	25.52	20.00	5.63	20.558			
Sprinkler 2210	27.10	26.00	5.63	23.187			
Sprinkler 2211	25.32	20.00	5.63	20.232			
Sprinkler 2212	25.27	20.00	5.63	20.158			
Sprinkler 2213	26.05	26.00	5.63	21.425			
⇒ <b>Sprinkler 2214</b>	<b>26.00</b>	<b>26.00</b>	<b>5.63</b>	<b>21.336</b>			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
222	112'-0	PO(5'-0)	22.307	
223	112'-0	E(2'-0)	22.419	
224	112'-0	PO(5'-0)	21.247	
225	112'-0	T(9'-11)	21.470	
226	112'-0	PO(5'-0)	21.172	
1	84'-6½	S	48.659	382.76
2200	113'-9½	Spr(-21.484)	21.484	26.09
2201	113'-9½	Spr(-21.432)	21.432	26.06
2202	113'-9½	Spr(-20.337)	20.337	25.38
2203	113'-9½	Spr(-19.820)	19.820	25.06
2204	113'-9½	Spr(-19.184)	19.184	24.65
2205	113'-9	Spr(-19.075)	19.075	24.58
2206	113'-9	Spr(-19.039)	19.039	24.56
2207	113'-9½	Spr(-20.799)	20.799	25.67
2208	113'-9½	Spr(-20.406)	20.406	25.43
2209	113'-9½	Spr(-20.558)	20.558	25.52
2210	108'-7½	Spr(-23.187), fd	23.187	27.10
2211	113'-9½	Spr(-20.232)	20.232	25.32
2212	113'-9½	Spr(-20.158)	20.158	25.27
2213	108'-7½	Spr(-21.425), fd	21.425	26.05
2214	108'-7½	Spr(-21.336), fd	21.336	26.00
2	84'-6½	PIV(-2.000)	48.446	
3	84'-6½	BFP(-1.831)	46.403	
6	84'-6½	PO(20'-0)	44.556	
7	90'-9		41.278	
8	91'-4½	St(-0.378)	41.008	
9	102'-6½	PO(20'-2)	35.604	
200	111'-5	PO(20'-2)	25.161	
201	112'-5½		24.671	
202	113'-2	E(8'-3)	23.977	
203	111'-5	PO(16'-5½)	24.563	
204	112'-2	PO(12'-3½)	24.660	
205	112'-0	PO(12'-3½)	24.176	
206	112'-0	PO(5'-0)	23.708	
207	112'-0	PO(5'-0)	23.666	
208	112'-0	PO(5'-0)	22.485	
209	112'-0	PO(12'-3½)	24.148	
210	112'-0	PO(5'-0)	21.934	
211	112'-0	PO(5'-0)	21.269	
212	112'-0	PO(5'-0)	21.127	
213	112'-0	PO(5'-0)	21.088	
214	112'-0	PO(5'-0)	23.337	
215	112'-0	PO(20'-2)	24.138	
216	112'-0		23.198	
217	112'-0	PO(5'-0)	22.977	
218	112'-0	PO(9'-11)	22.676	
219	112'-0	PO(5'-0)	22.558	
220	112'-0	PO(5'-0)	22.373	
221	112'-0	PO(9'-11)	22.317	



# Hydraulic Overview



Job Number: 22-3688  
Report Description: Light Hazard (3)

<b>Job</b>		
Job Number 22-3688	Designer Ben Bernard	
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945	FAX
Address 1 1601 39th AVE SE	State Certification/License Number	
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP	
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP	

<b>System</b>		
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1099 ft <sup>2</sup> )	
Most Demanding Sprinkler Data 5.63 K-Factor 14.89 at 7.000	Hose Streams 100.00	
Coverage Per Sprinkler 100 ft <sup>2</sup>	Number Of Sprinklers Calculated 22	Number Of Nozzles Calculated 0
System Pressure Demand 49.807	System Flow Demand 394.50	
Total Demand 494.50 @ 49.807	Pressure Result +11.364 (18.6%)	

<b>Supplies</b>						<b>Check Point Gauges</b>			
<u>Node</u>	<u>Name</u>	<u>Flow(gpm)</u>	<u>Hose Flow(gpm)</u>	<u>Static(psi)</u>	<u>Residual(psi)</u>	<u>Identifier</u>	<u>Pressure(psi)</u>	<u>K-Factor(K)</u>	<u>Flow(gpm)</u>
1	Water Supply	1950.00	100.00	64.000	20.000				
<p>FPET NICET #106245 LEVEL IV,MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p style="text-align: center;"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNM1060QP</p> <p><i>Signature</i>      03/26/2024      Expires 12/31/24</p> </div>									

22-3688\_PeirceSTEM-L01-Asbuilt      Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)











# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 3200	27.52	14.89	5.63	23.905			
Sprinkler 3201	19.47	14.89	5.63	11.965			
Sprinkler 3202	19.24	14.89	5.63	11.681			
Sprinkler 3203	19.39	14.89	5.63	11.869			
Sprinkler 3204	19.14	14.89	5.63	11.563			
Sprinkler 3205	18.62	14.89	5.63	10.937			
Sprinkler 3206	16.40	14.89	5.63	8.492			
Sprinkler 3207	18.32	14.89	5.63	10.598			
Sprinkler 3208	18.06	14.89	5.63	10.293			
Sprinkler 3209	17.69	14.89	5.63	9.880			
Sprinkler 3210	17.71	14.89	5.63	9.897			
Sprinkler 3211	17.56	14.89	5.63	9.728			
Sprinkler 3212	16.71	14.89	5.63	8.817			
Sprinkler 3213	15.65	14.89	5.63	7.728			
Sprinkler 3214	15.30	14.89	5.63	7.391			
<b>⇒ Sprinkler 3215</b>	<b>14.89</b>	<b>14.89</b>	<b>5.63</b>	<b>7.000</b>			
Sprinkler 3216	17.92	14.89	5.63	10.130			
Sprinkler 3217	16.71	14.89	5.63	8.817			
Sprinkler 3218	16.86	14.89	5.63	8.975			
Sprinkler 3219	16.98	14.89	5.63	9.098			
Sprinkler 3220	17.06	14.89	5.63	9.187			
Sprinkler 3221	17.30	14.89	5.63	9.442			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	49.807	394.50
3200	113'-2½	Spr(-23.905)	23.905	27.52
3201	113'-4½	Spr(-11.965)	11.965	19.47
3202	113'-3½	Spr(-11.681)	11.681	19.24
3203	113'-4½	Spr(-11.869)	11.869	19.39
3204	113'-3½	Spr(-11.563)	11.563	19.14
3205	109'-11½	Spr(-10.937), fd	10.937	18.62
3206	113'-3	Spr(-8.492)	8.492	16.40
3207	113'-6	Spr(-10.598)	10.598	18.32
3208	113'-6	Spr(-10.293)	10.293	18.06
3209	113'-6½	Spr(-9.880)	9.880	17.69
3210	112'-7½	Spr(-9.897)	9.897	17.71
3211	113'-6	Spr(-9.728)	9.728	17.56
3212	109'-11½	Spr(-8.817), fd	8.817	16.71
3213	112'-10	Spr(-7.728)	7.728	15.65
3214	113'-7½	Spr(-7.391)	7.391	15.30
3215	112'-10	Spr(-7.000)	7.000	14.89
3216	109'-11½	Spr(-10.130), fd	10.130	17.92
3217	113'-2	Spr(-8.817)	8.817	16.71
3218	113'-2	Spr(-8.975)	8.975	16.86
3219	113'-2	Spr(-9.098)	9.098	16.98
3220	113'-2	Spr(-9.187)	9.187	17.06
3221	113'-2	Spr(-9.442)	9.442	17.30
2	84'-6½	PIV(-2.000)	49.581	
3	84'-6½	BFP(-1.945)	47.536	
6	84'-6½	PO(20'-0)	45.574	
7	90'-9		42.261	
8	91'-4½	St(-0.408)	41.990	
9	102'-6½	PO(20'-2)	36.545	
200	111'-5	PO(20'-2)	26.066	
201	112'-5½		22.929	
202	113'-2	E(6'-2)	13.303	
203	111'-5	PO(16'-5½)	25.852	
204	112'-2	PO(12'-3½)	12.385	
300	111'-5	PO(16'-5½)	25.917	
301	112'-9½	PO(8'-0)	25.110	
302	111'-10½	E(4'-0)	18.243	
303	113'-4½	E(4'-11½)	12.268	
304	112'-10	PO(8'-0)	12.915	
305	111'-5	PO(10'-0)	25.874	
306	112'-8½	PO(5'-0)	11.578	
307	112'-7½	PO(5'-0)	10.405	
308	112'-8½	PO(5'-0)	11.255	
309	112'-2	PO(8'-0)	13.740	
310	112'-7½	PO(5'-0)	9.987	
311	112'-8½	PO(5'-0)	10.830	
312	112'-8½	PO(5'-0)	10.657	
313	113'-2	T(5'-0)	8.378	
314	112'-10	T(5'-0)	7.781	
315	113'-2	PO(6'-0)	9.750	
316	113'-2	PO(5'-0)	9.715	
317	112'-8½	PO(5'-0)	11.083	
318	111'-11½	T(5'-0)	9.263	
319	112'-2	PO(8'-0)	12.691	
320	113'-2	PO(5'-0)	9.715	
321	113'-2	PO(5'-0)	9.726	
322	113'-2	PO(5'-0)	9.771	
323	113'-2	PO(12'-3½)	10.065	
324	113'-2	PO(5'-0)	10.031	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (3)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
BL	1.0490	14.89	5.53	0.004"	0.072309	5'-9½"	Pf 0.781
3215	112'-10"	14.89	5.63 (adj)	7.000	Sprinkler,	5'-0"	Pe
314	112'-10"			7.781	T(5'-0)	10'-9½"	Pv
BL	1.3800	30.54	6.55	0.004"	0.070455	4'-6½"	Pf 0.742
314	112'-10"	15.65		7.781	Flow (q) from Route 3	6'-0"	Pe -0.145
313	113'-2"			8.378	2E(3'-0)	10'-6½"	Pv
BL	1.3800	45.84	9.83	0.004"	0.155244	2'-10"	Pf 1.372
313	113'-2"	15.30		8.378	Flow (q) from Route 2	6'-0"	Pe
315	113'-2"			9.750	PO(6'-0)	8'-10"	Pv
CM	2.1570	65.04	5.71	0.004"	0.030564	10'-10½"	Pf 0.709
315	113'-2"	19.20		9.750	Flow (q) from Route 6	12'-3½"	Pe 0.199
312	112'-8½"			10.657	2E(6'-2)	23'-2½"	Pv
CM	2.1570	82.60	7.25	0.004"	0.048559	3'-6½"	Pf 0.173
312	112'-8½"	17.56		10.657	Flow (q) from Route 11		Pe 0.000
311	112'-8½"			10.830		3'-6½"	Pv
CM	2.1570	100.29	8.81	0.004"	0.070849	6'-0"	Pf 0.425
311	112'-8½"	17.69		10.830	Flow (q) from Route 12		Pe 0.000
308	112'-8½"			11.255		6'-0"	Pv
CM	2.1570	118.35	10.39	0.004"	0.097898	3'-3½"	Pf 0.323
308	112'-8½"	18.06		11.255	Flow (q) from Route 15		Pe 0.000
306	112'-8½"			11.578		3'-3½"	Pv
CM	2.1570	136.67	12.00	0.004"	0.129779	2'-6"	Pf 1.924
306	112'-8½"	18.32		11.578	Flow (q) from Route 16	12'-3½"	Pe -0.199
202	113'-2"			13.303	2E(6'-2)	14'-10"	Pv
CM	2.6350	136.67	8.04	0.004"	0.046104	128'-2½"	Pf 11.797
202	113'-2"			13.303		127'-8"	Pe 0.752
203	111'-5"			25.852	4PO(16'-5½"), 5E(8'-3), T(16'-5½") , EE(4'-1½")	255'-10½"	Pv
CM	6.3570	136.67	1.38	0.004"	0.000534	40'-7½"	Pf 0.022
203	111'-5"			25.852			Pe
305	111'-5"			25.874		40'-7½"	Pv
CM	6.3570	213.91	2.16	0.004"	0.001236	34'-9½"	Pf 0.043
305	111'-5"	77.24		25.874	Flow (q) from Route 18		Pe
300	111'-5"			25.917		34'-9½"	Pv
CM	6.3570	241.44	2.44	0.004"	0.001554	60'-11½"	Pf 0.149
300	111'-5"	27.52		25.917	Flow (q) from Route 20	35'-2½"	Pe
200	111'-5"			26.066	2E(17'-7)	96'-2"	Pv
CM	6.3570	394.50	3.99	0.004"	0.003964	68'-8"	Pf 6.630
200	111'-5"	153.07		26.066	Flow (q) from Route 4	90'-2"	Pe 3.849
9	102'-6½"			36.545	2E(17'-7), sCV(-6.000), sCV(17'- 2½"), PO(37'-8½")	158'-10"	Pv
CM	6.3570	394.50	3.99	0.004"	0.003964	20'-5"	Pf 0.609
9	102'-6½"			36.545		30'-2"	Pe 4.836
8	91'-4½"			41.990	BV(12'-7), E(17'-7), St(-0.408)	50'-7"	Pv
DY	6.3400	394.50	4.01	0.004"	0.004018	0'-0"	Pf 0.000
8	91'-4½"			41.990			Pe 0.271
7	90'-9"			42.261		0'-0"	Pv
UG	6.3400	394.50	4.01	0.004"	0.004018	86'-3½"	Pf 0.625
7	90'-9"			42.261		69'-4"	Pe 2.688
6	84'-6½"			45.574	3E(23'-1½")	155'-7½"	Pv
UG	6.3400	394.50	4.01	0.004"	0.004018	4'-1½"	Pf 1.962
6	84'-6½"			45.574			Pe
3	84'-6½"			47.536	BFP(-1.945)	4'-1½"	Pv
UG	6.3400	394.50	4.01	0.004"	0.004018	11'-2½"	Pf 2.045
3	84'-6½"			47.536			Pe
2	84'-6½"			49.581	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	394.50	4.01	0.004"	0.004018	21'-7"	Pf 0.226
2	84'-6½"			49.581		34'-8"	Pe
1	84'-6½"			49.807	E(23'-1½"), EE(11'-6½"), S	56'-3"	Pv
1		100.00			Hose Allowance At Source		
1		494.50					
<b>Route 2</b>							
SP	1.0490	15.30	5.68	0.004"	0.076196	3'-2½"	Pf 0.779
3214	113'-7½"	15.30	5.63 (adj)	7.391	Sprinkler,	7'-0"	Pe 0.208
313	113'-2"			8.378	E(2'-0), T(5'-0)	10'-2½"	Pv
<b>Route 3</b>							



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (3)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.3800	15.65	3.36	0.004"	0.019518		
3213	112'-10	15.65	5.63 (adj)	7.728	Sprinkler	2'-9	Pf 0.053
314	112'-10			7.781		2'-9	Pe Pv
<b>Route 4</b>							
BL	1.0490	16.40	6.09	0.004"	0.087122		
3206	113'-3	16.40	5.63 (adj)	8.492	Sprinkler,	7'-0	Pf 1.219
310	112'-7½			9.987	E(2'-0), PO(5'-0)	14'-0	Pe 0.277 Pv
BL	1.6100	34.11	5.38	0.004"	0.039465		
310	112'-7½	17.71		9.987	Flow (q) from Route 13	2'-6½	Pf 0.417
307	112'-7½			10.405	PO(8'-0)	8'-0	Pe 0.000
						10'-6½	Pv
BL	1.6100	52.73	8.31	0.004"	0.091776		
307	112'-7½	18.62		10.405	Flow (q) from Route 17	14'-2	Pf 3.137
309	112'-2			13.740	2PO(8'-0), E(4'-0)	20'-0	Pe 0.198
						34'-2	Pv
CM	2.6350	153.07	9.01	0.004"	0.057495		
309	112'-2	100.34		13.740	Flow (q) from Route 5	71'-6½	Pf 9.323
201	112'-5½			22.929	5E(8'-3), PO(16'-5½), C(16'-5½), T(16'-5½)	90'-7½	Pe -0.134
						162'-2	Pv
CM	3.2600	153.07	5.88	0.004"	0.019242		
201	112'-5½			22.929		81'-5	Pf 2.678
200	111'-5			26.066	4E(9'-5), PO(20'-2)	57'-9½	Pe 0.459
						139'-2½	Pv
<b>Route 5</b>							
BL	1.0490	16.71	6.20	0.004"	0.090342		
3212	109'-11½	16.71	5.63 (adj)	8.817	Sprinkler,	9'-6½	Pf 1.314
318	111'-11½			9.263	T(5'-0), fd	5'-0	Pe -0.867
						14'-6½	Pv
BL	1.0490	34.63	12.86	0.004"	0.373400		
318	111'-11½	17.92		9.263	Flow (q) from Route 14	0'-9½	Pf 2.158
317	112'-8½			11.083	PO(5'-0)	5'-0	Pe -0.338
						5'-9½	Pv
BL	1.6100	34.63	5.46	0.004"	0.040630		
317	112'-8½			11.083		13'-7½	Pf 1.365
319	112'-2			12.691	2PO(8'-0), E(4'-0)	20'-0	Pe 0.242
						33'-7½	Pv
CM	2.6350	100.34	5.90	0.004"	0.025307		
319	112'-2	65.71		12.691	Flow (q) from Route 7	25'-0	Pf 1.049
309	112'-2			13.740	2E(8'-3)	16'-5½	Pe -0.000
						41'-5½	Pv
<b>Route 6</b>							
BL	1.0490	16.71	6.20	0.004"	0.090344		
3217	113'-2	16.71	5.63 (adj)	8.817	Sprinkler,	4'-11½	Pf 0.899
316	113'-2			9.715	PO(5'-0)	5'-0	Pe
						9'-11½	Pv
CM	2.1570	19.20	1.69	0.004"	0.003015		
316	113'-2	2.49		9.715	Flow (q) from Route 21	11'-4	Pf 0.034
315	113'-2			9.750		11'-4	Pe Pv
<b>Route 7</b>							
BL	1.0490	16.86	6.26	0.004"	0.091910		
3218	113'-2	16.86	5.63 (adj)	8.975	Sprinkler,	3'-0½	Pf 0.740
320	113'-2			9.715	PO(5'-0)	5'-0	Pe
						8'-0½	Pv
CM	2.1570	14.38	1.26	0.004"	0.001765		
320	113'-2			9.715		6'-0½	Pf 0.011
321	113'-2			9.726		6'-0½	Pe Pv
CM	2.1570	31.35	2.75	0.004"	0.007568		
321	113'-2	16.98		9.726	Flow (q) from Route 8	5'-11½	Pf 0.045
322	113'-2			9.771		5'-11½	Pe Pv
CM	2.1570	48.42	4.25	0.004"	0.017315		
322	113'-2	17.06		9.771	Flow (q) from Route 9	4'-8	Pf 0.294
323	113'-2			10.065	PO(12'-3½)	12'-3½	Pe
						17'-0	Pv
CM	2.1570	65.71	5.77	0.004"	0.031174		
323	113'-2	17.30		10.065	Flow (q) from Route 10	17'-7½	Pf 1.893
204	112'-2			12.385	3E(6'-2), 2PO(12'-3½)	43'-1	Pe 0.427
						60'-8½	Pv
CM	2.6350	65.71	3.87	0.004"	0.011207		
204	112'-2			12.385		27'-3½	Pf 0.306
319	112'-2			12.691		27'-3½	Pe 0.000 Pv
<b>Route 8</b>							
BL	1.0490	16.98	6.30	0.004"	0.093124		
3219	113'-2	16.98	5.63 (adj)	9.098	Sprinkler,	1'-9	Pf 0.628
321	113'-2			9.726	PO(5'-0)	5'-0	Pe
						6'-9	Pv
<b>Route 9</b>							
BL	1.0490	17.06	6.33	0.004"	0.094008		
3220	113'-2	17.06	5.63 (adj)	9.187	Sprinkler,	1'-2½	Pf 0.584
322	113'-2			9.771	PO(5'-0)	5'-0	Pe
						6'-2½	Pv
<b>Route 10</b>							



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (3)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.0490	17.30	6.42	0.004"		0.096525	1'-1½ Pf 0.589
3221	113'-2	17.30	5.63 (adj)	9.442	Sprinkler,		5'-0 Pe
324	113'-2			10.031	PO(5'-0)		6'-1½ Pv
CM	2.1570	17.30	1.52	0.004"		0.002484	1'-4 Pf 0.034
324	113'-2			10.031			12'-3½ Pe
323	113'-2			10.065	PO(12'-3½)		13'-7½ Pv
<b>Route 11</b>							
RN	1.0490	17.56	6.52	0.004"		0.099353	0'-10 Pf 0.577
3211	113'-6	17.56	5.63 (adj)	9.728	Sprinkler,		5'-0 Pe 0.352
312	112'-8½			10.657	PO(5'-0)		5'-10 Pv
<b>Route 12</b>							
RN	1.0490	17.69	6.57	0.004"		0.100862	0'-10 Pf 0.588
3209	113'-6½	17.69	5.63 (adj)	9.880	Sprinkler,		5'-0 Pe 0.361
311	112'-8½			10.830	PO(5'-0)		5'-10 Pv
<b>Route 13</b>							
BL	1.6100	17.71	2.79	0.004"		0.011283	8'-0½ Pf 0.091
3210	112'-7½	17.71	5.63 (adj)	9.897	Sprinkler		Pe -0.000
310	112'-7½			9.987			8'-0½ Pv
<b>Route 14</b>							
DY	1.0490	17.92	6.65	0.004"		0.103331	0'-0 Pf 0.000
3216	109'-11½	17.92	5.63 (adj)	10.130	Sprinkler,		Pe -0.867
318	111'-11½			9.263	, fd		0'-0 Pv
<b>Route 15</b>							
RN	1.0490	18.06	6.70	0.004"		0.104937	0'-10 Pf 0.610
3208	113'-6	18.06	5.63 (adj)	10.293	Sprinkler,		5'-0 Pe 0.352
308	112'-8½			11.255	PO(5'-0)		5'-10 Pv
<b>Route 16</b>							
RN	1.0490	18.32	6.80	0.004"		0.107947	0'-10 Pf 0.627
3207	113'-6	18.32	5.63 (adj)	10.598	Sprinkler,		5'-0 Pe 0.352
306	112'-8½			11.578	PO(5'-0)		5'-10 Pv
<b>Route 17</b>							
BL	1.0490	18.62	6.91	0.004"		0.111291	0'-8 Pf 0.629
3205	109'-11½	18.62	5.63 (adj)	10.937	Sprinkler,		5'-0 Pe -1.162
307	112'-7½			10.405	PO(5'-0), fd		5'-8 Pv
<b>Route 18</b>							
BL	1.6100	19.14	3.02	0.004"		0.013072	9'-0 Pf 0.118
3204	113'-3½	19.14	5.63 (adj)	11.563	Sprinkler		Pe
3202	113'-3½			11.681			9'-0 Pv
BL	1.6100	38.38	6.05	0.004"		0.049551	12'-11 Pf 1.036
3202	113'-3½	19.24	5.63 (adj)	11.681	Sprinkler,		8'-0 Pe 0.199
304	112'-10			12.915	2E(4'-0)		20'-11 Pv
BL	1.6100	77.24	12.17	0.004"		0.193527	13'-4½ Pf 4.912
304	112'-10	38.86		12.915	Flow (q) from Route 19		12'-0 Pe 0.415
302	111'-10½			18.243	3E(4'-0)		25'-4½ Pv
BL	2.0670	77.24	7.39	0.004"		0.053095	84'-11½ Pf 7.432
302	111'-10½			18.243			55'-0 Pe 0.199
305	111'-5			25.874	7E(5'-0), 2PO(10'-0)		139'-11½ Pv
<b>Route 19</b>							
BL	1.6820	19.39	2.80	0.004"		0.010735	9'-0 Pf 0.097
3203	113'-4½	19.39	5.63 (adj)	11.869	Sprinkler		Pe
3201	113'-4½			11.965			9'-0 Pv
BL	1.6820	38.86	5.61	0.004"		0.040541	2'-6 Pf 0.302
3201	113'-4½	19.47	5.63 (adj)	11.965	Sprinkler,		4'-11½ Pe
303	113'-4½			12.268	E(4'-11½)		7'-5½ Pv
DY	1.6100	38.86	6.12	0.004"		0.050768	0'-0 Pf 0.406
303	113'-4½			12.268			8'-0 Pe 0.242
304	112'-10			12.915	PO(8'-0)		8'-0 Pv
<b>Route 20</b>							
BL	1.6100	27.52	4.34	0.004"		0.026122	11'-7½ Pf 1.035
3200	113'-2½	27.52	5.63 (adj)	23.905	Sprinkler,		28'-0 Pe 0.169
301	112'-9½			25.110	5E(4'-0), PO(8'-0)		39'-7½ Pv
CM	2.6350	27.52	1.62	0.004"		0.002168	54'-2½ Pf 0.207
301	112'-9½			25.110			41'-2 Pe 0.600
300	111'-5			25.917	3E(8'-3), PO(16'-5½)		95'-4½ Pv
<b>Route 21</b>							
CM	2.1570	2.49	0.22	0.004"		0.000074	5'-8½ Pf 0.000
320	113'-2	14.38		9.715	Flow (q) from Route 7		Pe
316	113'-2			9.715			5'-8½ Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Summary
Upstream						Eq. Length	
						Total Length	

$$\Delta P = 0.000216 f \frac{lpQ^2}{d^5}$$

K-Factor conversion formula:  $K_A = 7.94 K_W \sqrt{\frac{1}{\gamma_A}}$

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)	C Value Multiplier
$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$	Value Of C: 100, 130, 140, 150 Multiplying Factor: 0.713, 1.16, 1.33, 1.51

Pipe Type Legend	Units Legend	Fittings Legend
AO Arm-Over	Diameter Inch	ALV Alarm Valve
BL Branch Line	Elevation Foot	AngV Angle Valve
CM Cross Main	Flow gpm	b Bushing
DN Drain	Discharge gpm	BaIV Ball Valve
DR Drop	Velocity fps	BFP Backflow Preventer
DY Dynamic	Pressure psi	BV Butterfly Valve
FM Feed Main	Length Foot	C Cross Flow Turn 90°
FR Feed Riser	Friction Loss psi/Foot	cplg Coupling
MS Miscellaneous	HWC Hazen-Williams Constant	Cr Cross Run
OR Outrigger	Pt Total pressure at a point in a pipe	CV Check Valve
RN Riser Nipple	Pn Normal pressure at a point in a pipe	DeIV Deluge Valve
SN Swing Nipple	Pf Pressure loss due to friction between points	DPV Dry Pipe Valve
SP Sprig	Pe Pressure due to elevation difference between indicated points	E 90° Elbow
ST Stand Pipe	Pv Velocity pressure at a point in a pipe	EE 45° Elbow
UG Underground		Ee1 11¼° Elbow
		Ee2 22½° Elbow
		f Flow Device
		fd Flex Drop
		FDC Fire Department Connection
		fE 90° FireLock(TM) Elbow
		fEE 45° FireLock(TM) Elbow
		flg Flange
		FN Floating Node
		fT FireLock(TM) Tee
		g Gauge
		GloV Globe Valve
		GV Gate Valve
		Ho Hose
		Hose Hose
		HV Hose Valve
		Hyd Hydrant
		LtE Long Turn Elbow
		mecT Mechanical Tee
		Noz Nozzle
		P1 Pump In
		P2 Pump Out
		PIV Post Indicating Valve
		PO Pipe Outlet
		PrV Pressure Relief Valve
		PRV Pressure Reducing Valve
		red Reducer/Adapter
		S Supply
		sCV Swing Check Valve
		SFx Seismic Flex
		Spr Sprinkler
		St Strainer
		T Tee Flow Turn 90°
		Tr Tee Run
		U Union
		WirF Wirsbo
		WMV Water Meter Valve
		Z Cap



# Hydraulic Overview

Job Number: 22-3688  
Report Description: Light Hazard (4)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1045 ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.63 K-Factor 14.89 at 7.000	Hose Streams 100.00
Coverage Per Sprinkler 125 ft <sup>2</sup>	Number Of Sprinklers Calculated 12
	Number Of Nozzles Calculated 0
System Pressure Demand 40.356	System Flow Demand 191.57
Total Demand 291.57 @ 40.356	Pressure Result +22.660 (36.0%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	100.00	64.000	20.000
<p>FPET NICET #106245 LEVEL IV,MSME</p> <div style="border: 2px dashed black; padding: 5px;"> <p style="text-align: center;"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNM1060QP</p> <p><i>[Signature]</i> 03/26/2024 Expires 12/31/24 Signature Date</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L01-Asbuilt

Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)










### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
63.016 @ 291.57

Required Pressure at System Demand  
40.356 @ 191.57

Required Pressure at System Demand (Including Hose Allowance at Source)  
40.356 @ 291.57



# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	4000	16.54	14.89	5.63	8.631		
Sprinkler	4001	16.45	14.89	5.63	8.539		
Sprinkler	4002	17.36	14.89	5.63	9.514		
Sprinkler	4003	17.16	14.89	5.63	9.296		
Sprinkler	4004	15.87	14.89	5.63	7.950		
Sprinkler	4005	17.15	14.89	5.63	9.283		
Sprinkler	4006	15.08	14.89	5.63	7.173		
Sprinkler	4007	15.67	14.89	5.63	7.747		
Sprinkler	4008	15.43	14.89	5.63	7.511		
Sprinkler	4009	14.91	14.89	5.63	7.021		
Sprinkler	4010	15.06	14.89	5.63	7.162		
<b>⇒ Sprinkler</b>	<b>4011</b>	<b>14.89</b>	<b>14.89</b>	<b>5.63</b>	<b>7.000</b>		

⇒ Most Demanding Sprinkler Data



# Node Analysis

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	40.356	191.57
4000	113'-8½	Spr(-8.631)	8.631	16.54
4001	113'-8½	Spr(-8.539)	8.539	16.45
4002	113'-8½	Spr(-9.514)	9.514	17.36
4003	113'-8½	Spr(-9.296)	9.296	17.16
4004	113'-8	Spr(-7.950)	7.950	15.87
4005	113'-8	Spr(-9.283)	9.283	17.15
4006	113'-8½	Spr(-7.173)	7.173	15.08
4007	113'-8½	Spr(-7.747)	7.747	15.67
4008	113'-8½	Spr(-7.511)	7.511	15.43
4009	113'-6	Spr(-7.021)	7.021	14.91
4010	113'-8	Spr(-7.162)	7.162	15.06
4011	113'-6	Spr(-7.000)	7.000	14.89
2	84'-6½	PIV(-2.000)	40.299	
3	84'-6½	BFP(-0.459)	38.287	
6	84'-6½	PO(20'-0)	37.824	
7	90'-9		34.978	
8	91'-4½	St(-0.059)	34.707	
9	102'-6½	PO(20'-2)	29.762	
200	111'-5	PO(20'-2)	19.753	
201	112'-5½		17.739	
202	113'-2	E(6'-2)	15.168	
203	111'-5	PO(16'-5½)	19.722	
204	112'-2	PO(12'-3½)	10.384	
400	112'-8½	PO(5'-0)	9.585	
401	112'-2	PO(8'-0)	10.579	
402	112'-8½	PO(5'-0)	9.487	
403	112'-8½	PO(5'-0)	10.542	
404	112'-8½	PO(12'-3½)	10.296	
405	112'-8½	PO(5'-0)	10.289	
406	112'-8½	PO(5'-0)	8.852	
407	112'-8½	PO(5'-0)	10.262	
408	112'-8½	PO(8'-0)	9.013	
409	112'-8½	PO(5'-0)	8.737	
410	112'-2	PO(8'-0)	10.134	
411	112'-8½	PO(5'-0)	8.648	
412	112'-8½	PO(5'-0)	8.040	
413	112'-8½	PO(5'-0)	8.107	
414	112'-8½	PO(8'-0)	8.403	
415	112'-2	PO(8'-0)	10.059	
416	112'-8½	PO(5'-0)	8.084	
417	112'-8½	PO(5'-0)	8.018	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (4)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
BL	1.0490	14.89	5.53	0.004"	0.072309	3'-3"	Pf 0.741
4011	113'-6"	14.89	5.63 (adj)	7.000	Sprinkler,	7'-0"	Pe 0.343
416	112'-8½"			8.084	E(2'-0"), PO(5'-0")	10'-3"	Pv
BL	1.6100	29.96	4.72	0.004"	0.030738	2'-4½"	Pf 0.319
416	112'-8½"	15.06		8.084	Flow (q) from Route 3	8'-0"	Pe
414	112'-8½"			8.403	PO(8'-0")	10'-4½"	Pv
DY	1.6100	59.95	9.45	0.004"	0.117868	0'-0"	Pf 1.414
414	112'-8½"	29.99		8.403	Flow (q) from Route 2	12'-0"	Pe 0.242
415	112'-2"			10.059	E(4'-0"), PO(8'-0")	12'-0"	Pv
CM	2.6350	59.95	3.53	0.004"	0.009404	8'-0"	Pf 0.075
415	112'-2"			10.059			Pe
410	112'-2"			10.134		8'-0"	Pv
CM	2.6350	106.91	6.29	0.004"	0.028612	8'-8½"	Pf 0.249
410	112'-2"	46.96		10.134	Flow (q) from Route 5		Pe
204	112'-2"			10.384		8'-8½"	Pv
CM	2.6350	82.47	4.85	0.004"	0.017332	11'-3½"	Pf 0.196
204	112'-2"			10.384			Pe
401	112'-2"			10.579		11'-3½"	Pv
CM	2.6350	115.45	6.79	0.004"	0.033211	112'-6½"	Pf 7.294
401	112'-2"	32.98		10.579	Flow (q) from Route 8	107'-1"	Pe -0.134
201	112'-5½"			17.739	7E(8'-3"), PO(16'-5½"), C(16'-5½"), T(16'-5½")	219'-7½"	Pv
CM	3.2600	115.45	4.44	0.004"	0.011170	81'-5"	Pf 1.555
201	112'-5½"			17.739		57'-9½"	Pe 0.459
200	111'-5"			19.753	4E(9'-5"), PO(20'-2")	139'-2½"	Pv
CM	6.3570	191.57	1.94	0.004"	0.001004	68'-8"	Pf 6.160
200	111'-5"	76.12		19.753	Flow (q) from Route 10	90'-2"	Pe 3.849
9	102'-6½"			29.762	2E(17'-7"), sCV(-6.000), sCV(17'-2½"), PO(37'-8½")	158'-10"	Pv
CM	6.3570	191.57	1.94	0.004"	0.001004	20'-5"	Pf 0.110
9	102'-6½"			29.762		30'-2"	Pe 4.836
8	91'-4½"			34.707	BV(12'-7"), E(17'-7"), St(-0.059)	50'-7"	Pv
DY	6.3400	191.57	1.95	0.004"	0.001018	0'-0"	Pf 0.000
8	91'-4½"			34.707			Pe 0.271
7	90'-9"			34.978		0'-0"	Pv
UG	6.3400	191.57	1.95	0.004"	0.001018	86'-3½"	Pf 0.158
7	90'-9"			34.978		69'-4"	Pe 2.688
6	84'-6½"			37.824	3E(23'-1½")	155'-7½"	Pv
UG	6.3400	191.57	1.95	0.004"	0.001018	4'-1½"	Pf 0.463
6	84'-6½"			37.824			Pe
3	84'-6½"			38.287	BFP(-0.459)	4'-1½"	Pv
UG	6.3400	191.57	1.95	0.004"	0.001018	11'-2½"	Pf 2.011
3	84'-6½"			38.287			Pe
2	84'-6½"			40.299	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	191.57	1.95	0.004"	0.001018	21'-7"	Pf 0.057
2	84'-6½"			40.299		34'-8"	Pe
1	84'-6½"			40.356	E(23'-1½"), EE(11'-6½"), S	56'-3"	Pv
		100.00			Hose Allowance At Source		
1		291.57					
<b>Route 2</b>							
BL	1.0490	14.91	5.54	0.004"	0.072515	3'-3"	Pf 0.743
4009	113'-6"	14.91	5.63 (adj)	7.021	Sprinkler,	7'-0"	Pe 0.343
413	112'-8½"			8.107	E(2'-0"), PO(5'-0")	10'-3"	Pv
BL	1.6100	29.99	4.73	0.004"	0.030804	1'-7½"	Pf 0.296
413	112'-8½"	15.08		8.107	Flow (q) from Route 4	8'-0"	Pe
414	112'-8½"			8.403	PO(8'-0")	9'-7½"	Pv
<b>Route 3</b>							
BL	1.0490	15.06	5.59	0.004"	0.073922	0'-11½"	Pf 0.440
4010	113'-8"	15.06	5.63 (adj)	7.162	Sprinkler,	5'-0"	Pe 0.415
417	112'-8½"			8.018	PO(5'-0")	5'-11½"	Pv
BL	1.6100	15.06	2.37	0.004"	0.008318	8'-0"	Pf 0.067
417	112'-8½"			8.018			Pe
416	112'-8½"			8.084		8'-0"	Pv
<b>Route 4</b>							



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (4)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
AO	1.0490	15.08	5.60	0.004"	0.074035	0'-11½"	Pf 0.443
4006	113'-8½"	15.08	5.63 (adj)	7.173	Sprinkler,	5'-0"	Pe 0.424
412	112'-8½"			8.040	PO(5'-0)	5'-11½"	Pv
BL	1.6100	15.08	2.38	0.004"	0.008330	8'-0"	Pf 0.067
412	112'-8½"			8.040			Pe
413	112'-8½"			8.107		8'-0"	Pv
<b>Route 5</b>							
BL	1.0490	15.43	5.73	0.004"	0.077394	3'-4½"	Pf 0.802
4008	113'-8½"	15.43	5.63 (adj)	7.511	Sprinkler,	7'-0"	Pe 0.424
409	112'-8½"			8.737	E(2'-0), PO(5'-0)	10'-4½"	Pv
BL	1.6100	31.09	4.90	0.004"	0.033019	0'-4½"	Pf 0.276
409	112'-8½"	15.67		8.737	Flow (q) from Route 6	8'-0"	Pe
408	112'-8½"			9.013	PO(8'-0)	8'-4½"	Pv
DY	1.6100	46.96	7.40	0.004"	0.073279	0'-0"	Pf 0.879
408	112'-8½"	15.87		9.013	Flow (q) from Route 7	12'-0"	Pe 0.242
410	112'-2"			10.134	E(4'-0), PO(8'-0)	12'-0"	Pv
<b>Route 6</b>							
BL	1.0490	15.67	5.82	0.004"	0.079732	0'-11½"	Pf 0.477
4007	113'-8½"	15.67	5.63 (adj)	7.747	Sprinkler,	5'-0"	Pe 0.424
411	112'-8½"			8.648	PO(5'-0)	5'-11½"	Pv
BL	1.6100	15.67	2.47	0.004"	0.008955	10'-0"	Pf 0.090
411	112'-8½"			8.648			Pe
409	112'-8½"			8.737		10'-0"	Pv
<b>Route 7</b>							
BL	1.0490	15.87	5.89	0.004"	0.081746	0'-11½"	Pf 0.487
4004	113'-8"	15.87	5.63 (adj)	7.950	Sprinkler,	5'-0"	Pe 0.415
406	112'-8½"			8.852	PO(5'-0)	5'-11½"	Pv
BL	1.6100	15.87	2.50	0.004"	0.009175	9'-7½"	Pf 0.162
406	112'-8½"			8.852		8'-0"	Pe
408	112'-8½"			9.013	PO(8'-0)	17'-7½"	Pv
<b>Route 8</b>							
BL	1.0490	16.45	6.11	0.004"	0.087588	0'-11½"	Pf 0.524
4001	113'-8½"	16.45	5.63 (adj)	8.539	Sprinkler,	5'-0"	Pe 0.424
402	112'-8½"			9.487	PO(5'-0)	5'-11½"	Pv
BL	1.6100	16.45	2.59	0.004"	0.009815	10'-0"	Pf 0.098
402	112'-8½"			9.487			Pe
400	112'-8½"			9.585		10'-0"	Pv
BL	1.6100	32.98	5.20	0.004"	0.036994	0'-4½"	Pf 0.753
400	112'-8½"	16.54		9.585	Flow (q) from Route 9	20'-0"	Pe 0.242
401	112'-2"			10.579	2PO(8'-0), E(4'-0)	20'-4½"	Pv
<b>Route 9</b>							
BL	1.0490	16.54	6.14	0.004"	0.088506	0'-11½"	Pf 0.529
4000	113'-8½"	16.54	5.63 (adj)	8.631	Sprinkler,	5'-0"	Pe 0.424
400	112'-8½"			9.585	PO(5'-0)	5'-11½"	Pv
<b>Route 10</b>							
SP	1.0490	17.15	6.37	0.004"	0.094959	0'-11½"	Pf 0.565
4005	113'-8"	17.15	5.63 (adj)	9.283	Sprinkler,	5'-0"	Pe 0.414
407	112'-8½"			10.262	PO(5'-0)	5'-11½"	Pv
CM	2.1570	17.15	1.51	0.004"	0.002445	10'-0"	Pf 0.024
407	112'-8½"			10.262			Pe 0.002
405	112'-8½"			10.289		10'-0"	Pv
CM	2.1570	34.31	3.01	0.004"	0.008977	0'-5"	Pf 0.004
405	112'-8½"	17.16		10.289	Flow (q) from Route 11		Pe 0.004
404	112'-8½"			10.296		0'-5"	Pv
CM	2.1570	58.75	5.16	0.004"	0.025118	9'-7"	Pf 0.241
404	112'-8½"	24.44		10.296	Flow (q) from Route 13		Pe 0.006
403	112'-8½"			10.542		9'-7"	Pv
CM	2.1570	76.12	6.68	0.004"	0.041435	67'-1½"	Pf 4.821
403	112'-8½"	17.36		10.542	Flow (q) from Route 12	49'-2½"	Pe -0.195
202	113'-2"			15.168	6E(6'-2), PO(12'-3½)	116'-4"	Pv
CM	2.6350	76.12	4.48	0.004"	0.014856	128'-2½"	Pf 3.801
202	113'-2"			15.168		127'-8"	Pe 0.752
203	111'-5"			19.722	4PO(16'-5½), 5E(8'-3), T(16'-5½), EE(4'-1½)	255'-10½"	Pv
CM	6.3570	76.12	0.77	0.004"	0.000182	136'-5"	Pf 0.031
203	111'-5"			19.722		35'-2½"	Pe
200	111'-5"			19.753	2E(17'-7)	171'-7½"	Pv
<b>Route 11</b>							



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (4)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.0490	17.16	6.37	0.004"		0.095081	1'-0 Pf 0.569
4003	113'-8½	17.16	5.63 (adj)	9.296	Sprinkler,		5'-0 Pe 0.424
405	112'-8½			10.289	PO(5'-0)		6'-0 Pv
<b>Route 12</b>							
BL	1.0490	17.36	6.45	0.004"		0.097245	1'-0 Pf 0.585
4002	113'-8½	17.36	5.63 (adj)	9.514	Sprinkler,		5'-0 Pe 0.442
403	112'-8½			10.542	PO(5'-0)		6'-0 Pv
<b>Route 13</b>							
CM	2.1570	24.44	2.15	0.004"		0.004733	0'-11 Pf 0.150
204	112'-2			10.384	PO(12'-3½)		30'-9 Pe -0.238
404	112'-8½			10.296	E(6'-2), PO(12'-3½)		31'-8 Pv

$\Delta P = 0.000216 f \frac{lpQ^2}{d^5}$  K-Factor conversion formula:  $K_A = 7.94 K_W \sqrt{\frac{1}{\gamma_A}}$

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BaV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DelV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap



# Hydraulic Overview

Job Number: 22-3688  
Report Description: Light Hazard (5)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1335 ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.63 K-Factor 14.89 at 7.000	Hose Streams 100.00
Coverage Per Sprinkler 120 ft <sup>2</sup>	Number Of Sprinklers Calculated 14
	Number Of Nozzles Calculated 0
System Pressure Demand 32.093	System Flow Demand 220.32
Total Demand 320.32 @ 32.093	Pressure Result +30.719 (48.9%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	100.00	64.000	20.000
<p>FPET NICET #106245 LEVEL IV,MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>Signature</i>      03/26/2024      Expires 12/31/24</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L01-Asbuilt

Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)










### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
62.813 @ 320.32

Required Pressure at System Demand  
32.093 @ 220.32

Required Pressure at System Demand (Including Hose Allowance at Source)  
32.093 @ 320.32



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 5600	16.27	14.89	5.63	8.353			
Sprinkler 5601	16.01	14.89	5.63	8.089			
Sprinkler 5602	16.22	14.89	5.63	8.305			
Sprinkler 5603	15.95	14.89	5.63	8.026			
Sprinkler 5604	15.96	14.89	5.63	8.042			
Sprinkler 5605	15.72	14.89	5.63	7.798			
Sprinkler 5606	15.90	14.89	5.63	7.980			
Sprinkler 5607	15.47	14.89	5.63	7.551			
Sprinkler 5608	14.96	14.89	5.63	7.066			
Sprinkler 5609	15.41	14.89	5.63	7.492			
⇒ <b>Sprinkler 5610</b>	<b>14.89</b>	<b>14.89</b>	<b>5.63</b>	<b>7.000</b>			
Sprinkler 5611	16.76	14.89	5.63	8.860			
Sprinkler 5612	15.37	14.89	5.63	7.458			
Sprinkler 5613	15.44	14.89	5.63	7.526			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Light Hazard (5)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	32.093	220.32
5600	113'-2½	Spr(-8.353)	8.353	16.27
5601	113'-2½	Spr(-8.089)	8.089	16.01
5602	113'-2½	Spr(-8.305)	8.305	16.22
5603	113'-2½	Spr(-8.026)	8.026	15.95
5604	113'-2½	Spr(-8.042)	8.042	15.96
5605	113'-2½	Spr(-7.798)	7.798	15.72
5606	113'-2½	Spr(-7.980)	7.980	15.90
5607	113'-2½	Spr(-7.551)	7.551	15.47
5608	113'-5	Spr(-7.066)	7.066	14.96
5609	113'-2½	Spr(-7.492)	7.492	15.41
5610	113'-5	Spr(-7.000)	7.000	14.89
5611	110'-0	Spr(-8.860), fd	8.860	16.76
5612	113'-2½	Spr(-7.458)	7.458	15.37
5613	113'-2½	Spr(-7.526)	7.526	15.44
2	84'-6½	PIV(-2.000)	32.019	
3	84'-6½	BFP(-0.607)	30.004	
6	84'-6½	PO(20'-0)	29.392	
7	90'-9		26.498	
8	91'-4½	St(-0.078)	26.227	
9	102'-6½	PO(20'-2)	21.247	
200	111'-5	PO(20'-2)	11.190	
201	112'-5½		9.963	
202	113'-2	E(6'-2)	10.191	
203	111'-5	PO(16'-5½)	11.164	
204	112'-2	PO(16'-5½)	10.282	
300	111'-5	PO(16'-5½)	11.165	
301	112'-9½	PO(8'-0)	9.260	
500	113'-2½	E(4'-11½)	8.942	
501	111'-5	PO(8'-0)	10.467	
502	113'-2½	E(4'-11½)	8.890	
503	111'-5	PO(8'-0)	10.411	
504	113'-2½	E(4'-11½)	8.350	
505	111'-5	PO(8'-0), C(8'-0)	10.403	
506	112'-9½	PO(5'-0)	7.740	
507	112'-9½	PO(5'-0)	7.670	
508	112'-9½	PO(5'-0)	8.141	
509	113'-2½		7.513	
510	112'-9½	PO(5'-0)	9.294	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (5)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
SP	1.0490	14.89	5.53	0.004"	0.072309	0'-7½"	Pf 0.406
5610	113'-5"	14.89	5.63 (adj)	7.000	Sprinkler,	5'-0"	Pe 0.265
507	112'-9½"			7.670	PO(5'-0)	5'-7½"	Pv
BL	1.6820	14.89	2.15	0.004"	0.006531	10'-7½"	Pf 0.069
507	112'-9½"			7.670			Pe
506	112'-9½"			7.740		10'-7½"	Pv
BL	1.6820	29.85	4.31	0.004"	0.024413	11'-6"	Pf 0.401
506	112'-9½"	14.96		7.740	Flow (q) from Route 2	4'-11½"	Pe
508	112'-9½"			8.141	E(4'-11½)	16'-5"	Pv
BL	1.6820	46.61	6.73	0.004"	0.057625	10'-1"	Pf 1.152
508	112'-9½"	16.76		8.141	Flow (q) from Route 7	9'-11"	Pe
510	112'-9½"			9.294	PO(9'-11)	20'-0"	Pv
CM	2.6350	77.42	4.56	0.004"	0.015350	41'-7½"	Pf 1.271
510	112'-9½"	30.81		9.294	Flow (q) from Route 3	41'-2"	Pe 0.600
300	111'-5"			11.165	3E(8'-3), PO(16'-5½)	82'-9½"	Pv
CM	6.3570	94.09	0.95	0.004"	0.000268	60'-11½"	Pf 0.026
300	111'-5"	16.66		11.165	Flow (q) from Route 8	35'-2½"	Pe
200	111'-5"			11.190	2E(17'-7)	96'-2"	Pv
CM	6.3570	220.32	2.23	0.004"	0.001307	68'-8"	Pf 6.208
200	111'-5"	126.23		11.190	Flow (q) from Route 4	90'-2"	Pe 3.849
9	102'-6½"			21.247	2E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½)	158'-10"	Pv
CM	6.3570	220.32	2.23	0.004"	0.001307	20'-5"	Pf 0.144
9	102'-6½"			21.247		30'-2"	Pe 4.836
8	91'-4½"			26.227	BV(12'-7), E(17'-7), St(-0.078)	50'-7"	Pv
DY	6.3400	220.32	2.24	0.004"	0.001325	0'-0"	Pf 0.000
8	91'-4½"			26.227			Pe 0.271
7	90'-9"			26.498		0'-0"	Pv
UG	6.3400	220.32	2.24	0.004"	0.001325	86'-3½"	Pf 0.206
7	90'-9"			26.498		69'-4"	Pe 2.688
6	84'-6½"			29.392	3E(23'-1½)	155'-7½"	Pv
UG	6.3400	220.32	2.24	0.004"	0.001325	4'-1½"	Pf 0.612
6	84'-6½"			29.392			Pe
3	84'-6½"			30.004	BFP(-0.607)	4'-1½"	Pv
UG	6.3400	220.32	2.24	0.004"	0.001325	11'-2½"	Pf 2.015
3	84'-6½"			30.004			Pe
2	84'-6½"			32.019	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	220.32	2.24	0.004"	0.001325	21'-7"	Pf 0.075
2	84'-6½"			32.019		34'-8"	Pe
1	84'-6½"			32.093	E(23'-1½), EE(11'-6½), S	56'-3"	Pv
		100.00			Hose Allowance At Source		
1		320.32					
<b>Route 2</b>							
SP	1.0490	14.96	5.55	0.004"	0.072964	0'-7½"	Pf 0.409
5608	113'-5"	14.96	5.63 (adj)	7.066	Sprinkler,	5'-0"	Pe 0.265
506	112'-9½"			7.740	PO(5'-0)	5'-7½"	Pv
<b>Route 3</b>							
BL	1.6820	15.37	2.22	0.004"	0.006931	7'-11"	Pf 0.055
5612	113'-2½"	15.37	5.63 (adj)	7.458	Sprinkler		Pe
509	113'-2½"			7.513		7'-11"	Pv
BL	1.6100	15.37	2.42	0.004"	0.008641	1'-6"	Pf 0.013
509	113'-2½"			7.513			Pe 0.000
5613	113'-2½"			7.526		1'-6"	Pv
BL	1.6100	30.81	4.86	0.004"	0.032452	20'-2½"	Pf 1.564
5613	113'-2½"	15.44	5.63 (adj)	7.526	Sprinkler,	28'-0"	Pe 0.170
301	112'-9½"			9.260	5E(4'-0), PO(8'-0)	48'-2½"	Pv
CM	2.6350	30.81	1.81	0.004"	0.002676	12'-7"	Pf 0.034
301	112'-9½"			9.260			Pe -0.000
510	112'-9½"			9.294		12'-7"	Pv
<b>Route 4</b>							
BL	1.6820	15.41	2.22	0.004"	0.006960	8'-4½"	Pf 0.058
5609	113'-2½"	15.41	5.63 (adj)	7.492	Sprinkler		Pe
5607	113'-2½"			7.551		8'-4½"	Pv
BL	1.6820	30.87	4.46	0.004"	0.026037	9'-6"	Pf 0.248
5607	113'-2½"	15.47	5.63 (adj)	7.551	Sprinkler		Pe
5605	113'-2½"			7.798		9'-6"	Pv



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (5)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.6820	46.59	6.73	0.004"	0.057584	4'-7½"	Pf 0.552
5605	113'-2½"	15.72	5.63 (adj)	7.798	Sprinkler,	4'-11½"	Pe
504	113'-2½"			8.350	E(4'-11½")	9'-7"	Pv
RN	1.6100	46.59	7.34	0.004"	0.072159	1'-9½"	Pf 1.283
504	113'-2½"			8.350		16'-0"	Pe 0.770
505	111'-5"			10.403	PO(8'-0), C(8'-0)	17'-9½"	Pv
CM	3.2600	29.93	1.15	0.004"	0.000879	9'-0"	Pf 0.008
505	111'-5"			10.403			Pe
503	111'-5"			10.411		9'-0"	Pv
CM	3.2600	78.01	3.00	0.004"	0.005280	10'-7½"	Pf 0.056
503	111'-5"	48.08		10.411	Flow (q) from Route 5		Pe
501	111'-5"			10.467		10'-7½"	Pv
CM	3.2600	126.23	4.85	0.004"	0.013263	34'-5"	Pf 0.724
501	111'-5"	48.22		10.467	Flow (q) from Route 6	20'-2"	Pe
200	111'-5"			11.190	PO(20'-2)	54'-7"	Pv
<b>Route 5</b>							
BL	1.6820	15.90	2.30	0.004"	0.007384	8'-4½"	Pf 0.062
5606	113'-2½"	15.90	5.63 (adj)	7.980	Sprinkler		Pe
5604	113'-2½"			8.042		8'-4½"	Pv
BL	1.6820	31.86	4.60	0.004"	0.027660	9'-6"	Pf 0.263
5604	113'-2½"	15.96	5.63 (adj)	8.042	Sprinkler		Pe
5602	113'-2½"			8.305		9'-6"	Pv
BL	1.6820	48.08	6.94	0.004"	0.061210	4'-7½"	Pf 0.586
5602	113'-2½"	16.22	5.63 (adj)	8.305	Sprinkler,	4'-11½"	Pe
502	113'-2½"			8.890	E(4'-11½")	9'-7"	Pv
RN	1.6100	48.08	7.58	0.004"	0.076711	1'-9½"	Pf 0.750
502	113'-2½"			8.890		8'-0"	Pe 0.770
503	111'-5"			10.411	PO(8'-0)	9'-9½"	Pv
<b>Route 6</b>							
BL	1.6820	15.95	2.30	0.004"	0.007425	8'-4½"	Pf 0.062
5603	113'-2½"	15.95	5.63 (adj)	8.026	Sprinkler		Pe
5601	113'-2½"			8.089		8'-4½"	Pv
BL	1.6820	31.96	4.61	0.004"	0.027815	9'-6"	Pf 0.265
5601	113'-2½"	16.01	5.63 (adj)	8.089	Sprinkler		Pe
5600	113'-2½"			8.353		9'-6"	Pv
BL	1.6820	48.22	6.96	0.004"	0.061558	4'-7½"	Pf 0.589
5600	113'-2½"	16.27	5.63 (adj)	8.353	Sprinkler,	4'-11½"	Pe
500	113'-2½"			8.942	E(4'-11½")	9'-7"	Pv
BL	1.6100	48.22	7.60	0.004"	0.077148	1'-9½"	Pf 0.754
500	113'-2½"			8.942		8'-0"	Pe 0.770
501	111'-5"			10.467	PO(8'-0)	9'-9½"	Pv
<b>Route 7</b>							
BL	1.0490	16.76	6.22	0.004"	0.090775	0'-5½"	Pf 0.495
5611	110'-0"	16.76	5.63 (adj)	8.860	Sprinkler,	5'-0"	Pe -1.214
508	112'-9½"			8.141	PO(5'-0), fd	5'-5½"	Pv
<b>Route 8</b>							
CM	2.6350	16.66	0.98	0.004"	0.000860	128'-2½"	Pf 0.220
202	113'-2"	16.66		10.191	Flow (q) from Route 9	127'-8"	Pe 0.752
203	111'-5"			11.164	4PO(16'-5½"), 5E(8'-3), T(16'-5½") , EE(4'-1½")	255'-10½"	Pv
CM	6.3570	16.66	0.17	0.004"	0.000012	75'-5½"	Pf 0.001
203	111'-5"			11.164			Pe
300	111'-5"			11.165		75'-5½"	Pv
<b>Route 9</b>							
DY	2.1570	16.66	1.46	0.004"	0.002318	77'-7½"	Pf 0.337
204	112'-2"	16.66		10.282	Flow (q) from Route 10	67'-8"	Pe -0.427
202	113'-2"			10.191	7E(6'-2), 2PO(12'-3½")	145'-3½"	Pv
<b>Route 10</b>							
CM	2.6350	16.66	0.98	0.004"	0.000860	123'-10"	Pf 0.184
201	112'-5½"	16.66		9.963	Flow (q) from Route 11	90'-7½"	Pe 0.134
204	112'-2"			10.282	T(16'-5½"), 7E(8'-3), PO(16'-5½")	214'-5"	Pv
<b>Route 11</b>							
CM	3.2600	16.66	0.64	0.004"	0.000303	27'-4½"	Pf 0.020
505	111'-5"	29.93		10.403	Flow (q) from Route 4	37'-7½"	Pe -0.459
201	112'-5½"			9.963	4E(9'-5)	65'-0"	Pv

$$\Delta P = 0.000216 f \frac{\rho Q^2}{d^5}$$

K-Factor conversion formula:

$$K_A = 7.94 K_W \sqrt{\frac{1}{\gamma_A}}$$



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (5)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)	C Value Multiplier
$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$	Value Of C
	100      130      140      150
	Multiplying Factor      0.713      1.16      1.33      1.51

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
balV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DelV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
ft	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap



# Hydraulic Overview

Job Number: 22-3688  
Report Description: Ordinary Group II (6)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.20 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1042 ft <sup>2</sup> )
Most Demanding Sprinkler Data 8.04 K-Factor 26.00 at 10.455	Hose Streams 250.00
Coverage Per Sprinkler 110 ft <sup>2</sup>	Number Of Sprinklers Calculated 10
System Pressure Demand 45.561	System Flow Demand 268.37
Total Demand 518.37 @ 45.561	Pressure Result +15.329 (25.2%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	250.00	64.000	20.000
<p>FPET NICET #106245 LEVEL IV, MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>[Signature]</i> 03/26/2024 Expires 12/31/24 Signature Date</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L02-Asbuilt

Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)










### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure  
20.000 @ 1950.00

Available Flow @ 20 PSI:  
0.00

Available Pressure at System Demand  
60.891 @ 518.37

Required Pressure at System Demand  
45.561 @ 268.37

Required Pressure at System Demand (Including Hose Allowance at Source)  
45.561 @ 518.37



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 6000	28.16	26.00	8.04	12.266			
Sprinkler 6001	28.10	26.00	8.04	12.210			
Sprinkler 6002	26.27	26.00	8.04	10.674			
Sprinkler 6003	27.68	26.00	8.04	11.849			
Sprinkler 6004	26.05	26.00	8.04	10.493			
➔ <b>Sprinkler 6005</b>	<b>26.00</b>	<b>26.00</b>	<b>8.04</b>	<b>10.455</b>			
Sprinkler 6006	26.29	26.00	8.04	10.686			
Sprinkler 6007	26.06	26.00	8.04	10.505			
Sprinkler 6008	27.75	26.00	8.04	11.910			
Sprinkler 6009	26.01	26.00	8.04	10.466			

➔ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Ordinary Group II (6)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	45.561	268.37
6000	124'-8	Spr(-12.266), fd	12.266	28.16
6001	124'-8	Spr(-12.210), fd	12.210	28.10
6002	124'-8	Spr(-10.674), fd	10.674	26.27
6003	124'-0	Spr(-11.849), fd	11.849	27.68
6004	124'-8	Spr(-10.493), fd	10.493	26.05
6005	124'-8	Spr(-10.455), fd	10.455	26.00
6006	124'-8	Spr(-10.686), fd	10.686	26.29
6007	124'-8	Spr(-10.505), fd	10.505	26.06
6008	124'-0	Spr(-11.910), fd	11.910	27.75
6009	124'-8	Spr(-10.466), fd	10.466	26.01
2	84'-6½	PIV(-2.000)	45.453	
3	84'-6½	BFP(-0.900)	43.432	
6	84'-6½	PO(20'-0)	42.523	
7	90'-9		39.536	
8	91'-4½	St(-0.132)	39.265	
9	102'-6½	PO(20'-2)	34.201	
600	126'-6	PO(12'-3½)	17.283	
601	126'-6	PO(16'-5½)	16.475	
602	126'-7	PO(16'-5½)	14.451	
603	126'-8	PO(5'-0)	12.645	
604	126'-9	PO(5'-0)	13.630	
605	126'-8	PO(5'-0)	12.583	
606	126'-9	PO(5'-0)	10.859	
607	127'-5	PO(5'-0)	11.571	
608	126'-9	PO(12'-3½)	13.538	
609	126'-9	PO(5'-0)	10.660	
610	126'-9	PO(5'-0)	10.617	
611	126'-9	PO(5'-0)	10.872	
612	127'-5	PO(5'-0)	11.639	
613	126'-9	PO(12'-3½)	13.513	
614	126'-9	PO(5'-0)	10.673	
615	126'-9	PO(5'-0)	10.630	
801	101'-6	T(14'-4½)	34.201	
802	111'-0	E(6'-8½)	34.201	
803	111'-6½	E(6'-8½)	34.201	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (6)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
DY	1.0490	26.00	9.65	0.004"	0.213138	0'-0	Pf 1.066
6005	124'-8	26.00	8.04 (adj)	10.455	Sprinkler,	5'-0	Pe -0.903
610	126'-9			10.617	PO(5'-0), fd	5'-0	Pv
BL	2.1570	26.00	2.28	0.004"	0.005316	8'-0	Pf 0.043
610	126'-9			10.617			Pe
609	126'-9			10.660		8'-0	Pv
BL	2.1570	52.05	4.57	0.004"	0.019894	10'-0	Pf 0.199
609	126'-9	26.05		10.660	Flow (q) from Route 3		Pe
606	126'-9			10.859		10'-0	Pv
BL	2.1570	78.32	6.88	0.004"	0.043794	10'-7	Pf 1.002
606	126'-9	26.27		10.859	Flow (q) from Route 5	12'-3½	Pe -0.289
607	127'-5			11.571	2E(6'-2)	22'-10½	Pv
BL	2.1570	106.00	9.31	0.004"	0.078928	2'-9½	Pf 1.678
607	127'-5	27.68		11.571	Flow (q) from Route 7	18'-5½	Pe 0.289
608	126'-9			13.538	E(6'-2), PO(12'-3½)	21'-3	Pv
CM	4.2600	212.11	4.77	0.004"	0.009204	10'-0	Pf 0.092
608	126'-9	106.11		13.538	Flow (q) from Route 2		Pe
604	126'-9			13.630		10'-0	Pv
CM	4.2600	268.37	6.04	0.004"	0.014500	25'-4	Pf 0.749
604	126'-9	56.26		13.630	Flow (q) from Route 9	26'-4	Pe 0.072
602	126'-7			14.451	2E(13'-2)	51'-8	Pv
CM	4.2600	230.78	5.19	0.004"	0.010830	104'-6	Pf 1.987
602	126'-7			14.451		79'-0	Pe 0.036
601	126'-6			16.475	6E(13'-2)	183'-6	Pv
CM	4.2600	268.37	6.04	0.004"	0.014500	29'-4	Pf 0.807
601	126'-6	37.59		16.475	Flow (q) from Route 11	26'-4	Pe
600	126'-6			17.283	PO(26'-4)	55'-8	Pv
CM	6.3570	268.37	2.71	0.004"	0.001899	118'-8½	Pf 6.530
600	126'-6			17.283		160'-6½	Pe 10.388
9	102'-6½			34.201	6E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½)	279'-3½	Pv
CM	6.3570	268.37	2.71	0.004"	0.001899	20'-5	Pf 0.228
9	102'-6½			34.201		30'-2	Pe 4.836
8	91'-4½			39.265	BV(12'-7), E(17'-7), St(-0.132)	50'-7	Pv
DY	6.3400	268.37	2.73	0.004"	0.001925	0'-0	Pf 0.000
8	91'-4½			39.265			Pe 0.271
7	90'-9			39.536		0'-0	Pv
UG	6.3400	268.37	2.73	0.004"	0.001925	86'-3½	Pf 0.300
7	90'-9			39.536		69'-4	Pe 2.688
6	84'-6½			42.523	3E(23'-1½)	155'-7½	Pv
UG	6.3400	268.37	2.73	0.004"	0.001925	4'-1½	Pf 0.908
6	84'-6½			42.523			Pe
3	84'-6½			43.432	BFP(-0.900)	4'-1½	Pv
UG	6.3400	268.37	2.73	0.004"	0.001925	11'-2½	Pf 2.022
3	84'-6½			43.432			Pe
2	84'-6½			45.453	PIV(-2.000)	11'-2½	Pv
UG	6.3400	268.37	2.73	0.004"	0.001925	21'-7	Pf 0.108
2	84'-6½			45.453		34'-8	Pe
1	84'-6½			45.561	E(23'-1½), EE(11'-6½), S	56'-3	Pv
		250.00			Hose Allowance At Source		
1		518.37					
<b>Route 2</b>							
DY	1.0490	26.01	9.66	0.004"	0.213373	0'-0	Pf 1.067
6009	124'-8	26.01	8.04 (adj)	10.466	Sprinkler,	5'-0	Pe -0.903
615	126'-9			10.630	PO(5'-0), fd	5'-0	Pv
BL	2.1570	26.01	2.28	0.004"	0.005321	8'-0	Pf 0.043
615	126'-9			10.630			Pe
614	126'-9			10.673		8'-0	Pv
BL	2.1570	52.08	4.57	0.004"	0.019916	10'-0	Pf 0.199
614	126'-9	26.06		10.673	Flow (q) from Route 4		Pe
611	126'-9			10.872		10'-0	Pv
BL	2.1570	78.36	6.88	0.004"	0.043842	11'-9½	Pf 1.056
611	126'-9	26.29		10.872	Flow (q) from Route 6	12'-3½	Pe -0.289
612	127'-5			11.639	2E(6'-2)	24'-1	Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	2.1570	106.11	9.32	0.004"	0.079096	1'-7"	Pf 1.586
612	127'-5"	27.75		11.639	Flow (q) from Route 8	18'-5½"	Pe 0.289
613	126'-9"			13.513	E(6'-2), PO(12'-3½)	20'-0½"	Pv
CM	4.2600	106.11	2.39	0.004"	0.002454	10'-0"	Pf 0.025
613	126'-9"			13.513			Pe
608	126'-9"			13.538		10'-0"	Pv
<b>Route 3</b>							
DY	1.0490	26.05	9.67	0.004"	0.213907	0'-0"	Pf 1.070
6004	124'-8"	26.05	8.04 (adj)	10.493	Sprinkler,	5'-0"	Pe -0.903
609	126'-9"			10.660	PO(5'-0), fd	5'-0"	Pv
<b>Route 4</b>							
DY	1.0490	26.06	9.68	0.004"	0.214143	0'-0"	Pf 1.071
6007	124'-8"	26.06	8.04 (adj)	10.505	Sprinkler,	5'-0"	Pe -0.903
614	126'-9"			10.673	PO(5'-0), fd	5'-0"	Pv
<b>Route 5</b>							
DY	1.0490	26.27	9.75	0.004"	0.217506	0'-0"	Pf 1.088
6002	124'-8"	26.27	8.04 (adj)	10.674	Sprinkler,	5'-0"	Pe -0.903
606	126'-9"			10.859	PO(5'-0), fd	5'-0"	Pv
<b>Route 6</b>							
DY	1.0490	26.29	9.76	0.004"	0.217746	0'-0"	Pf 1.089
6006	124'-8"	26.29	8.04 (adj)	10.686	Sprinkler,	5'-0"	Pe -0.903
611	126'-9"			10.872	PO(5'-0), fd	5'-0"	Pv
<b>Route 7</b>							
DY	1.0490	27.68	10.28	0.004"	0.240838	0'-0"	Pf 1.204
6003	124'-0"	27.68	8.04 (adj)	11.849	Sprinkler,	5'-0"	Pe -1.481
607	127'-5"			11.571	PO(5'-0), fd	5'-0"	Pv
<b>Route 8</b>							
DY	1.0490	27.75	10.30	0.004"	0.242051	0'-0"	Pf 1.210
6008	124'-0"	27.75	8.04 (adj)	11.910	Sprinkler,	5'-0"	Pe -1.481
612	127'-5"			11.639	PO(5'-0), fd	5'-0"	Pv
<b>Route 9</b>							
DY	1.0490	28.10	10.43	0.004"	0.248015	0'-0"	Pf 1.240
6001	124'-8"	28.10	8.04 (adj)	12.210	Sprinkler,	5'-0"	Pe -0.867
605	126'-8"			12.583	PO(5'-0), fd	5'-0"	Pv
BL	2.1570	28.10	2.47	0.004"	0.006152	10'-0"	Pf 0.062
605	126'-8"			12.583			Pe
603	126'-8"			12.645		10'-0"	Pv
BL	2.1570	56.26	4.94	0.004"	0.023106	13'-5½"	Pf 1.022
603	126'-8"	28.16		12.645	Flow (q) from Route 10	30'-9"	Pe -0.036
604	126'-9"			13.630	3E(6'-2), PO(12'-3½)	44'-2½"	Pv
<b>Route 10</b>							
DY	1.0490	28.16	10.45	0.004"	0.249126	0'-0"	Pf 1.246
6000	124'-8"	28.16	8.04 (adj)	12.266	Sprinkler,	5'-0"	Pe -0.867
603	126'-8"			12.645	PO(5'-0), fd	5'-0"	Pv
<b>Route 11</b>							
CM	2.6350	37.59	2.21	0.004"	0.003885	363'-4"	Pf 1.987
602	126'-7"			14.451	PO(16'-5½)	148'-3"	Pe 0.036
601	126'-6"			16.475	2Ee1(4'-1½), 10E(8'-3), T(16'-5 ½), 2EE(4'-1½), PO(16'-5½)	511'-7"	Pv

$$\Delta P = 0.000216 f \frac{lpQ^2}{d^5}$$

K-Factor conversion formula:

$$K_A = 7.94 K_w \sqrt{\frac{1}{\gamma_A}}$$

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

### C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap



# Hydraulic Overview

Job Number: 22-3688  
Report Description: Light Hazard (7)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1032 ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.63 K-Factor 19.60 at 12.125	Hose Streams 100.00
Coverage Per Sprinkler 196 ft <sup>2</sup>	Number Of Sprinklers Calculated 8
System Pressure Demand 45.340	System Flow Demand 157.37
Total Demand 257.37 @ 45.340	Pressure Result +17.893 (28.3%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	100.00	64.000	20.000
<p>FPET NICET #106245 LEVEL IV, MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>Signature</i> 03/26/2024 Expires 12/31/24</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L02-Asbuilt

Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)










### Supply at Node 1



Hydraulic Graph

Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
63.234 @ 257.37

Required Pressure at System Demand  
45.340 @ 157.37

Required Pressure at System Demand (Including Hose Allowance at Source)  
45.340 @ 257.37



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 7200	19.75	19.60	5.63	12.309			
Sprinkler 7201	19.64	19.60	5.63	12.178			
Sprinkler 7202	19.71	19.60	5.63	12.267			
Sprinkler 7203	19.63	19.60	5.63	12.166			
Sprinkler 7204	19.60	19.60	5.63	12.125			
Sprinkler 7205	19.71	19.60	5.63	12.267			
Sprinkler 7206	19.72	19.60	5.63	12.272			
<b>⇒ Sprinkler 7207</b>	<b>19.60</b>	<b>19.60</b>	<b>5.63</b>	<b>12.125</b>			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Light Hazard (7)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	45.340	157.37
7200	128'-3	Spr(-12.309)	12.309	19.75
7201	128'-3	Spr(-12.178)	12.178	19.64
7202	128'-3	Spr(-12.267)	12.267	19.71
7203	128'-3	Spr(-12.166)	12.166	19.63
7204	128'-3	Spr(-12.125)	12.125	19.60
7205	128'-3	Spr(-12.267)	12.267	19.71
7206	128'-3	Spr(-12.272)	12.272	19.72
7207	128'-3	Spr(-12.125)	12.125	19.60
2	84'-6½	PIV(-2.000)	45.301	
3	84'-6½	BFP(-0.310)	43.293	
6	84'-6½	PO(20'-0)	42.980	
7	90'-9		40.183	
8	91'-4½	St(-0.040)	39.912	
9	102'-6½	PO(20'-2)	35.001	
600	126'-6	PO(12'-3½)	18.419	
601	126'-6	PO(16'-5½)	18.130	
602	126'-7	PO(16'-5½)	17.827	
700	127'-7	PO(9'-11)	13.820	
701	127'-7	PO(5'-0)	13.293	
702	127'-8	PO(5'-0)	13.109	
703	127'-7	PO(9'-11)	13.774	
704	127'-7	PO(5'-0)	13.249	
705	127'-7	PO(5'-0)	13.143	
706	127'-7	PO(5'-0)	13.099	
707	127'-8	PO(5'-0)	13.208	
708	127'-7	PO(9'-11)	13.774	
709	127'-7	PO(5'-0)	13.249	
710	127'-0½	PO(9'-11)	14.114	
711	127'-7	PO(5'-0)	13.099	
801	101'-6	T(14'-4½)	35.001	
802	111'-0	E(6'-8½)	35.001	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (7)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
BL	1.0490	19.60	7.28	0.004"	0.122989	0'-8"	Pf 0.694
7207	128'-3"	19.60	5.63 (adj)	12.125	Sprinkler,	5'-0"	Pe 0.280
711	127'-7"			13.099	PO(5'-0)	5'-8"	Pv
BL	1.6820	19.60	2.83	0.004"	0.010954	13'-8½"	Pf 0.150
711	127'-7"			13.099			Pe
709	127'-7"			13.249		13'-8½"	Pv
BL	1.6820	39.31	5.68	0.004"	0.041457	2'-9"	Pf 0.524
709	127'-7"	19.71		13.249	Flow (q) from Route 5	9'-11"	Pe
708	127'-7"			13.774	PO(9'-11)	12'-8"	Pv
CM	2.6350	37.65	2.22	0.004"	0.003896	14'-7½"	Pf 0.105
708	127'-7"			13.774		12'-4½"	Pe 0.235
710	127'-0½"			14.114	E(8'-3), EE(4'-1½)	27'-0"	Pv
CM	2.6350	77.01	4.53	0.004"	0.015193	183'-0"	Pf 3.781
710	127'-0½"	39.36		14.114	Flow (q) from Route 4	65'-11"	Pe 0.235
601	126'-6"			18.130	5E(8'-3), Ee1(4'-1½), EE(4'-1½), PO(16'-5½)	248'-10½"	Pv
CM	4.2600	157.37	3.54	0.004"	0.005191	29'-4"	Pf 0.289
601	126'-6"	80.36		18.130	Flow (q) from Route 2	26'-4"	Pe
600	126'-6"			18.419	PO(26'-4)	55'-8"	Pv
CM	6.3570	157.37	1.59	0.004"	0.000695	118'-8½"	Pf 6.194
600	126'-6"			18.419		160'-6½"	Pe 10.388
9	102'-6½"			35.001	6E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½)	279'-3½"	Pv
CM	6.3570	157.37	1.59	0.004"	0.000695	20'-5"	Pf 0.075
9	102'-6½"			35.001		30'-2"	Pe 4.836
8	91'-4½"			39.912	BV(12'-7), E(17'-7), St(-0.040)	50'-7"	Pv
DY	6.3400	157.37	1.60	0.004"	0.000704	0'-0"	Pf 0.000
8	91'-4½"			39.912			Pe 0.271
7	90'-9"			40.183		0'-0"	Pv
UG	6.3400	157.37	1.60	0.004"	0.000704	86'-3½"	Pf 0.110
7	90'-9"			40.183		69'-4"	Pe 2.688
6	84'-6½"			42.980	3E(23'-1½)	155'-7½"	Pv
UG	6.3400	157.37	1.60	0.004"	0.000704	4'-1½"	Pf 0.312
6	84'-6½"			42.980			Pe
3	84'-6½"			43.293	BFP(-0.310)	4'-1½"	Pv
UG	6.3400	157.37	1.60	0.004"	0.000704	11'-2½"	Pf 2.008
3	84'-6½"			43.293			Pe
2	84'-6½"			45.301	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	157.37	1.60	0.004"	0.000704	21'-7"	Pf 0.040
2	84'-6½"			45.301		34'-8"	Pe
1	84'-6½"			45.340	E(23'-1½), EE(11'-6½), S	56'-3"	Pv
1		100.00			Hose Allowance At Source		
1		257.37					
<b>Route 2</b>							
BL	1.0490	19.60	7.28	0.004"	0.122989	0'-8"	Pf 0.694
7204	128'-3"	19.60	5.63 (adj)	12.125	Sprinkler,	5'-0"	Pe 0.280
706	127'-7"			13.099	PO(5'-0)	5'-8"	Pv
BL	1.6820	19.60	2.83	0.004"	0.010954	13'-8½"	Pf 0.150
706	127'-7"			13.099			Pe
704	127'-7"			13.249		13'-8½"	Pv
BL	1.6820	39.31	5.68	0.004"	0.041457	2'-9"	Pf 0.524
704	127'-7"	19.71		13.249	Flow (q) from Route 6	9'-11"	Pe
703	127'-7"			13.774	PO(9'-11)	12'-8"	Pv
CM	2.6350	40.98	2.41	0.004"	0.004570	10'-0"	Pf 0.046
703	127'-7"	1.67		13.774	Flow (q) from Route 9		Pe
700	127'-7"			13.820		10'-0"	Pv
CM	2.6350	80.36	4.73	0.004"	0.016490	146'-8½"	Pf 3.574
700	127'-7"	39.38		13.820	Flow (q) from Route 3	70'-0"	Pe 0.434
602	126'-7"			17.827	T(16'-5½), 4E(8'-3), Ee1(4'-1½), PO(16'-5½)	216'-8½"	Pv
CM	4.2600	80.36	1.81	0.004"	0.001455	104'-6"	Pf 0.267
602	126'-7"			17.827		79'-0"	Pe 0.036
601	126'-6"			18.130	6E(13'-2)	183'-6"	Pv
<b>Route 3</b>							



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (7)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.0490	19.63	7.29	0.004"	0.123395	0'-7½"	Pf 0.697
7203	128'-3"	19.63	5.63 (adj)	12.166	Sprinkler,	5'-0"	Pe 0.280
705	127'-7"			13.143	PO(5'-0)	5'-8"	Pv
BL	1.6820	19.63	2.83	0.004"	0.010989	13'-8½"	Pf 0.151
705	127'-7"			13.143			Pe
701	127'-7"			13.293		13'-8½"	Pv
BL	1.6820	39.38	5.69	0.004"	0.041593	2'-9"	Pf 0.526
701	127'-7"	19.75		13.293	Flow (q) from Route 8	9'-11"	Pe
700	127'-7"			13.820	PO(9'-11)	12'-8"	Pv
<b>Route 4</b>							
BL	1.0490	19.64	7.29	0.004"	0.123512	0'-7"	Pf 0.687
7201	128'-3"	19.64	5.63 (adj)	12.178	Sprinkler,	5'-0"	Pe 0.244
702	127'-8"			13.109	PO(5'-0)	5'-7"	Pv
BL	1.6820	19.64	2.84	0.004"	0.010999	9'-0"	Pf 0.099
702	127'-8"			13.109			Pe
707	127'-8"			13.208		9'-0"	Pv
BL	1.6820	39.36	5.68	0.004"	0.041552	2'-11"	Pf 0.635
707	127'-8"	19.72		13.208	Flow (q) from Route 7	12'-4½"	Pe 0.271
710	127'-0½"			14.114	EE(2'-5½), PO(9'-11)	15'-3½"	Pv
<b>Route 5</b>							
BL	1.0490	19.71	7.32	0.004"	0.124387	0'-7½"	Pf 0.702
7205	128'-3"	19.71	5.63 (adj)	12.267	Sprinkler,	5'-0"	Pe 0.280
709	127'-7"			13.249	PO(5'-0)	5'-8"	Pv
<b>Route 6</b>							
BL	1.0490	19.71	7.32	0.004"	0.124388	0'-7½"	Pf 0.702
7202	128'-3"	19.71	5.63 (adj)	12.267	Sprinkler,	5'-0"	Pe 0.280
704	127'-7"			13.249	PO(5'-0)	5'-8"	Pv
<b>Route 7</b>							
BL	1.0490	19.72	7.32	0.004"	0.124435	0'-7"	Pf 0.692
7206	128'-3"	19.72	5.63 (adj)	12.272	Sprinkler,	5'-0"	Pe 0.244
707	127'-8"			13.208	PO(5'-0)	5'-7"	Pv
<b>Route 8</b>							
BL	1.0490	19.75	7.33	0.004"	0.124798	0'-8"	Pf 0.705
7200	128'-3"	19.75	5.63 (adj)	12.309	Sprinkler,	5'-0"	Pe 0.280
701	127'-7"			13.293	PO(5'-0)	5'-8"	Pv
<b>Route 9</b>							
CM	2.6350	1.67	0.10	0.004"	0.000009	9'-0"	Pf 0.000
708	127'-7"	37.65		13.774	Flow (q) from Route 1		Pe
703	127'-7"			13.774		9'-0"	Pv

$\Delta P = 0.000216 f \frac{\rho Q^2}{d^5}$  K-Factor conversion formula:  $K_A = 7.94 K_W \sqrt{\frac{1}{\gamma_A}}$

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)		C Value Multiplier			
$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$	Value Of C	100	130	140	150
	Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 22-3688

Report Description: Light Hazard (7)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap





# Hydraulic Summary

Job Number: 22-3688  
Report Description: Light Hazard (8)

Job	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	State Certification/License Number
Address 1 1601 39th AVE SE	AHJ CITY OF PUYALLUP
Address 2 Puyallup, WA 98374	Job Site/Building PIERCE COLLEGE PUYALLUP
Address 3	Drawing Name 22-3688_PeirceSTEM-L02-Asbuilt

System		Remote Area(s)	
Most Demanding Sprinkler Data 5.34 K-Factor 14.12 at 7.000		Occupancy Light Hazard	Job Suffix
Hose Allowance At Source 100.00		Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1091 ft <sup>2</sup> )
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>		Number Of Sprinklers Calculated 8	Number Of Nozzles Calculated 0
		Coverage Per Sprinkler 130 ft <sup>2</sup>	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area Left: 34.959			
Total Hose Streams 100.00			
System Flow Demand 119.76	Total Water Required (Including Hose Allowance) 219.76		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 8.71 between nodes 810 and 811			
Maximum Velocity Under Ground 1.22 between nodes 6 and 7	Volume capacity of Antifreeze/Other Pipes 64.00 gal		
Volume capacity of Wet Pipes 2500.50 gal	Volume capacity of Dry Pipes		

Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	100.00	64.000	20.000	1950.00	63.441	219.76	38.341	25.100

**Darcy-Weisbach Calculation**

Darcy-Weisbach equations are being used because the system requires special design considerations. The Darcy-Weisbach formula used in this hydraulic calculation to determine fluid/agent friction loss is:  $P = 0.000216 f_L P (Q^2) / (d^5)$   
Friction Loss factors are derived from the Moody Diagram.  
Reynolds Number is calculated using:  $Re = Q/d/k$   
Relative Roughness of Pipe is:  $e/D$   
K-Factors for Sprinkler Heads are adjusted based on the density of the fluid being discharged (Bernoulli-based formula).  
C-Factors are not relevant to this type of calculation. These are replaced with the Roughness e-value for the pipe.


Description: Water/Antifreeze @ 0°F/-18°C, 10% Glycerine (C.P. or U.S.P. 96.5%) by weight  
Product Name: FreezeMaster By Lubrizol  
Antifreeze solution in pipes within or passing through:  
Cold Areas: Warm Areas:  
Density: 69.400 lb/ft<sup>3</sup> Density: 67.900 lb/ft<sup>3</sup>  
Viscosity: 55.000 cP Viscosity: 6.000 cP  
NFPA Suggested Aged Pipe Roughness is being applied.

Contractor			
Contractor Number 01		Contact Name Ben Bernard	Contact Title Engineer/PM
Name of Contractor: SHINN FIRE PROTECTION		Phone 425-204-3945	Extension
Address 1 18802 80TH AVE S		FAX	
Address 2 KENT WA98032		E-mail	
Address 3		Web-Site	





### Supply at Node 1



Hydraulic Graph

Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
63.441 @ 219.76

Required Pressure at System Demand  
38.341 @ 119.76

Required Pressure at System Demand (Including Hose Allowance at Source)  
38.341 @ 219.76



# Summary Of Outflowing Devices

Job Number: 22-3688  
Report Description: Light Hazard (8)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 8400	16.03	13.00	5.34	9.015			
Sprinkler 8401	15.88	13.00	5.34	8.853			
Sprinkler 8402	15.30	13.00	5.34	8.217			
Sprinkler 8403	15.12	13.00	5.34	8.025			
Sprinkler 8404	14.46	13.00	5.34	7.339			
Sprinkler 8405	14.61	13.00	5.34	7.489			
Sprinkler 8406	14.25	13.00	5.34	7.123			

➔ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Light Hazard (8)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	38.341	119.76
8400	126'-9½	Spr(-9.015)	9.015	16.03
8401	126'-9½	Spr(-8.853)	8.853	15.88
8402	126'-9½	Spr(-8.217)	8.217	15.30
8403	126'-9½	Spr(-8.025)	8.025	15.12
8404	126'-9½	Spr(-7.339)	7.339	14.46
8405	126'-9½	Spr(-7.489)	7.489	14.61
8406	126'-9½	Spr(-7.123)	7.123	14.25
8407	126'-9½	Spr(-7.000)	7.000	14.12
2	84'-6½	PIV(-2.000)	38.318	
3	84'-6½	BFP(-0.179)	36.313	
6	84'-6½	PO(20'-0)	36.132	
7	90'-9		33.378	
8	91'-4½	St(-0.023)	33.107	
9	102'-6½	PO(20'-2)	28.227	
801	101'-6	T(5'-0)	26.863	
802	111'-0	E(6'-8½)	22.205	
803	111'-6½	E(6'-8½)	21.852	
805	115'-4		18.787	
806	127'-0½	E(5'-10½)	13.426	
807	127'-0½	PO(7'-0½)	12.318	
808	127'-0½	PO(3'-7)	11.144	
809	127'-0½	PO(3'-7)	10.248	
810	127'-0½	PO(7'-0½)	12.045	
811	127'-0½	PO(3'-7)	10.854	
812	127'-0½	PO(3'-7)	9.164	
813	127'-0½	PO(3'-7)	9.938	
814	127'-0½	PO(3'-7)	9.333	
815	105'-4		25.873	
816	127'-0½	PO(3'-7)	8.780	
817	127'-0½	PO(3'-7)	8.920	
818	127'-0½	E(3'-6½)	8.780	
819	127'-0½		8.919	
820	127'-0½		8.780	
821	127'-0½		8.919	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Light Hazard (8)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
<b>Route 1</b>							
DR	1.0490	14.12	5.24	0.015"	0.175030	2'-2½"	Pf 1.881
8407	126'-9½"	14.12	5.34 (adj)	7.000	Sprinkler,	8'-6½"	Pe -0.101
816	127'-0½"			8.780	T(3'-7), E(1'-5), PO(3'-7)	10'-9"	Pv
BL	1.6820	13.66	1.97	0.015"	0.025616	15'-0"	Pf 0.384
816	127'-0½"			8.780			Pe
812	127'-0½"			9.164		15'-0"	Pv
BL	1.6820	28.12	4.06	0.015"	0.052730	13'-6"	Pf 1.084
812	127'-0½"	14.46		9.164	Flow (q) from Route 3	7'-0½"	Pe
809	127'-0½"			10.248	2E(3'-6½)	20'-6½"	Pv
BL	1.6820	43.42	6.27	0.015"	0.081419	11'-0"	Pf 0.896
809	127'-0½"	15.30		10.248	Flow (q) from Route 6		Pe
808	127'-0½"			11.144		11'-0"	Pv
BL	1.6820	59.45	8.58	0.015"	0.111468	3'-5½"	Pf 1.174
808	127'-0½"	16.03		11.144	Flow (q) from Route 8	7'-0½"	Pe
807	127'-0½"			12.318	PO(7'-0½)	10'-6½"	Pv
CM	2.6350	119.76	7.05	0.015"	0.058243	7'-3½"	Pf 1.108
807	127'-0½"	60.31		12.318	Flow (q) from Route 2	11'-9"	Pe
806	127'-0½"			13.426	2E(5'-10½)	19'-0½"	Pv
CM	3.0680	119.76	5.20	0.015"	0.023584	11'-8½"	Pf 0.277
806	127'-0½"			13.426			Pe 5.084
805	115'-4"			18.787		11'-8½"	Pv
CM	3.2600	119.76	4.60	0.015"	0.016627	52'-10½"	Pf 1.437
805	115'-4"			18.787		33'-6½"	Pe 1.629
803	111'-6½"			21.852	5E(6'-8½)	86'-5"	Pv
DY	3.2600	119.76	4.60	0.015"	0.016124	0'-0"	Pf 0.108
803	111'-6½"			21.852		6'-8½"	Pe 0.244
802	111'-0"			22.205	E(6'-8½)	6'-8½"	Pv
CM	3.2600	119.76	4.60	0.015"	0.016627	11'-5"	Pf 0.541
802	111'-0"			22.205		21'-1"	Pe 4.117
801	101'-6"			26.863	E(6'-8½), T(14'-4½)	32'-6"	Pv
CM	3.2600	119.76	4.60	0.015"	0.016124	8'-8"	Pf 0.670
801	101'-6"			26.863		32'-10½"	Pe -1.659
815	105'-4"			25.873	sCV(5'-1), 2E(6'-8½), T(14'-4½)	41'-6½"	Pv
CM	3.2600	119.76	4.60	0.004"	0.011985	40'-7"	Pf 1.147
815	105'-4"			25.873		55'-1"	Pe 1.207
9	102'-6½"			28.227	f(-0.000), sCV(21'-6), BV(13'-5½), PO(20'-2)	95'-8"	Pv
CM	6.3570	119.76	1.21	0.004"	0.000418	20'-5"	Pf 0.044
9	102'-6½"			28.227		30'-2"	Pe 4.836
8	91'-4½"			33.107	BV(12'-7), E(17'-7), St(-0.023)	50'-7"	Pv
DY	6.3400	119.76	1.22	0.004"	0.000424	0'-0"	Pf 0.000
8	91'-4½"			33.107			Pe 0.271
7	90'-9"			33.378		0'-0"	Pv
UG	6.3400	119.76	1.22	0.004"	0.000424	86'-3½"	Pf 0.066
7	90'-9"			33.378		69'-4"	Pe 2.688
6	84'-6½"			36.132	3E(23'-1½)	155'-7½"	Pv
UG	6.3400	119.76	1.22	0.004"	0.000424	4'-1½"	Pf 0.181
6	84'-6½"			36.132			Pe
3	84'-6½"			36.313	BFP(-0.179)	4'-1½"	Pv
UG	6.3400	119.76	1.22	0.004"	0.000424	11'-2½"	Pf 2.005
3	84'-6½"			36.313			Pe
2	84'-6½"			38.318	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	119.76	1.22	0.004"	0.000424	21'-7"	Pf 0.024
2	84'-6½"			38.318		34'-8"	Pe
1	84'-6½"			38.341	E(23'-1½), EE(11'-6½), S	56'-3"	Pv
		100.00			Hose Allowance At Source		
1		219.76					
<b>Route 2</b>							
DR	1.0490	14.25	5.29	0.015"	0.176565	2'-2½"	Pf 1.897
8406	126'-9½"	14.25	5.34 (adj)	7.123	Sprinkler,	8'-6½"	Pe -0.101
817	127'-0½"			8.920	T(3'-7), E(1'-5), PO(3'-7)	10'-9"	Pv
BL	1.6820	14.71	2.12	0.015"	0.027575	15'-0"	Pf 0.414
817	127'-0½"	0.46		8.920	Flow (q) from Route 9		Pe
814	127'-0½"			9.333		15'-0"	Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.6820	29.31	4.23	0.015"	0.054964	11'-0"	Pf 0.605
814	127'-0½"	14.61		9.333	Flow (q) from Route 4		Pe
813	127'-0½"			9.938		11'-0"	Pv
BL	1.6820	44.43	6.42	0.015"	0.083316	11'-0"	Pf 0.916
813	127'-0½"	15.12		9.938	Flow (q) from Route 5		Pe
811	127'-0½"			10.854		11'-0"	Pv
BL	1.6820	60.31	8.71	0.015"	0.113094	3'-5½"	Pf 1.191
811	127'-0½"	15.88		10.854	Flow (q) from Route 7	7'-0½"	Pe
810	127'-0½"			12.045	PO(7'-0½")	10'-6½"	Pv
CM	2.6350	60.31	3.55	0.015"	0.018777	14'-6"	Pf 0.272
810	127'-0½"			12.045			Pe
807	127'-0½"			12.318		14'-6"	Pv
<b>Route 3</b>							
DR	1.0490	14.46	5.37	0.015"	0.179221	2'-2½"	Pf 1.926
8404	126'-9½"	14.46	5.34 (adj)	7.339	Sprinkler,	8'-6½"	Pe -0.101
812	127'-0½"			9.164	T(3'-7), E(1'-5), PO(3'-7)	10'-9"	Pv
<b>Route 4</b>							
DR	1.0490	14.61	5.42	0.015"	0.181039	2'-2½"	Pf 1.945
8405	126'-9½"	14.61	5.34 (adj)	7.489	Sprinkler,	8'-6½"	Pe -0.101
814	127'-0½"			9.333	T(3'-7), E(1'-5), PO(3'-7)	10'-9"	Pv
<b>Route 5</b>							
DR	1.0490	15.12	5.61	0.015"	0.187408	2'-2½"	Pf 2.014
8403	126'-9½"	15.12	5.34 (adj)	8.025	Sprinkler,	8'-6½"	Pe -0.101
813	127'-0½"			9.938	T(3'-7), E(1'-5), PO(3'-7)	10'-9"	Pv
<b>Route 6</b>							
DR	1.0490	15.30	5.68	0.015"	0.189631	2'-8½"	Pf 2.132
8402	126'-9½"	15.30	5.34 (adj)	8.217	Sprinkler,	8'-6½"	Pe -0.101
809	127'-0½"			10.248	T(3'-7), E(1'-5), PO(3'-7)	11'-3"	Pv
<b>Route 7</b>							
DR	1.0490	15.88	5.90	0.015"	0.196835	2'-2"	Pf 2.111
8401	126'-9½"	15.88	5.34 (adj)	8.853	Sprinkler,	8'-6½"	Pe -0.110
811	127'-0½"			10.854	T(3'-7), E(1'-5), PO(3'-7)	10'-8½"	Pv
<b>Route 8</b>							
DR	1.0490	16.03	5.95	0.015"	0.198628	2'-8½"	Pf 2.237
8400	126'-9½"	16.03	5.34 (adj)	9.015	Sprinkler,	8'-6½"	Pe -0.108
808	127'-0½"			11.144	T(3'-7), E(1'-5), PO(3'-7)	11'-3"	Pv
<b>Route 9</b>							
BL	1.6820	0.46	0.07	0.015"	0.000863	0'-7½"	Pf 0.001
816	127'-0½"	13.66		8.780	Flow (q) from Route 1		Pe
820	127'-0½"			8.780		0'-7½"	Pv
DY	1.6820	0.46	0.07	0.015"	0.000016	0'-0"	Pf 0.000
820	127'-0½"			8.780		3'-6½"	Pe
818	127'-0½"			8.780	E(3'-6½")	3'-6½"	Pv
BL	1.0490	0.46	0.17	0.015"	0.005705	17'-11"	Pf 0.139
818	127'-0½"			8.780		6'-5"	Pe
821	127'-0½"			8.919	2E(1'-5), T(3'-7)	24'-4"	Pv
DY	1.6820	0.46	0.07	0.015"	0.000016	0'-0"	Pf 0.000
821	127'-0½"			8.919			Pe
819	127'-0½"			8.919		0'-0"	Pv
BL	1.6820	0.46	0.07	0.015"	0.000863	0'-7"	Pf 0.000
819	127'-0½"			8.919			Pe
817	127'-0½"			8.920		0'-7"	Pv

$$\Delta P = 0.000216 f \frac{lpQ^2}{d^5}$$

K-Factor conversion formula:

$$K_A = 7.94 K_w \sqrt{\frac{1}{\gamma_A}}$$

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 22-3688

Report Description: Light Hazard (8)

Pipe Type	Diameter	Flow	Velocity	HWC/Roughness		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LiE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PRV	Pressure Reducing Valve
PrV	Pressure Relief Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap










### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure  
20.000 @ 1950.00

Available Flow @ 20 PSI:  
0.00

Available Pressure at System Demand  
60.213 @ 517.91

Required Pressure at System Demand  
50.006 @ 267.91

Required Pressure at System Demand (Including Hose Allowance at Source)  
50.006 @ 517.91



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 9000	26.82	26.00	8	11.237			
Sprinkler 9001	26.31	26.00	8	10.816			
Sprinkler 9002	26.73	26.00	8	11.163			
Sprinkler 9003	26.26	26.00	8	10.772			
Sprinkler 9004	26.73	26.00	8	11.163			
➔ <b>Sprinkler 9005</b>	<b>26.00</b>	<b>26.00</b>	<b>8</b>	<b>10.563</b>			
Sprinkler 9006	27.95	26.00	8	12.204			
Sprinkler 9007	26.37	26.00	8	10.869			
Sprinkler 9008	26.80	26.00	8	11.223			
Sprinkler 9009	27.95	26.00	8	12.203			

➔ Most Demanding Sprinkler Data



# Node Analysis

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	50.006	267.91
9000	139'-10½	Spr(-11.237), fd	11.237	26.82
9001	139'-10½	Spr(-10.816), fd	10.816	26.31
9002	139'-10½	Spr(-11.163), fd	11.163	26.73
9003	139'-10½	Spr(-10.772), fd	10.772	26.26
9004	139'-10½	Spr(-11.163), fd	11.163	26.73
9005	139'-10½	Spr(-10.563), fd	10.563	26.00
9006	139'-10½	Spr(-12.204), fd	12.204	27.95
9007	139'-10½	Spr(-10.869), fd	10.869	26.37
9008	139'-10½	Spr(-11.223), fd	11.223	26.80
9009	139'-10½	Spr(-12.203), fd	12.203	27.95
2	84'-6½	PIV(-2.000)	49.901	
3	84'-6½	BFP(-0.953)	47.880	
6	84'-6½	PO(20'-0)	46.920	
7	90'-9		43.942	
8	91'-4½	St(-0.132)	43.671	
9	102'-6½	PO(20'-2)	38.580	
801	101'-6	T(14'-4½)	38.580	
802	111'-0	E(6'-8½)	38.580	
803	111'-6½	E(6'-8½)	38.580	
900	144'-9	E(13'-2)	13.725	
901	144'-9	PO(12'-3½)	12.716	
902	144'-9	PO(12'-3½)	12.572	
903	144'-9	PO(12'-3½)	12.508	
904	144'-9	PO(12'-3½)	12.474	
905	140'-6		10.551	
906	141'-6		10.538	
907	144'-9	PO(6'-0)	9.673	
908	144'-9	PO(6'-0)	9.291	
909	144'-9	PO(6'-0)	9.597	
910	144'-9	PO(6'-0)	9.244	
911	141'-6		10.464	
912	140'-6		10.506	
913	140'-6		10.297	
914	141'-6		10.464	
915	144'-9	PO(6'-0)	9.596	
916	144'-9	PO(6'-0)	9.247	
917	144'-9	PO(6'-0)	10.748	
918	140'-6		11.939	
919	144'-9	PO(6'-0)	9.345	
920	141'-6		10.524	
921	140'-6		10.591	
922	144'-9	PO(6'-0)	10.746	
923	144'-9	PO(6'-0)	9.659	
924	140'-6		11.937	
925	144'-9	PO(12'-3½)	11.072	
926	144'-9	PO(12'-3½)	11.112	
927	144'-9	PO(12'-3½)	11.080	
928	144'-9	PO(12'-3½)	11.168	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (9)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
<b>Route 1</b>							
DY	1.0490	26.00	9.65	120	0.211435	0'-0	Pf 0.000
9005	139'-10½	26.00	8	10.563	Sprinkler, , fd	0'-0	Pe -0.266
913	140'-6			10.297		Pv	
DR	1.3800	26.00	5.58	120	0.055609	5'-3	Pf 0.792
913	140'-6			10.297		9'-0	Pe -1.842
916	144'-9			9.247	E(3'-0), PO(6'-0)	14'-3	Pv
BL	2.1570	31.21	2.74	120	0.008857	11'-1	Pf 0.098
916	144'-9	5.21		9.247	Flow (q) from Route 14		Pe
919	144'-9			9.345		11'-1	Pv
BL	2.1570	57.59	5.06	120	0.027504	50'-9	Pf 1.735
919	144'-9	26.37		9.345	Flow (q) from Route 4	12'-3½	Pe
927	144'-9			11.080	PO(12'-3½)	63'-1	Pv
CM	4.2600	109.11	2.46	120	0.003262	9'-10½	Pf 0.032
927	144'-9	51.53		11.080	Flow (q) from Route 7		Pe
926	144'-9			11.112		9'-10½	Pv
CM	4.2600	133.94	3.01	120	0.004767	11'-9½	Pf 0.056
926	144'-9	24.83		11.112	Flow (q) from Route 11		Pe
928	144'-9			11.168		11'-9½	Pv
CM	4.2600	112.42	2.53	120	0.003448	244'-4½	Pf 1.306
928	144'-9			11.168		134'-3½	Pe 0.000
904	144'-9			12.474	9E(13'-2), 2EE(5'-3), Ee2(5'-3)	378'-8	Pv
CM	4.2600	133.94	3.01	120	0.004767	7'-2½	Pf 0.034
904	144'-9	21.52		12.474	Flow (q) from Route 12		Pe
903	144'-9			12.508		7'-2½	Pv
CM	4.2600	165.01	3.71	120	0.007012	9'-2	Pf 0.064
903	144'-9	31.07		12.508	Flow (q) from Route 9		Pe
902	144'-9			12.572		9'-2	Pv
CM	4.2600	212.36	4.78	120	0.011182	12'-10	Pf 0.144
902	144'-9	47.36		12.572	Flow (q) from Route 2		Pe
901	144'-9			12.716		12'-10	Pv
CM	4.2600	267.91	6.03	120	0.017187	32'-4½	Pf 1.009
901	144'-9	55.55		12.716	Flow (q) from Route 5	26'-4	Pe
900	144'-9			13.725	2E(13'-2)	58'-8½	Pv
FR	6.3570	267.91	2.71	120	0.002447	103'-5½	Pf 6.560
900	144'-9			13.725		125'-4½	Pe 18.295
9	102'-6½			38.580	4E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½)	228'-9½	Pv
CM	6.3570	267.91	2.71	120	0.002447	20'-5	Pf 0.255
9	102'-6½			38.580		30'-2	Pe 4.836
8	91'-4½			43.671	BV(12'-7), E(17'-7), St(-0.132)	50'-7	Pv
DY	6.3400	267.91	2.72	140	0.001864	0'-0	Pf 0.000
8	91'-4½			43.671		0'-0	Pe 0.271
7	90'-9			43.942		0'-0	Pv
UG	6.3400	267.91	2.72	140	0.001864	86'-3½	Pf 0.290
7	90'-9			43.942		69'-4	Pe 2.688
6	84'-6½			46.920	3E(23'-1½)	155'-7½	Pv
UG	6.3400	267.91	2.72	140	0.001864	4'-1½	Pf 0.961
6	84'-6½			46.920			Pe
3	84'-6½			47.880	BFP(-0.953)	4'-1½	Pv
UG	6.3400	267.91	2.72	140	0.001864	11'-2½	Pf 2.021
3	84'-6½			47.880			Pe
2	84'-6½			49.901	PIV(-2.000)	11'-2½	Pv
UG	6.3400	267.91	2.72	140	0.001864	21'-7	Pf 0.105
2	84'-6½			49.901		34'-8	Pe
1	84'-6½			50.006	E(23'-1½), EE(11'-6½), S	56'-3	Pv
		250.00			Hose Allowance At Source		
1		517.91					
<b>Route 2</b>							
DY	1.0490	26.26	9.75	120	0.215309	0'-0	Pf 0.000
9003	139'-10½	26.26	8	10.772	Sprinkler, , fd	0'-0	Pe -0.266
912	140'-6			10.506		Pv	
DR	1.3800	26.26	5.63	120	0.056628	4'-3	Pf 0.580
912	140'-6			10.506		6'-0	Pe -1.842
910	144'-9			9.244	PO(6'-0)	10'-3	Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
BL	2.1570	21.05	1.85	120	0.004272	10'-11½"	Pf 0.047
910	144'-9"			9.244			Pe
908	144'-9"			9.291		10'-11½"	Pv
BL	2.1570	47.36	4.16	120	0.019153	122'-1"	Pf 3.281
908	144'-9"	26.31		9.291	Flow (q) from Route 3	49'-2½"	Pe
902	144'-9"			12.572	6E(6'-2"), PO(12'-3½")	171'-4"	Pv
<b>Route 3</b>							
DY	1.0490	26.31	9.77	120	0.216132	0'-0"	Pf 0.000
9001	139'-10½"	26.31	8	10.816	Sprinkler,		Pe -0.266
905	140'-6"			10.551	, fd	0'-0"	Pv
DR	1.3800	26.31	5.64	120	0.056844	4'-3"	Pf 0.583
905	140'-6"			10.551		6'-0"	Pe -1.842
908	144'-9"			9.291	PO(6'-0)	10'-3"	Pv
<b>Route 4</b>							
DY	1.0490	26.37	9.79	120	0.217111	0'-0"	Pf 0.000
9007	139'-10½"	26.37	8	10.869	Sprinkler,		Pe -0.278
921	140'-6"			10.591	, fd	0'-0"	Pv
DR	1.3800	26.37	5.66	120	0.057101	4'-2½"	Pf 0.584
921	140'-6"			10.591		6'-0"	Pe -1.830
919	144'-9"			9.345	PO(6'-0)	10'-2½"	Pv
<b>Route 5</b>							
DY	1.0490	26.73	9.92	120	0.222530	0'-0"	Pf 0.000
9004	139'-10½"	26.73	8	11.163	Sprinkler,		Pe -0.699
914	141'-6"			10.464	, fd	0'-0"	Pv
DR	1.3800	26.73	5.73	120	0.058527	3'-3"	Pf 0.541
914	141'-6"			10.464		6'-0"	Pe -1.409
915	144'-9"			9.596	PO(6'-0)	9'-3"	Pv
BL	2.1570	2.00	0.18	120	0.000055	9'-2"	Pf 0.001
915	144'-9"			9.596			Pe
909	144'-9"			9.597		9'-2"	Pv
BL	2.1570	28.73	2.52	120	0.007599	10'-1"	Pf 0.077
909	144'-9"	26.73		9.597	Flow (q) from Route 6		Pe
907	144'-9"			9.673		10'-1"	Pv
BL	2.1570	55.55	4.88	120	0.025730	105'-11½"	Pf 3.042
907	144'-9"	26.82		9.673	Flow (q) from Route 8	12'-3½"	Pe
901	144'-9"			12.716	PO(12'-3½")	118'-3"	Pv
<b>Route 6</b>							
DY	1.0490	26.73	9.92	120	0.222539	0'-0"	Pf 0.000
9002	139'-10½"	26.73	8	11.163	Sprinkler,		Pe -0.699
911	141'-6"			10.464	, fd	0'-0"	Pv
DR	1.3800	26.73	5.73	120	0.058529	3'-3"	Pf 0.541
911	141'-6"			10.464		6'-0"	Pe -1.409
909	144'-9"			9.597	PO(6'-0)	9'-3"	Pv
<b>Route 7</b>							
DY	1.0490	26.80	9.95	120	0.223636	0'-0"	Pf 0.000
9008	139'-10½"	26.80	8	11.223	Sprinkler,		Pe -0.699
920	141'-6"			10.524	, fd	0'-0"	Pv
DR	1.3800	26.80	5.75	120	0.058818	3'-3"	Pf 0.544
920	141'-6"			10.524		6'-0"	Pe -1.409
923	144'-9"			9.659	PO(6'-0)	9'-3"	Pv
BL	2.1570	51.53	4.52	120	0.022392	50'-9½"	Pf 1.413
923	144'-9"	24.73		9.659	Flow (q) from Route 13	12'-3½"	Pe
925	144'-9"			11.072	PO(12'-3½")	63'-1½"	Pv
CM	4.2600	51.53	1.16	120	0.000814	9'-6½"	Pf 0.008
925	144'-9"			11.072			Pe
927	144'-9"			11.080		9'-6½"	Pv
<b>Route 8</b>							
DY	1.0490	26.82	9.96	120	0.223891	0'-0"	Pf 0.000
9000	139'-10½"	26.82	8	11.237	Sprinkler,		Pe -0.699
906	141'-6"			10.538	, fd	0'-0"	Pv
DR	1.3800	26.82	5.75	120	0.058885	3'-3"	Pf 0.545
906	141'-6"			10.538		6'-0"	Pe -1.409
907	144'-9"			9.673	PO(6'-0)	9'-3"	Pv
<b>Route 9</b>							
DY	1.0490	27.95	10.37	120	0.241641	0'-0"	Pf 0.000
9009	139'-10½"	27.95	8	12.203	Sprinkler,		Pe -0.266
924	140'-6"			11.937	, fd	0'-0"	Pv



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
DR	1.3800	27.95	5.99	120	0.063553	4'-3	Pf 0.651
924	140'-6			11.937		6'-0	Pe -1.842
922	144'-9			10.746	PO(6'-0)	10'-3	Pv
BL	2.1570	3.12	0.27	120	0.000125	11'-0½	Pf 0.001
922	144'-9			10.746			Pe
917	144'-9			10.748		11'-0½	Pv
BL	2.1570	31.07	2.73	120	0.008781	138'-11½	Pf 1.760
917	144'-9	27.95		10.748	Flow (q) from Route 10	61'-6½	Pe -0.000
903	144'-9			12.508	8E(6'-2), PO(12'-3½)	200'-5½	Pv
<b>Route 10</b>							
DY	1.0490	27.95	10.37	120	0.241665	0'-0	Pf 0.000
9006	139'-10½	27.95	8	12.204	Sprinkler,		Pe -0.266
918	140'-6			11.939	, fd	0'-0	Pv
DR	1.3800	27.95	5.99	120	0.063559	4'-3	Pf 0.651
918	140'-6			11.939		6'-0	Pe -1.842
917	144'-9			10.748	PO(6'-0)	10'-3	Pv
<b>Route 11</b>							
BL	2.1570	24.83	2.18	120	0.005800	50'-9	Pf 0.366
922	144'-9	3.12		10.746	Flow (q) from Route 9	12'-3½	Pe
926	144'-9			11.112	PO(12'-3½)	63'-0½	Pv
<b>Route 12</b>							
BL	2.1570	21.52	1.89	120	0.004451	194'-10	Pf 1.306
928	144'-9			11.168	PO(12'-3½)	98'-5½	Pe
904	144'-9			12.474	10E(6'-2), T(12'-3½), PO(12'-3½)	293'-3½	Pv
<b>Route 13</b>							
BL	2.1570	24.73	2.17	120	0.005757	10'-10½	Pf 0.063
915	144'-9	2.00		9.596	Flow (q) from Route 5		Pe
923	144'-9			9.659		10'-10½	Pv
<b>Route 14</b>							
BL	2.1570	5.21	0.46	120	0.000323	8'-0½	Pf 0.003
910	144'-9	21.05		9.244	Flow (q) from Route 2		Pe
916	144'-9			9.247		8'-0½	Pv

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

### C Value Multiplier

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 22-3688

Report Description: Ordinary Group II (9)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap



# Hydraulic Overview

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.20 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 924 ft <sup>2</sup> )
Most Demanding Sprinkler Data 8 K-Factor 26.00 at 10.563	Hose Streams 250.00
Coverage Per Sprinkler 130 ft <sup>2</sup>	Number Of Sprinklers Calculated 9
	Number Of Nozzles Calculated 0
System Pressure Demand 50.062	System Flow Demand 237.30
Total Demand 487.30 @ 50.062	Pressure Result +10.555 (17.4%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	250.00	64.000	20.000
<p>FPET NICET #106245 LEVEL IV,MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNM1060QP</p> <p><i>[Signature]</i>      03/26/2024      Expires 12/31/24 Signature      Date</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L03-Asbuilt

Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)







# Hydraulic Summary

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

Job	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	State Certification/License Number
Address 1 1601 39th AVE SE	AHJ CITY OF PUYALLUP
Address 2 Puyallup, WA 98374	Job Site/Building PIERCE COLLEGE PUYALLUP
Address 3	Drawing Name 22-3688_PeirceSTEM-L03-Asbuilt

System		Remote Area(s)	
Most Demanding Sprinkler Data 8 K-Factor 26.00 at 10.563		Occupancy Ordinary Group II	Job Suffix
Hose Allowance At Source 250.00		Density 0.20 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 924 ft <sup>2</sup> )
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>		Number Of Sprinklers Calculated 9	Number Of Nozzles Calculated 0
		Coverage Per Sprinkler 130 ft <sup>2</sup>	
		AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area Left: 50.062 Right: 50.062	
Total Hose Streams 250.00			
System Flow Demand 237.30	Total Water Required (Including Hose Allowance) 487.30		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 9.96 between nodes 1021 and 10200			
Maximum Velocity Under Ground 2.41 between nodes 6 and 7			
Volume capacity of Wet Pipes 3128.85 gal	Volume capacity of Dry Pipes		

### Supplies


Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	250.00	64.000	20.000	1950.00	60.617	487.30	50.062	10.555

### Contractor

Contractor Number 01	Contact Name Ben Bernard	Contact Title Engineer/PM
Name of Contractor: SHINN FIRE PROTECTION	Phone 425-204-3945	Extension
Address 1 18802 80TH AVE S	FAX	
Address 2 KENT WA98032	E-mail	
Address 3	Web-Site	



### Supply at Node 1



Hydraulic Graph

Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
60.617 @ 487.30

Required Pressure at System Demand  
50.062 @ 237.30

Required Pressure at System Demand (Including Hose Allowance at Source)  
50.062 @ 487.30



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 10200	26.84	26.00	8	11.255			
Sprinkler 10201	26.23	26.00	8	10.747			
Sprinkler 10202	26.50	26.00	8	10.969			
Sprinkler 10203	26.75	26.00	8	11.181			
Sprinkler 10204	26.40	26.00	8	10.894			
Sprinkler 10205	26.27	26.00	8	10.783			
Sprinkler 10206	26.19	26.00	8	10.715			
➔ <b>Sprinkler 10207</b>	<b>26.00</b>	<b>26.00</b>	<b>8</b>	<b>10.563</b>			
Sprinkler 10208	26.12	26.00	8	10.663			

➔ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	50.062	237.30
10200	139'-10	Spr(-11.255), fd	11.255	26.84
10201	139'-10	Spr(-10.747), fd	10.747	26.23
10202	139'-10	Spr(-10.969), fd	10.969	26.50
10203	139'-10	Spr(-11.181), fd	11.181	26.75
10204	139'-10	Spr(-10.894), fd	10.894	26.40
10205	139'-10	Spr(-10.783), fd	10.783	26.27
10206	139'-10	Spr(-10.715), fd	10.715	26.19
10207	139'-10	Spr(-10.563), fd	10.563	26.00
10208	139'-10	Spr(-10.663), fd	10.663	26.12
2	84'-6½	PIV(-2.000)	49.978	
3	84'-6½	BFP(-0.761)	47.962	
6	84'-6½	PO(20'-0)	47.194	
7	90'-9		44.275	
8	91'-4½	St(-0.091)	44.004	
9	102'-6½	PO(20'-2)	38.978	
801	101'-6	T(14'-4½)	38.978	
802	111'-0	E(6'-8½)	38.978	
803	111'-6½	E(6'-8½)	38.978	
900	144'-9	E(13'-2)	14.236	
901	144'-9	PO(12'-3½)	13.430	
902	144'-9	PO(12'-3½)	13.282	
903	144'-9	PO(12'-3½)	13.192	
904	144'-9	PO(12'-3½)	13.132	
925	144'-9	PO(12'-3½)	12.483	
926	144'-9	PO(12'-3½)	12.477	
927	144'-9	PO(12'-3½)	12.482	
928	144'-9	PO(12'-3½)	12.466	
1019	145'-8	PO(26'-4)	11.726	
1020	146'-4½	PO(12'-3½)	10.634	
1021	146'-4½	PO(5'-0)	10.443	
1022	146'-4½	PO(5'-0)	10.065	
1023	146'-4½	PO(16'-5½)	10.536	
1024	146'-4½		10.528	
1025	146'-4½	PO(5'-0)	10.404	
1026	146'-4½		10.092	
1027	146'-4½	PO(16'-5½)	10.447	
1028	146'-4½	PO(5'-0)	9.850	
1029	146'-4½	PO(5'-0)	10.346	
1030	146'-4½		10.008	
1031	146'-4½	PO(5'-0)	10.012	
1032	146'-4½	PO(5'-0)	9.804	
1033	146'-4½	PO(5'-0)	9.802	
1034	146'-4½	PO(5'-0)	9.743	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
<b>Route 1</b>							
DR	1.0490	26.00	9.65	120	0.211435	4'-9½"	Pf 2.070
10207	139'-10"	26.00	8	10.563	Sprinkler,	5'-0"	Pe -2.831
1033	146'-4½"			9.802	PO(5'-0), fd	9'-9½"	Pv
BL	2.1570	26.00	2.28	120	0.006317	7'-7"	Pf 0.048
1033	146'-4½"			9.802			Pe
1028	146'-4½"			9.850		7'-7"	Pv
BL	2.1570	52.23	4.59	120	0.022956	9'-4½"	Pf 0.215
1028	146'-4½"	26.23		9.850	Flow (q) from Route 4		Pe
1022	146'-4½"			10.065		9'-4½"	Pv
BL	2.1570	78.72	6.91	120	0.049044	0'-6½"	Pf 0.027
1022	146'-4½"	26.50		10.065	Flow (q) from Route 7		Pe
1026	146'-4½"			10.092		0'-6½"	Pv
BL	2.6350	78.72	4.63	120	0.018502	7'-6½"	Pf 0.444
1026	146'-4½"			10.092		16'-5½"	Pe -0.000
1023	146'-4½"			10.536	PO(16'-5½")	24'-0"	Pv
CM	4.2600	211.03	4.75	120	0.011052	10'-1"	Pf 0.112
1023	146'-4½"	105.46 + 26.84		10.536	Flow (q) from Route 2 and 9		Pe -0.014
1020	146'-4½"			10.634		10'-1"	Pv
CM	4.2600	237.30	5.34	120	0.013731	16'-7½"	Pf 0.770
1020	146'-4½"	26.27		10.634	Flow (q) from Route 5	39'-6"	Pe 0.321
1019	145'-8"			11.726	E(13'-2), PO(26'-4)	56'-1½"	Pv
CM	4.2600	167.18	3.76	120	0.007183	85'-1½"	Pf 1.009
1019	145'-8"			11.726		55'-3½"	Pe 0.397
904	144'-9"			13.132	3E(13'-2), 2EE(5'-3), Ee2(5'-3)	140'-5"	Pv
CM	4.2600	182.13	4.10	120	0.008416	7'-2½"	Pf 0.061
904	144'-9"	14.95		13.132	Flow (q) from Route 12		Pe
903	144'-9"			13.192		7'-2½"	Pv
CM	4.2600	198.24	4.46	120	0.009845	9'-2"	Pf 0.090
903	144'-9"	16.11		13.192	Flow (q) from Route 11		Pe
902	144'-9"			13.282		9'-2"	Pv
CM	4.2600	215.71	4.86	120	0.011510	12'-10"	Pf 0.148
902	144'-9"	17.47		13.282	Flow (q) from Route 13		Pe
901	144'-9"			13.430		12'-10"	Pv
CM	4.2600	237.30	5.34	120	0.013731	32'-4½"	Pf 0.806
901	144'-9"	21.59		13.430	Flow (q) from Route 10	26'-4"	Pe
900	144'-9"			14.236	2E(13'-2)	58'-8½"	Pv
FR	6.3570	237.30	2.40	120	0.001955	103'-5½"	Pf 6.447
900	144'-9"			14.236		125'-4½"	Pe 18.295
9	102'-6½"			38.978	4E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½)	228'-9½"	Pv
CM	6.3570	237.30	2.40	120	0.001955	20'-5"	Pf 0.190
9	102'-6½"			38.978		30'-2"	Pe 4.836
8	91'-4½"			44.004	BV(12'-7), E(17'-7), St(-0.091)	50'-7"	Pv
DY	6.3400	237.30	2.41	140	0.001489	0'-0"	Pf 0.000
8	91'-4½"			44.004			Pe 0.271
7	90'-9"			44.275		0'-0"	Pv
UG	6.3400	237.30	2.41	140	0.001489	86'-3½"	Pf 0.232
7	90'-9"			44.275		69'-4"	Pe 2.688
6	84'-6½"			47.194	3E(23'-1½)	155'-7½"	Pv
UG	6.3400	237.30	2.41	140	0.001489	4'-1½"	Pf 0.767
6	84'-6½"			47.194			Pe
3	84'-6½"			47.962	BFP(-0.761)	4'-1½"	Pv
UG	6.3400	237.30	2.41	140	0.001489	11'-2½"	Pf 2.017
3	84'-6½"			47.962			Pe
2	84'-6½"			49.978	PIV(-2.000)	11'-2½"	Pv
UG	6.3400	237.30	2.41	140	0.001489	21'-7"	Pf 0.084
2	84'-6½"			49.978		34'-8"	Pe
1	84'-6½"			50.062	E(23'-1½), EE(11'-6½), S	56'-3"	Pv
		250.00			Hose Allowance At Source		
1		487.30					
<b>Route 2</b>							
DR	1.0490	26.12	9.70	120	0.213289	3'-11½"	Pf 1.911
10208	139'-10"	26.12	8	10.663	Sprinkler,	5'-0"	Pe -2.831
1034	146'-4½"			9.743	PO(5'-0), fd	8'-11½"	Pv



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
BL	2.1570	26.12	2.29	120	0.006372	9'-7"	Pf 0.061
1034	146'-4½"			9.743			Pe
1032	146'-4½"			9.804		9'-7"	Pv
BL	2.1570	52.31	4.59	120	0.023024	8'-10"	Pf 0.204
1032	146'-4½"	26.19		9.804	Flow (q) from Route 3		Pe
1030	146'-4½"			10.008		8'-10"	Pv
BL	2.6350	52.31	3.08	120	0.008686	0'-6"	Pf 0.004
1030	146'-4½"			10.008			Pe
1031	146'-4½"			10.012		0'-6"	Pv
BL	2.6350	78.71	4.63	120	0.018499	7'-0½"	Pf 0.435
1031	146'-4½"	26.40		10.012	Flow (q) from Route 6	16'-5½"	Pe
1027	146'-4½"			10.447	PO(16'-5½")	23'-6"	Pv
CM	3.2600	105.46	4.05	120	0.011273	7'-2½"	Pf 0.081
1027	146'-4½"	26.75		10.447	Flow (q) from Route 8		Pe
1024	146'-4½"			10.528		7'-2½"	Pv
CM	4.2600	105.46	2.37	120	0.003063	2'-8½"	Pf 0.008
1024	146'-4½"			10.528			Pe
1023	146'-4½"			10.536		2'-8½"	Pv
<b>Route 3</b>							
BL	1.0490	26.19	9.72	120	0.214260	3'-11½"	Pf 1.919
10206	139'-10"	26.19	8	10.715	Sprinkler,	5'-0"	Pe -2.831
1032	146'-4½"			9.804	PO(5'-0), fd	8'-11½"	Pv
<b>Route 4</b>							
BL	1.0490	26.23	9.74	120	0.214849	4'-0"	Pf 1.934
10201	139'-10"	26.23	8	10.747	Sprinkler,	5'-0"	Pe -2.831
1028	146'-4½"			9.850	PO(5'-0), fd	9'-0"	Pv
<b>Route 5</b>							
BL	1.0490	26.27	9.75	120	0.215519	6'-4½"	Pf 2.452
10205	139'-10"	26.27	8	10.783	Sprinkler,	5'-0"	Pe -2.831
1025	146'-4½"			10.404	PO(5'-0), fd	11'-4½"	Pv
BL	2.1570	26.27	2.31	120	0.006439	25'-7"	Pf 0.244
1025	146'-4½"			10.404		12'-3½"	Pe -0.014
1020	146'-4½"			10.634	PO(12'-3½")	37'-10½"	Pv
<b>Route 6</b>							
BL	1.0490	26.40	9.80	120	0.217562	3'-11½"	Pf 1.949
10204	139'-10"	26.40	8	10.894	Sprinkler,	5'-0"	Pe -2.831
1031	146'-4½"			10.012	PO(5'-0), fd	8'-11½"	Pv
<b>Route 7</b>							
BL	1.0490	26.50	9.84	120	0.218958	3'-9½"	Pf 1.928
10202	139'-10"	26.50	8	10.969	Sprinkler,	5'-0"	Pe -2.832
1022	146'-4½"			10.065	PO(5'-0), fd	8'-9½"	Pv
<b>Route 8</b>							
BL	1.0490	26.75	9.93	120	0.222856	3'-11½"	Pf 1.996
10203	139'-10"	26.75	8	11.181	Sprinkler,	5'-0"	Pe -2.831
1029	146'-4½"			10.346	PO(5'-0), fd	8'-11½"	Pv
BL	2.1570	26.75	2.35	120	0.006658	2'-9½"	Pf 0.100
1029	146'-4½"			10.346		12'-3½"	Pe
1027	146'-4½"			10.447	PO(12'-3½")	15'-1"	Pv
<b>Route 9</b>							
BL	1.0490	26.84	9.96	120	0.224228	4'-0"	Pf 2.018
10200	139'-10"	26.84	8	11.255	Sprinkler,	5'-0"	Pe -2.831
1021	146'-4½"			10.443	PO(5'-0), fd	9'-0"	Pv
BL	2.1570	26.84	2.36	120	0.006699	1'-8½"	Pf 0.094
1021	146'-4½"			10.443		12'-3½"	Pe -0.000
1023	146'-4½"			10.536	PO(12'-3½")	14'-0"	Pv
<b>Route 10</b>							
CM	4.2600	55.17	1.24	120	0.000924	11'-9½"	Pf 0.011
928	144'-9"	70.12		12.466	Flow (q) from Route 14		Pe
926	144'-9"			12.477		11'-9½"	Pv
CM	4.2600	39.06	0.88	120	0.000488	9'-10½"	Pf 0.005
926	144'-9"			12.477			Pe
927	144'-9"			12.482		9'-10½"	Pv
CM	4.2600	21.59	0.49	120	0.000163	9'-6½"	Pf 0.002
927	144'-9"			12.482			Pe
925	144'-9"			12.483		9'-6½"	Pv
BL	2.1570	21.59	1.90	120	0.004477	186'-10½"	Pf 0.947
925	144'-9"			12.483	PO(12'-3½")	24'-7½"	Pe
901	144'-9"			13.430	PO(12'-3½")	211'-6"	Pv



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group II (10)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
<b>Route 11</b>							
BL	2.1570	16.11	1.41	120	0.002606	200'-8½"	<b>Pf</b> 0.715
926	144'-9"			12.477	PO(12'-3½")	73'-10"	<b>Pe</b> -0.000
903	144'-9"			13.192	8E(6'-2), PO(12'-3½")	274'-7"	<b>Pv</b>
<b>Route 12</b>							
BL	2.1570	14.95	1.31	120	0.002269	194'-10"	<b>Pf</b> 0.666
928	144'-9"	70.12		12.466	PO(12'-3½"), Flow (q) from Route	98'-5½"	<b>Pe</b>
904	144'-9"			13.132	14 10E(6'-2), T(12'-3½"), PO(12'-3½")	293'-3½"	<b>Pv</b>
<b>Route 13</b>							
BL	2.1570	17.47	1.53	120	0.003028	202'-11"	<b>Pf</b> 0.801
927	144'-9"			12.482	PO(12'-3½")	61'-6½"	<b>Pe</b>
902	144'-9"			13.282	6E(6'-2), PO(12'-3½")	264'-5½"	<b>Pv</b>
<b>Route 14</b>							
CM	4.2600	70.12	1.58	120	0.001440	159'-3½"	<b>Pf</b> 0.343
1019	145'-8"	167.18		11.726	Flow (q) from Route 1	79'-0"	<b>Pe</b> 0.397
928	144'-9"			12.466	6E(13'-2)	238'-3½"	<b>Pv</b>

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

### C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LiE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PRV	Pressure Reducing Valve
PrV	Pressure Relief Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap





# Hydraulic Overview

Job Number: 22-3688  
Report Description: Ordinary Group I (12)

<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	State Certification/License Number
Address 2 Puyallup, WA 98374	AHJ CITY OF PUYALLUP
Address 3	Job Site/Building PIERCE COLLEGE PUYALLUP



<b>System</b>	
Density 0.15 gpm/ft <sup>2</sup>	Area of Application 418 ft <sup>2</sup> (Actual 418 ft <sup>2</sup> )
Most Demanding Sprinkler Data 2.8 K-Factor 7.41 at 7.000	Hose Streams 250.00
Coverage Per Sprinkler 112 ft <sup>2</sup>	Number Of Sprinklers Calculated 4
	Number Of Nozzles Calculated 0
System Pressure Demand 47.292	System Flow Demand 29.78
Total Demand 279.78 @ 47.292	Pressure Result +15.496 (24.7%)

<b>Supplies</b>					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	1950.00	250.00	64.000	20.000
FPET NICET #106245 LEVEL IV,MSME					
<div style="border: 2px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>Signature</i>      03/26/2024      <b>Expires</b> Signature      Date      12/31/24</p> </div>					

<b>Check Point Gauges</b>			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

22-3688\_PeirceSTEM-L04-Asbuilt


Supply at Node 1 (1950.00, 0.00, 64.000, 20.000)







### Supply at Node 1



Hydraulic Graph

#### Supply at Node 1

Static: Pressure  
64.000

Residual: Pressure Available Flow @ 20 PSI:  
20.000 @ 1950.00 0.00

Available Pressure at System Demand  
62.788 @ 279.78

Required Pressure at System Demand  
47.292 @ 29.78

Required Pressure at System Demand (Including Hose Allowance at Source)  
47.292 @ 279.78



# Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 11000	7.45	7.41	2.8	7.074			
Sprinkler 11001	7.51	7.41	2.8	7.196			
Sprinkler 11002	7.42	7.41	2.8	7.016			
<b>⇒ Sprinkler 11003</b>	<b>7.41</b>	<b>7.41</b>	<b>2.8</b>	<b>7.000</b>			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: Ordinary Group I (12)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	84'-6½	S	47.292	29.78
11000	156'-10	Spr(-7.074)	7.074	7.45
11001	156'-10	Spr(-7.196)	7.196	7.51
11002	156'-10	Spr(-7.016)	7.016	7.42
11003	156'-10	Spr(-7.000)	7.000	7.41
2	84'-6½	PIV(-2.000)	47.290	
3	84'-6½	BFP(-0.016)	45.290	
6	84'-6½	PO(20'-0)	45.274	
7	90'-9		42.581	
8	91'-4½	St(-0.002)	42.310	
9	102'-6½	PO(20'-2)	37.470	
788	144'-9	T(12'-3½)	12.848	
801	101'-6	T(14'-4½)	37.470	
802	111'-0	E(6'-8½)	37.470	
803	111'-6½	E(6'-8½)	37.470	
900	144'-9	E(13'-2)	13.166	
901	144'-9	PO(12'-3½)	13.148	
902	144'-9	PO(12'-3½)	13.145	
903	144'-9	PO(12'-3½)	13.143	
904	144'-9	PO(12'-3½)	13.143	
925	144'-9	PO(12'-3½)	13.127	
926	144'-9	PO(12'-3½)	13.127	
927	144'-9	PO(12'-3½)	13.127	
928	144'-9	PO(12'-3½)	13.127	
1100	156'-10	E(4'-11½)	7.406	



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group I (12)

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
<b>Route 1</b>								
BL	1.6820	7.41	1.07	120		0.002079	7'-8½"	Pf 0.016
11003	156'-10"	7.41	2.8	7.000		Sprinkler		Pe 0.000
11002	156'-10"			7.016			7'-8½"	Pv
BL	1.6820	14.82	2.14	120		0.007502	7'-8"	Pf 0.058
11002	156'-10"	7.42	2.8	7.016		Sprinkler		Pe 0.000
11000	156'-10"			7.074			7'-8"	Pv
BL	1.6820	22.27	3.22	120		0.015930	7'-8½"	Pf 0.123
11000	156'-10"	7.45	2.8	7.074		Sprinkler		Pe 0.000
11001	156'-10"			7.196			7'-8½"	Pv
BL	1.6820	29.78	4.30	120		0.027272	2'-9"	Pf 0.209
11001	156'-10"	7.51	2.8	7.196		Sprinkler,	4'-11½"	Pe 0.000
1100	156'-10"			7.406		E(4'-11½")	7'-8"	Pv
BL	2.1570	29.78	2.61	120		0.008122	12'-1"	Pf 0.198
1100	156'-10"			7.406			12'-3½"	Pe 5.244
788	144'-9"			12.848		T(12'-3½")	24'-5"	Pv
BL	2.1570	12.54	1.10	120		0.001638	118'-8½"	Pf 0.295
788	144'-9"			12.848			61'-6½"	Pe -0.000
903	144'-9"			13.143		8E(6'-2), PO(12'-3½")	180'-3"	Pv
CM	4.2600	24.72	0.56	120		0.000209	9'-2"	Pf 0.002
903	144'-9"	12.19		13.143		Flow (q) from Route 2		Pe
902	144'-9"			13.145			9'-2"	Pv
CM	4.2600	26.99	0.61	120		0.000246	12'-10"	Pf 0.003
902	144'-9"	2.27		13.145		Flow (q) from Route 6		Pe
901	144'-9"			13.148			12'-10"	Pv
CM	4.2600	29.78	0.67	120		0.000295	32'-4½"	Pf 0.017
901	144'-9"	2.79		13.148		Flow (q) from Route 3	26'-4"	Pe
900	144'-9"			13.166		2E(13'-2)	58'-8½"	Pv
FR	6.3570	29.78	0.30	120		0.000042	103'-5½"	Pf 6.010
900	144'-9"			13.166			125'-4½"	Pe 18.295
9	102'-6½"			37.470		4E(17'-7), sCV(-6.000), sCV(17'-2½), PO(37'-8½")	228'-9½"	Pv
CM	6.3570	29.78	0.30	120		0.000042	20'-5"	Pf 0.004
9	102'-6½"			37.470			30'-2"	Pe 4.836
8	91'-4½"			42.310		BV(12'-7), E(17'-7), St(-0.002)	50'-7"	Pv
DY	6.3400	29.78	0.30	140		0.000032	0'-0"	Pf 0.000
8	91'-4½"			42.310				Pe 0.271
7	90'-9"			42.581			0'-0"	Pv
UG	6.3400	29.78	0.30	140		0.000032	86'-3½"	Pf 0.005
7	90'-9"			42.581			69'-4"	Pe 2.688
6	84'-6½"			45.274		3E(23'-1½")	155'-7½"	Pv
UG	6.3400	29.78	0.30	140		0.000032	4'-1½"	Pf 0.017
6	84'-6½"			45.274				Pe
3	84'-6½"			45.290		BFP(-0.016)	4'-1½"	Pv
UG	6.3400	29.78	0.30	140		0.000032	11'-2½"	Pf 2.000
3	84'-6½"			45.290				Pe
2	84'-6½"			47.290		PIV(-2.000)	11'-2½"	Pv
UG	6.3400	29.78	0.30	140		0.000032	21'-7"	Pf 0.002
2	84'-6½"			47.290			34'-8"	Pe
1	84'-6½"			47.292		E(23'-1½), EE(11'-6½), S	56'-3"	Pv
		250.00				Hose Allowance At Source		
1		279.78						
<b>Route 2</b>								
CM	4.2600	12.19	0.27	120		0.000057	7'-2½"	Pf 0.000
904	144'-9"	10.23 + 1.96		13.143		Flow (q) from Route 4 and 5		Pe
903	144'-9"			13.143			7'-2½"	Pv
<b>Route 3</b>								
CM	4.2600	5.06	0.11	120		0.000011	9'-10½"	Pf 0.000
926	144'-9"			13.127				Pe
927	144'-9"			13.127			9'-10½"	Pv
CM	4.2600	2.79	0.06	120		0.000004	9'-6½"	Pf 0.000
927	144'-9"			13.127				Pe
925	144'-9"			13.127			9'-6½"	Pv
BL	2.1570	2.79	0.24	120		0.000102	186'-10½"	Pf 0.021
925	144'-9"			13.127		PO(12'-3½")	24'-7½"	Pe
901	144'-9"			13.148		PO(12'-3½")	211'-6"	Pv
<b>Route 4</b>								



# Hydraulic Analysis

Job Number: 22-3688  
Report Description: Ordinary Group I (12)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	2.1570	17.25	1.51	120	0.002956	82'-0	Pf 0.279
788	144'-9	12.54		12.848	Flow (q) from Route 1	12'-3½	Pe
926	144'-9			13.127	PO(12'-3½)	94'-3½	Pv
CM	4.2600	12.19	0.27	120	0.000057	11'-9½	Pf 0.001
926	144'-9	5.06		13.127	Flow (q) from Route 3		Pe
928	144'-9			13.127		11'-9½	Pv
CM	4.2600	10.23	0.23	120	0.000041	244'-4½	Pf 0.015
928	144'-9			13.127		134'-3½	Pe 0.000
904	144'-9			13.143	9E(13'-2), 2EE(5'-3), Ee2(5'-3)	378'-8	Pv
<b>Route 5</b>							
BL	2.1570	1.96	0.17	120	0.000053	194'-10	Pf 0.015
928	144'-9			13.127	PO(12'-3½)	98'-5½	Pe
904	144'-9			13.143	10E(6'-2), T(12'-3½), PO(12'-3½)	293'-3½	Pv
<b>Route 6</b>							
BL	2.1570	2.27	0.20	120	0.000069	202'-11	Pf 0.018
927	144'-9			13.127	PO(12'-3½)	61'-6½	Pe
902	144'-9			13.145	6E(6'-2), PO(12'-3½)	264'-5½	Pv

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

### C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap







<b>Job</b>	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	Phone 425.204.3945
Address 1 1601 39th AVE SE	FAX
Address 2 Puyallup, WA 98374	State Certification/License Number
Address 3	AHJ CITY OF PUYALLUP
	Job Site/Building PIERCE COLLEGE PUYALLUP

<b>System</b>	
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1340 ft <sup>2</sup> )
Most Demanding Sprinkler Data K-Factor at	Hose Streams 750.00
Coverage Per Sprinkler 130 ft <sup>2</sup>	Number Of Sprinklers Calculated 0
	Number Of Nozzles Calculated 0
System Pressure Demand 157.569	System Flow Demand 750.00
Total Demand 750.00 @ 157.569	Pressure Result +0.431 (0.3%)

<b>Supplies</b>					<b>Check Point Gauges</b>				
<u>Node</u>	<u>Name</u>	<u>Flow(gpm)</u>	<u>Hose Flow(gpm)</u>	<u>Static(psi)</u>	<u>Residual(psi)</u>	<u>Identifier</u>	<u>Pressure(psi)</u>	<u>K-Factor(K)</u>	<u>Flow(gpm)</u>
4	Water Supply	750.00		158.000	158.000				
<p>FPET NICET #106245 LEVEL IV,MSME</p> <div style="border: 1px dashed black; padding: 5px;"> <p align="center"><b>WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE PROTECTION SPRINKLER SYSTEMS</b></p> <p>Hussein A. A. Huballa 8321-1119-C Level 3 Shinn Mechanical, Inc. SHINNMI060QP</p> <p><i>Signature</i>      03/26/2024      Expires 12/31/24</p> </div>									

22-3688\_PeirceSTEM-L10-R041-Standpipe      Water Supply at Node 4 (750.00, 0.00, 158.000, 158.000)





# Hydraulic Summary

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Job	
Job Number 22-3688	Designer Ben Bernard
Job Name: PIERCE COLLEGE PUYALLUP NEW STEM BUILDING	State Certification/License Number
Address 1 1601 39th AVE SE	AHJ CITY OF PUYALLUP
Address 2 Puyallup, WA 98374	Job Site/Building PIERCE COLLEGE PUYALLUP
Address 3	Drawing Name 22-3688_PeirceSTEM-L10-R041-Standpipe

System	Remote Area(s)									
Most Demanding Sprinkler Data K-Factor at	Occupancy ROOF TOP HOSE FLOW	Job Suffix								
Hose Allowance At Source 0.00	Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 1340 ft <sup>2</sup> )								
Additional Hose Supplies	Number Of Sprinklers Calculated 0	Number Of Nozzles Calculated 0								
<table border="1"> <thead> <tr> <th>Node</th> <th>Flow(gpm)</th> </tr> </thead> <tbody> <tr> <td>Hose At Node 17</td> <td>250.00</td> </tr> <tr> <td>Hose At Node 19</td> <td>250.00</td> </tr> <tr> <td>Hose At Node 15</td> <td>250.00</td> </tr> </tbody> </table>	Node	Flow(gpm)	Hose At Node 17	250.00	Hose At Node 19	250.00	Hose At Node 15	250.00	Coverage Per Sprinkler 130 ft <sup>2</sup>	
Node	Flow(gpm)									
Hose At Node 17	250.00									
Hose At Node 19	250.00									
Hose At Node 15	250.00									
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area										
Total Hose Streams 750.00										
System Flow Demand 750.00	Total Water Required (Including Hose Allowance) 750.00									
Maximum Pressure Unbalance In Loops 0.000										
Maximum Velocity Above Ground 18.90 between nodes 4 and 6										
Maximum Velocity Under Ground 7.62 between nodes 6 and 7										
Volume capacity of Wet Pipes 899.33 gal	Volume capacity of Dry Pipes									

### Supplies


Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
4	Water Supply		158.000	158.000	750.00	158.000	750.00	157.569	0.431

### Contractor

Contractor Number 01	Contact Name Ben Bernard	Contact Title Engineer/PM
Name of Contractor: SHINN FIRE PROTECTION	Phone 425-204-3945	Extension
Address 1 18802 80TH AVE S	FAX	
Address 2 KENT WA98032	E-mail	
Address 3	Web-Site	



### Water Supply at Node 4



Hydraulic Graph

#### Water Supply at Node 4

Static: Pressure  
158.000

Residual: Pressure 158.000 @ 750.00 Available Flow @ 20 PSI: inf

Available Pressure at System Demand  
158.000 @ 750.00

Required Pressure at System Demand  
157.569 @ 750.00

Required Pressure at System Demand (Including Hose Allowance at Source)  
157.569 @ 750.00



# Summary Of Outflowing Devices

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Hose	15	250.00	250.00	28.87	101.709			
Hose	17	250.00	250.00	28.87	75.211			
Hose	19	250.00	250.00	28.87	74.987			

⇒ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
4	-21'-0	S	157.569	750.00
15	22'-10	Hose(-74.987)(31'-0)	101.709	250.00
17	42'-10	Hose(-74.987)(31'-0)	75.211	250.00
19	43'-4	Hose(-74.987)(31'-0)	74.987	250.00
6	-25'-0	PO(49'-6)	151.515	
7	-18'-2½		146.003	
8	-16'-2	St(-1.691)	145.080	
9	-7'-5½	PO(20'-2)	139.021	
12	1'-3½		130.027	
13	-0'-3½	T(26'-4)	124.435	
14	22'-10	PO(12'-0), f(-0.000)	110.971	
16	42'-10	PO(12'-0)	84.474	



# Hydraulic Analysis

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
<b>Route 1</b>							
DY	2.4690	250.00	16.75	120	0.215409	0'-0"	Pf 9.263
19	43'-4"	250.00		74.987	Hose(-74.987)(31'-0)	43'-0"	Pe
18	43'-4"			84.250	PO(12'-0)	43'-0"	Pv
FR	4.2600	250.00	5.63	120	0.015122	0'-6"	Pf 0.008
18	43'-4"			84.250			Pe 0.217
16	42'-10"			84.474		0'-6"	Pv
FR	4.2600	500.00	11.25	120	0.054516	216'-6"	Pf 21.279
16	42'-10"	250.00		84.474	Flow (q) from Route 2	173'-9½"	Pe 18.682
13	-0'-3½"			124.435	7E(13'-2), PIV(2'-7½), 2T(26'-4), BV(15'-9½), 2EE(5'-3)	390'-4"	Pv
ST	4.2600	750.00	16.88	120	0.115423	28'-1"	Pf 6.279
13	-0'-3½"	250.00		124.435	Flow (q) from Route 3	26'-4"	Pe -0.687
12	1'-3½"			130.027	2E(13'-2)	54'-5"	Pv
CM	6.3570	750.00	7.58	120	0.016432	30'-4½"	Pf 5.193
12	1'-3½"			130.027		103'-1"	Pe 3.801
9	-7'-5½"			139.021	3E(17'-7), f(-3.000), BV(12'-7), PO(37'-8½)	133'-5½"	Pv
CM	6.3570	750.00	7.58	120	0.016432	18'-5"	Pf 2.282
9	-7'-5½"			139.021		17'-7"	Pe 3.777
8	-16'-2"			145.080	E(17'-7), St(-1.691)	36'-0"	Pv
CM	6.3570	750.00	7.58	120	0.016432	2'-0½"	Pf 0.034
8	-16'-2"			145.080			Pe 0.889
7	-18'-2½"			146.003		2'-0½"	Pv
UG	6.3400	750.00	7.62	140	0.012517	86'-10½"	Pf 2.575
7	-18'-2½"			146.003		118'-10"	Pe 2.937
6	-25'-0"			151.515	3E(23'-1½), PO(49'-6)	205'-8½"	Pv
BL	4.0260	750.00	18.90	120	0.151978	31'-3"	Pf 7.788
6	-25'-0"			151.515		20'-0"	Pe -1.734
4	-21'-0"			157.569	2E(10'-0), S	51'-3"	Pv
		0.00			Hose Allowance At Source		
4		750.00					
<b>Route 2</b>							
DY	2.4690	250.00	16.75	120	0.215409	0'-0"	Pf 9.263
17	42'-10"	250.00		75.211	Hose(-74.987)(31'-0)	43'-0"	Pe
16	42'-10"			84.474	PO(12'-0)	43'-0"	Pv
<b>Route 3</b>							
DY	2.4690	250.00	16.75	120	0.215409	0'-0"	Pf 9.263
15	22'-10"	250.00		101.709	Hose(-74.987)(31'-0)	43'-0"	Pe
14	22'-10"			110.971	PO(12'-0), f(-0.000)	43'-0"	Pv
FR	4.2600	250.00	5.63	120	0.015122	67'-1"	Pf 3.444
14	22'-10"			110.971		160'-7½"	Pe 10.020
13	-0'-3½"			124.435	7E(13'-2), 2T(26'-4), BV(15'-9½)	227'-8½"	Pv

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

### C Value Multiplier

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 22-3688

Report Description: ROOF TOP HOSE FLOW (ROOF TOP HOSE FLOW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SN	Swing Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PrV	Pressure Relief Valve
PRV	Pressure Reducing Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
SFx	Seismic Flex
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap