

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Permit Review Correction Letter Permit Application #PRFUP20240492

April 11, 2024

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the City's permit portal. Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and resubmittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.


Re-submittal Instructions

To resubmit, you must address all comments and upload a Correction Response Letter that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.



Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.

Por each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.



Corrections

Corrections to be addressed on the next set of resubmitted plans:

	Yianni Charitou	(253)435-3612	YCharitou@PuyallupWA.gov
Undate description of work	to match permit application	description and work r	proposed on other sheets. [SITE PLAN,
sheet 1 of 4]			
			roadways and not public right-of-way permit holder shall be responsible to
3 3 1	•		tional agencies prior to starting work.
51			ng conditions. [SITE PLAN, sheet 3 of
4]			
		51	er traveling through new or existing ditional callouts. [SITE PLAN, sheet 4 o
4]	materi the legend symbols o	inspect 2 of provide add	
e 1 j	•		ould not extend farther west as
•	ymbol or add a callout that v	vork to continue under	separate permit. [SITE PLAN, sheet 4
of 4] · Label 15TH AVE SE. [SITE P	IAN sheet 4 of 4]		
5TH ST SE north of 15TH A authorize or permit work on permissions or permits from	/E SE is a private roadway an private property. The permi all property owners or juriso	t holder shall be respon dictional agencies prior f	y. The City of Puyallup does not sible to obtain the necessary to starting work. Revise the right-of-
way and property lines accou	dingly to accurately reflect e	existing conditions. [SIT	E PLAN, sheet 4 of 4]

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the City's permit portal.

Condition	Condition	Department	Condition
Category			Status

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center (253) 864-4165 option 1 permitcenter@puyallupwa.gov