



*Fire Sprinklers Save Lives!*

2707 70TH Avenue East  
Tacoma, WA 98424

TEL: (253) 926.2290  
FAX: (253) 922.6150

April 12, 2024

To: Puyallup Fire Department  
311 W Pioneer  
Puyallup, WA 98371

Re: Red Dot Climate Control Room  
2504 East Main  
Puyallup, WA 98372

To whom it may concern,

The sprinkler modifications for the Red Dot Climate Control RM do not change the hydraulic characteristics of the existing sprinkler system. This project consists of adding sprinklers for TI wall and ceiling changes.

Please feel free to call with any questions.

Sincerely,  
PATRIOT FIRE PROTECTION, INC.

Mathew Greene  
Service Project Manager

VANCOUVER, WA OFFICE  
TEL (360) 699.4403  
PORTLAND (503) 222.6001  
FAX (360) 699.4485

[www.patriotfire.com](http://www.patriotfire.com)  
**PATRIFFP099CF**

SPOKANE, WA OFFICE  
TEL (509) 926.3428  
FAX (509) 926.3708