



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20240334

FIRE ALARMS

Puyallup, WA

Job Address	Address: 4002 10TH ST SE, PUYALLUP, WA 98374 Parcel # 4389000181	ISSUED April 16, 2024
Owner		
Applicant Sheila Wilkinson 11409 58th Ave E Puyallup, WA 98373 sheilaw@linxnw.com		
Contractor LINX INTEGRATED 11409 58TH AVE EAST PUYALLUP, WA 98373 WA L&I #:		
Description of Work Installation of fire alarm system - COPPERBERRY NORTH		
Permit Types	Fire Alarms	
Expiration Date: October 13, 2024		
Total ESU's		

Building Components:

Quantity	Units	Description
54	DEVICES	Fire Alarm and Detection System and Related Equipment, New
		Total Value of Work: \$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Total coverage is required, subject to field inspection. Comply with NFPA 72.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - The requirements for Total Coverage on this building are the following.
 - a. 100% complete monitoring of Fire Sprinkler System
 - b. Smoke Detector in Riser Room
 - c. Exterior Fire Bell outside of Riser Room

- d. Pull Stations at Main Entry's
- e. Heat Detectors spaced accordingly throughout attic
- f. Heat detection in garages
- g. Shared tenant spaces will require smoke detection
- h. Horns and strobes are required
 - Pre-test shall be conducted with a printout for inspector at time of inspection.
 - Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
 - The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
 - Due to unforeseeable construction design, all device locations to be field verified for compliance.
 - The Buildings Fire Alarm system must meet The City of Puyallup's Municipal Code Total Coverage NPFA 72 and U.L. Certification. The sleeping units are required to be local only with two choices. They can be part of the system but must report as a supervisory (will not dispatch). Or they can be Standard 120V smoke alarms in sleeping/dwelling units. CO detection must comply with IBC and WAC requirements. Installation for local must comply with IBC section 907 requirements. Comply with ADA requirements where required.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Sheila Wilkinson