



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20240641

FIRE ALARMS

Puyallup, WA

Job Address	Address: 2315 INTER AVE, PUYALLUP, WA 98372 Parcel # 2105200140	ISSUED April 18, 2024
Owner	VELASQUEZ RICK & ELLEN RAEANN 2315 INTER AVE PUYALLUP, WA 98374-4510	
Applicant	ADT Commercial LLC 21312 30th Drive SE, Suite 103 Bothell, WA 98021 (425) 219-3232 Rh_bothellpermits@adt.com	
Contractor	ADT COMMERCIAL FORMALLY RED HAWK FIRE 21312 30TH DR SE, STE. BOTHELL, WA 98021 NWCOMMPERMITS@ADT.COM WA L&I #:	
Description of Work	ADT COMMERCIAL/ EVERON TO INSTALL A NEW FIRE ALARM SYSTEM WITH 42 DEVICES TOTAL.	
Permit Types	Fire Alarms	
Expiration Date:	October 15, 2024	
Total ESU's		

Building Components:

Quantity	Units	Description
42	DEVICES	Fire Alarm and Detection System and Related Equipment, New
		Total Value of Work: \$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Exterior fire bell required outside fire sprinkler room.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - Pre-test shall be conducted with a printout for inspector at time of inspection.
 - Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
 - Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
ADT Commercial LLC