



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRCTI20240275

COMMERCIAL - TENANT IMPROVEMENT/REMODEL

Puyallup, WA

| | | |
|----------------------------|--|---------------------------------|
| Job Address | Address: 1023 39TH AVE SE, PUYALLUP, WA 98374 Parcel # 0419034037 | ISSUED April 23, 2024 |
| Owner | BCC PUYALLUP LLC 9675 SE 36TH ST STE 115 MERCER ISLAND, WA 98188 | |
| Applicant | Leonard Ruff 6210 36th Ave. NE Seattle, WA 98115 (206) 294-1288 leonard.ruff@casca demissioncritical.com | |
| Contractor | HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109 WA L&I #: | |
| Description of Work | Installation of foundations and steel supports for exterior chiller piping and electrical conduit, as well as installation of fluid coolers, air cooled chillers, pumps and miscellaneous mechanical equipment - CENTERIS VOLTAGE PARK | |
| Permit Types | Commercial - Tenant Improvement/Remodel | |
| Expiration Date: | October 20, 2024 | |
| Total ESU's | | |

Building Components:

| Quantity | Units | Description |
|----------|-------|--|
| 500 | SQ FT | Commercial Tenant Improvement/Remodel |
| 4 | QTY | SDC - Commercial/Industrial Plumbing Fixtures (sewer) |
| 3.5 | QTY | SDC - Commercial/Industrial Plumbing Fixtures (water) |
| 2 | QTY | Boilers & Compressors/Heat Pumps, over 1,000,001 or over 50 HP |
| 3 | QTY | Air Handlers (Up to 10,000 cfm) |
| 2 | QTY | Evaporative Coolers |
| 1 | QTY | Sump, Sewage, or Ejector Pumps |
| | | Total Value of Work: |
| | | \$0.00 |

Standard Conditions:

1. * Final approval by the Building Official is required prior to use or occupancy.* Work shall not proceed until the inspector has approved the stages of construction.* Surface storm water shall be diverted from the building site and shall not drain onto

adjacent properties.* I hereby acknowledge that I have read this Permit/Application, that the information given is correct; that I am the owner or the duly authorized agent of the owner; that plans submitted herewith are in compliance with all applicable city, county and state laws and that all construction will proceed in accordance with said laws. This permit shall expire if work is not commenced with 180 days or if the work is suspended for a period of 180 days. Permits expire two years from issuance. * By leaving the contractor information section blank, I hereby certify further that contractors (general or subcontractors) will not be hired to perform any work in association with this permit. I also certify that if I do choose to hire a contractor (general or subcontractor) I will only hire those contractors that are licensed by the State of Washington. If you are a property owner, contractor or permittee and you are paying for someone to perform the work, they must have a valid contractor registration and the person(s) installing plumbing inside a structure must meet the plumbing certification requirements. If you have any questions regarding these regulations, you may contact the Washington State Department of Labor and Industries or you can find more information on-line at: <http://www.lni.wa.gov/TradesLicensing/Contractors/HireCon/default.asp>

2. 1. INSTALL ADDRESS NUMBERS PER THE FOLLOWING DISTANCES:0-50FOOT SETBACK FROM STREET NUMBERS SHALL BE 6 INCHES IN HEIGHT; 51-100 FEET 12 INCHES IN HEIGHT. ALL NUMBERS SHALL CONTRAST WITH THEIR BACKGROUND. ADDITIONAL NUMBERS MAY BE NEEDED AT DRIVEWAY ENTRANCE IF BUILDING NUMBERS ARE NOT VISIBLE FROM THE STREET. REAR DOORS OF SUITES OR UNITS SHALL ALSO BE LABELED WITH MINIMUM 4 INCH NUMBERS.
2. FIRE HYDRANTS REQUIRED FOR CONSTRUCTION AND FIRE DEPARTMENT ACCESS SHALL BE INSTALLED AND APPROVED BY THE FIRE CODE OFFICIAL PRIOR TO THE STORAGE OR INSTALLATION OF ANY COMBUSTIBLE FRAMING MATERIAL. ACCESS ROADWAY SURFACES SHALL BE DESIGNED TO CITY STANDARDS AND BE DESIGNED TO MAINTAIN THE IMPOSED LOADS OF A 80,000 POUND FIRE APPARATUS. ASPHALT TREATED BASE, ASPHALT OR CONCRETE PAVEMENT CAN BE USED TO PROVIDE THE REQUIRED ALL-WEATHER DRIVING SURFACE.
3. ANY REQUIRED FIRE LANE MARKINGS SHALL BE INSTALLED PRIOR TO FINAL INSPECTION AND PER CITY ORDINANCE.
4. KNOX BOXES, WHEN REQUIRED, SHALL BE INSTALLED USUALLY TO THE RIGHT OF THE MAIN FRONT DOOR AND NO HIGHER THAN 6 FEET OFF OF THE GROUND. ONLY HINGED KNOX BOXES SHALL BE USED. KNOX BOXES AND KEY SWITCHES CAN BE ORDERED ONLINE AT THE "KNOX COMPANY"
5. FIRE EXTINGUISHERS WILL BE REQUIRED PER CHAPTER 9 OF THE INTERNATIONAL FIRE CODE. GENERALLY, 1 FIRE EXTINGUISHER WITH A MINIMUM RATING OF 2A 10BC SHALL BE INSTALLED PER EVERY 3,000 SQUARE FEET OF FLOOR AREA. THE LOCATION OF THE FIRE EXTINGUISHERS SHALL BE NEAR THE EXIT DOORS AND TRAVEL DISTANCE TO AN EXTINGUISHER SHALL NOT EXCEED 75 FEET. ADDITIONAL SIGNAGE MAY BE NECESSARY TO INDICATE THE FIRE EXTINGUISHER LOCATION.

4. The subject property has been classified as a contaminated site by the Tacoma Pierce County Health Department (TPCHD) and must be remediated per Washington Administrative Code Title 173. It is the applicant's responsibility to coordinate cleanup with TPCHD. Visit <https://www.tpchd.org/healthy-places/contaminated-property-cleanup> for more information. The applicant shall request a remediation status report from TPCHD by emailing UST@tpchd.org. Provide a copy of the status report to the City.

5. Prior to starting construction, the contractor shall verify the location and design of the existing storm drain and proposed sanitary sewer line located underneath the proposed project footprint. The general contractor shall be responsible for protecting the utilities as designed under the approved PRCCP20240183 civil plans and maintaining utility separation from all other existing and proposed utilities prior to pouring the concrete pads and installing the footings. Any and all conflicts between the proposed project and and civil design shall be mitigated and corrected at the expense of the permit applicant and property owner. The City shall not be held responsible or liable for any conflicts that arise between the building and civil plans.

7. According to UPC Table 702.2(1), the proposed 2" trap serving the new chillers and coolers is equivalent to 4 drainage fixture units. Each sewer fixture unit is currently \$432.70 above the first 15 units. \$1,730.80 sewer system development charges were assessed for the sewer system that serves the new chillers and coolers. [Yianni Charitou @ 03/20/2024 4:12 PM]

According to footnote 2 of UPC Table 610.3, appliances appurtenances, or fixtures not referenced in this table shall be permitted to be sized by reference to fixtures having similar flow rate and frequency of use. For this project, the proposed 1.5" branch supplying the new coolers is sized like a private hose bibb which equals 2.5 water supply fixture units for the first hose bibb and 1 unit for each additional hose bibb. Each water supply fixture unit is currently \$355.90 above the first 15 units. Two hose bibbs are assumed to serve the coolers. \$1,245.65 water system development charges were assessed for the tank that supplies the new coolers. [Yianni Charitou @ 03/20/2024 4:12 PM]

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Leonard Ruff