



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 24, 2024

Inspection Result: PASSED

Permit Number: PRCTI20240555

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Door alteration, and modification of affected ductwork by removing a damper. - GOOD SAM, OBS DEPT.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: approved frame at new door opening in room - 2-E-041

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684