City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

	Date of Inspection:	Apr 25, 2024	Inspection Result:	PASSED
--	---------------------	--------------	--------------------	--------

Permit Number: PRCTI20231574

Property Address: 105 7TH ST SW, PUYALLUP, WA 98371;

Contractor: TBD < NO STREET ADDRESS> NEELEY CONSTRUCTION COMPANY 111

23RD ST SE PUYALLUP, WA 98372-4163

To construct: Small Tenant Improvements at PHS, BLDG -01. At existing third floor

existing chemistry classroom 3 new student lab stations will be added, along with a relocated fume hood and refrigerator from building-02. Existing third floor storage room near chemistry classroom will be converted to Science Prep room which includes relocated a fume hood,

small refrigerator, hazardous materials storage cabinets, science utility

sink, emergency eyewash, fire blanket, fire extinguisher, spill kits,

neutralized chemical barrel, and installing a new emergency shower. No exterior work is building done except roof penetrations for fume hood exhaust. The existing building is currently in use, connected to public water and sewer. Work planned to take place over winter break, after

contractor has been selected.

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the

following result of the inspection.	If there are any questions, please contact the inspector below.	
Comments:		
Corrections:		

Kevin Spruell

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590