

## CITY OF PUYALLUP **Development & Permitting Services** 333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit No: PRFS20240547

## FIRE SPRINKLERS

Puyallup, WA

Job Address	Address: 401 15TH AVE SE, PUYALLUP, WA 98372 Parcel # 9810000014	ISSUED April 29, 2024					
Owner MULTICARE HEALTH SYSTEM 14400 METCALF AVE OVERLAND PARK, KS 98415							
INIOCHICANE FILALITI STSTEINI 14400 INICTOALI AVE OVENEAIVOTANN, NO 70413							
Applicant Matthew Greene 2707 70th Ave E TACOMA, WA 98424 (253) 377-2272 mattg@patriotfire.com							
Contractor PATRIOT FIRE PROTECTION 2707 70TH AVE E TACOMA, WA 98424 WA L&I #:							
Description of Work							
Add and relocate sprinkler for TI wall and ceiling changes							
Permit Types	Fire Sprinklers						
Expiration Date: October 26, 2024							
Total ESU's							

**Building Components:** 

Quantity	Units	Description		
2	HEADS	Automatic Fire-Sprinkler System,		
		Alteration		
			Total Value of Work:	\$0.00

## **Standard Conditions:**

- 1. Provide plans and permit on site for inspection.
- Cover and final inspections are required.
- Fire watch is required when sprinkler system is out of service in existing buildings.
- Contractor required at all inspections.
- Hydro test will be required on all new and existing buildings. Appointment required.
- Hydro test, two inspections will be required 2hrs apart. Call to schedule times. Am/pm is not guaranteed without appointment.
- Fire pumps will be required to be tested and witnessed by inspector.
- Tool kit required at time of final.
- NFPA placards required.
- In existing buildings all upright fire sprinklers to remain, do not remove.
- In existing buildings all required service and maintenance to be updated prior to inspection.
- Due to unforeseeable construction design, all head locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

**Applicant**: Matthew Greene