



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 02, 2024

Inspection Result: **FAILED**

Permit Number: PRMH20240184

Property Address: 3500 S MERIDIAN., Unit: 494, Puyallup WA 98373

Contractor: HERMANSON 1221 2ND AVE N KENT, WA 98032

To construct: Replacement of (1) existing 10-ton RTU SOUTH HILL MALL (3500 S MERIDIAN, UNIT 494)

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. complete fasteners at curb attachment east and west side
2. provide service plug
3. complete nock out on north side of unit

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590