



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 04, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20240313

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA
98134 Sam Eastman 2500 Holgate St Tacoma, WA 98402

To construct: Alteration to an existing Urology/MMA clinic to create a soiled utility
room. - GOOD SAM MOB, 3RD FLOOR UROLOGY/MMA CLINIC

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. plumbing supply was live pressure at 45 PSI
2. waste approved at air test 5 PSI run test on fitting same room approved
3. perform run test on tie in of waste on floor below at time of final

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590