



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 07, 2024                      **Inspection Result:**     **FAILED**

**Permit Number:** PRPF20230347

**Property Address:** 2315 INTER AVE, PUYALLUP, WA 98372;

**Contractor:** WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406

**To construct:** Construct 4,987 SF pre-fabricated metal building warehouse; SEE PRMH20230349/MECH

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. framing and insulation was covered up without inspection
2. accessible route exceeds side slope requirements and has obstructions with in the route
3. not a complete list

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590