



CITY OF PUYALLUP  
**Development & Permitting Services**  
 333 S. Meridian, Puyallup, WA 98371  
 (253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Permit No:**  
PRFA20240566

## FIRE ALARMS

Puyallup, WA

<b>Job Address</b>	Address: 3601 9TH ST SW, PUYALLUP, WA 98373 Parcel # 6021590090	<b>ISSUED</b> May 03, 2024
<b>Owner</b>	CAFARO NORTHWEST PARTNERSHIP PO BOX 586 ANNANDALE, NJ 08801	
<b>Applicant</b>	Fire Protection Inc PO Box 12642 Mill Creek, WA 98082 (425) 290-9600 david@fpiseattle.com	
<b>Contractor</b>	FIRE PROTECTION INC 17410 ASH WAY STE #8 LYNNWOOD, WA 98037 WA L&I #:	
<b>Description of Work</b>	<p>NEW CONSTRUCTION OF A FULLY SPRINKLED (5) STORY WOOD FRAMED HOTEL. THE BUILDING WILL BE PROVIDED WITH A FULLY ADDRESSABLE FIRE ALARM SYSTEM WITH A REMOTE ANNUNICATOR LOCATED AT THE FRONT DESK. THE FIRE ALARM SYSTEM WILL PROVIDE TOTAL-COVERAGE DETECTION AS DEFINED IN 2019 NFPA-72 (17.5.3.1) AND PER CITY OF PUYALLUP'S REQUIREMENTS. THE FIRE ALARM SYSTEM WILL BE INTERFACED WITH THE (5) STOP ELEVATOR TO PROVIDE PHASE 1 ELEVATOR RECALL. THE FIRE ALARM SYSTEM SHALL MONITOR ALL FIRE ALARM INITIATING DEVICES, THE ERRCS / DAS SYSTEM (IF INSTALLED), ALL FIRE SPRINKLER FLOW DEVICES, AND FIRE SPRINKLER SUPERVISORY DEVICES. AUDIBLE AND VISIBLE OCCUPANT NOTIFICATION WILL BE PROVIDED THROUGHOUT ALL COMMON AREAS. TOTAL COVERAGE SMOKE DETECTION WILL BE PROVIDED THROUGHOUT THE BUILDING, INCLUDING ABOVE AND BELOW ALL SUSPENDED CEILINGS. SMOKE DETECTORS WITH 520Hz LOW FREQUENCY SOUNDER BASES WILL BE INSTALLED IN ALL HOTEL GUESTROOMS. FIRE ALARM VISIBLE OCCUPANT NOTIFICATION DEVICES SHALL BE PROVIDED IN GUESTROOMS WITH COMMUNICATION FEATURES PER ADAS 224.4 AND ACTIVATED BY THE ASSOCIATED GUESTROOM SMOKE DETECTORS AND/OR THE BUILDINGS FIRE ALARM SYSTEM. ACTIVATION OF THE GUESTROOM SMOKE DETECTORS WILL BE A LOCAL ONLY SUPERVISORY SIGNAL; IT WILL NOT DISPATCH THE FIRE DEPARTMENT. ACTIVATION OF THE FIRE ALARM SYSTEM SHALL ACTIVATE THE OUTDOOR HORN/STROBE, ALL AUDIBLE / VISUAL OCCUPANT NOTIFICATION DEVICES, ALL 520Hz LOW-FREQUENCY SMOKE DETECTOR SOUNDER BASES IN GUESTROOMS, RELEASE MAGNETICALLY HELD FIRE DOORS, AND CLOSE FIRE/SMOKE DAMPERS IN RATED WALLS. -          HOMEWOOD SUITES</p>	
<b>Permit Types</b>	Fire Alarms	
<b>Expiration Date:</b>	October 30, 2024	
<b>Total ESU's</b>		

**Building Components:**

Quantity	Units	Description
542	DEVICES	Fire Alarm and Detection System and Related Equipment, New

**Total Value of Work:** \$0.00

**Standard Conditions:**

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
  - Provide plans and permit on site for inspection.
  - Complete labor and industries inspections prior to requesting city inspection.
  - Exterior fire bell required outside fire sprinkler room.
  - Above ceiling detection is required.
  - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
  - Total coverage is required, subject to field inspection. Comply with NFPA 72.
  - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
  - Pre-test shall be conducted with a printout for inspector at time of inspection.
  - Labeling of all devices above and below ceiling required.
  - Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
  - RTU'S and smoke dampeners will be required to be tested during inspection.
  - The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
  - Due to unforeseeable construction design, all device locations to be field verified for compliance.
- Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

**I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.**

**Applicant:**  
Fire Protection Inc