



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 08, 2024                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCTI20240063

**Property Address:** 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;

**Contractor:** MARCO CONTRACTORS INC 100 COMMONWEALTH DR  
WARRENDALE, PA 15095

**To construct:** retail tenant improvement project, designated as Group M (Mercantile).  
Work to include but not limited to: Demolition of existing non-structural  
tenant improvements and storefront; New interior partition walls,  
ceilings, finishes; New storefront, new illuminated channel; New electrical  
distribution and lighting; Existing HVAC unit with new distribution as  
required; (1) one new restroom location using existing plumbing fixtures;  
(1) one new sink in Staff Room. - JD SPORTS UNIT #530

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 1 ; complete bottom track attachment as per city approved plans.
- 2 ; complete lateral bracing CR as per plans.
- 3 ; complete angle clips as per plans.
- 4 ; inspection of framing at sales floor only.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684