



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 09, 2024

Inspection Result: NOT READY

Permit Number: PRPF20230347

Property Address: 2315 INTER AVE, PUYALLUP, WA 98372;

Contractor: WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406

To construct: Construct 4,987 SF pre-fabricated metal building warehouse; SEE PRMH20230349/MECH

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. framing and insulation was covered up without inspection
2. accessible route exceeds side slope requirements and has obstructions with in the route
3. not a complete list
- 2 1. provide special inspection reports for framing as discussed with contractor
2. provide final letter fro EOR
3. provide air testing report
4. provide clarification on accessible route from architect

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590