



### Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

#### Project Information

1 Bed Int Unit - 3 Story Stack w/ Basement  
 Bradley Heights Apartments  
 Puyallup, WA

#### Contact Information

Milbrandt Architects  
 25 Central Way Suite 210  
 Kirkland, WA 98033 425.454.7130

Heating System Type:  All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

#### Design Temperature

Instructions

Design Temperature Difference ( $\Delta T$ ) 51  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

#### Area of Building

Instructions **Conditioned Floor Area** (sq ft)

Instructions **Average Ceiling Height** (ft)

Conditioned Volume 24,443

#### Glazing and Doors

Instructions

**U-Factor X Area = UA**  
 0.220  95.92

#### Skylights

Instructions

**U-Factor X Area = UA**  
 0.50  ---

#### Insulation

Instructions **Attic**

**U-Factor X Area = UA**  
 0.026  21.45

Instructions **Single Rafter or Joist Vaulted Ceilings**

**U-Factor X Area = UA**  
 ---  ---

Instructions **Above Grade Walls (see Figure 1)**

**U-Factor X Area = UA**  
 0.056  59.65

Instructions **Floors**

**U-Factor X Area = UA**  
 ---  ---

Instructions **Below Grade Walls (see Figure 1)**

**U-Factor X Area = UA**  
 0.042  9.94

Instructions **Slab Below Grade (see Figure 1)**

**F-Factor X Length = UA**  
 0.303  ---


Instructions **Slab on Grade (see Figure 1)**

**F-Factor X Length = UA**  
 0.540  384.48

#### Location of Ducts

Instructions

Duct Leakage Coefficient 1.10



<b>Sum of UA</b>	571.43
<b>Envelope Heat Load</b>	29,143 Btu / Hour
<i>Sum of UA x <math>\Delta T</math></i>	
<b>Air Leakage Heat Load</b>	13,463 Btu / Hour
<i>Volume x 0.6 x <math>\Delta T</math> x 0.018</i>	
<b>Building Design Heat Load</b>	42,606 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
<b>Building and Duct Heat Load</b>	46,867 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
<b>Maximum Heat Equipment Output</b>	58,583 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	

FULL SIZED LEDGIBLE COLOR REPORT IS REQUIRED TO BE PROVIDED BY THE PERMITTEE ON SITE FOR ALL INSPECTIONS