



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20240642

FIRE ALARMS

Puyallup, WA

Job Address	Address: 1023 39TH AVE SE, PUYALLUP, WA 983741019 39TH AVE SE, PUYALLUP, WA 98374 Parcel # 04190340360419034037	ISSUED May 10, 2024
Owner	BCC PUYALLUP LLC 9675 SE 36TH ST STE 115 MERCER ISLAND, WA 98188	
Applicant	Charity Powers 450, Shattuck Ave S Renton, WA 98057 (206) 258-0521 charity.powers@convergent.com	
Contractor	CONVERGINT TECHNOLOGIES, LLC 450 SHATTUCK AVE. S. RENTON, WA 98055 WA L&I #:	
Description of Work	New VESDA aspiration smoke detectors to support pre-action releasing for new battery and UPS rooms, as well as new detection for new exhaust fan walls. New VESDA tied into existing EST3 system supporting tenant/data hall equipment. This building has a house panel that performs notification and central station communications, as well as any initiating & emergency control devices associated with the building shell such as elevator recall. Changes to the house system are by others, under separate permit. - CENTERIS VOLTAGE PARK	
Permit Types	Fire Alarms	
Expiration Date:	November 06, 2024	
Total ESU's		

Building Components:

Quantity	Units	Description
54	DEVICES	Fire Alarm and Detection System and Related Equipment, New
		Total Value of Work: \$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Above ceiling detection is required.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Total coverage is required, subject to field inspection. Comply with NFPA 72.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The

system will need to be UL certified.

- Pre-test shall be conducted with a printout for inspector at time of inspection.
- Labeling of all devices above and below ceiling required.
- Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
- The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
- In existing buildings all above ceiling detection is to remain. Do not remove.
- Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Charity Powers