



JOB NUMBER: 105105530/ 104361565/3002634319

ADDRESS: 506 33RD ST SE PUYALLUP

PERMIT: Y
 EASEMENT: N
 OUTAGES: N
 LRC: 65
 SQ FT: 190
 PANEL: 200
 FLICKER: 2.3%
 V DROP: 0.7%

DESCRIPTION:
 P01: GRID # __568081-156498__
 HANG __25_ KVA, 120/240V OH XFMR OR6025.1000
 INST L/B C/O ON C/O BRACKET, FUSE @ __T
 INST STIRRUP TAP __ PHASE
 INST POLE GND (AS REQ'D)
 INST GRID# _____

P01-M01
 INST __1/0__ OH TPLX, ± __90__ '

PRFUP20240751

The applicant is responsible to notify the city of a job start 48 hours in advance using the CityView portal.

The permit and traffic control plans shall be posted at the job site and available to inspectors at all times.

**** Public notification shall comply with PMC Chapter 11.05.110 ****

City of Puyallup
 Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic