



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 14, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCTI20240063

Property Address: 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;

Contractor: MARCO CONTRACTORS INC 100 COMMONWEALTH DR
WARRENDALE, PA 15095

To construct: retail tenant improvement project, designated as Group M (Mercantile).
Work to include but not limited to: Demolition of existing non-structural
tenant improvements and storefront; New interior partition walls,
ceilings, finishes; New storefront, new illuminated channel; New electrical
distribution and lighting; Existing HVAC unit with new distribution as
required; (1) one new restroom location using existing plumbing fixtures;
(1) one new sink in Staff Room. - JD SPORTS UNIT #530

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. complete drywall fasteners as discussed with contractor
2. provide correct space at top of demising wall for deflection per city approved plans

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org