### City of Puyallup

#### **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

### INSPECTION REPORT

Date of Inspection: May 15, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCTI20240063

**Property Address:** 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;

**Contractor:** MARCO CONTRACTORS INC 100 COMMONWEALTH DR

WARRENDALE, PA 15095

**To construct:** retail tenant improvement project, designated as Group M (Mercantile).

Work to include but not limited to:Demolition of existing non-structural

tenant improvements and storefront; New interior partition walls,

ceilings, finishes; New storefront, new illuminated channel; New electrical distribution and lighting; Existing HVAC unit with new distribution as required; (1) one new restroom location using existing plumbing fixtures;

(1) one new sink in Staff Room. - JD SPORTS UNIT #530

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; drywall nailing complete at sales floor area only.( except at storefront)

### **Corrections:**

- 1 1; complete bottom track attachment as per city approved plans.
  - 2; complete lateral bracing CR as per plans.
  - 3; complete angle clips as per plans.
  - 4; inspection of framing at sales floor only.

Sincerely,



## City of Puyallup

# **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684