



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 20, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20221698

Property Address: 201 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

To construct: Remodel of existing office building to a medical/dental clinic - CHC
CANNERY * REVISION (1) - 1/26/2024 - CORRECT OCCUPANCY, FULL
RE-ROOF AND WALL ASSEMBLIES

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 2 floor
 1. zone one top out only both sides approved except where plumbing has not been tested
 2. zone 2 top out both sides approved except where plumbing has not been signed off and where noted in yellow high lighter on field drawings sheet A2.o1b
- 2 2ND FLOOR
 1. zone 3 top of wall top out only accept where plumbing has not been tested approved
- 3 2ND FLOOR inspection date 5/20/2024
 1. zones 1 and 2 exterior walls patches ok to insulate
 2. zone 4 provide detail from architect for rafter attachment at light monitor
 3. provide Fire cover approval for zone 4 ceiling at hard lids
 4. complete fire stop at ceiling in zone 4 as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590