



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 20, 2024                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; inspection of below slab plumbing test approved in room 239 only.

**Corrections:**

- 1    1 ; provide as built plumbing plan approval from mechanical engineer for changes to below slab plumbing.  
     2 ; test failed on below slab plumbing. ( no 10' head test at time of inspection)
- 2    1 ; provide as built plumbing plan approval from mechanical engineer for changes to below slab plumbing prior to below slab plumbing approval . (inspection of below slab plumbing only)
- 3    1 ; complete rough-in of water supply as discussed with contractor.  
     2 ; approved test on d.w.v.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684