



CITY OF PUYALLUP  
**Development & Permitting Services**  
 333 S. Meridian, Puyallup, WA 98371  
 (253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Permit No:**  
 PRFA20240802

## FIRE ALARMS

Puyallup, WA

<b>Job Address</b>	Address: 401 15TH AVE SE, PUYALLUP, WA 98372 Parcel # 9810000014	<b>ISSUED</b> May 21, 2024
<b>Owner</b>	MULTICARE HEALTH SYSTEM 14400 METCALF AVE OVERLAND PARK, KS 98415	
<b>Applicant</b>	Janet Stebbins 12781 GATEWAY DRIVE TUKWILA, WA 98168 (206) 291-1400 janet.stebbins@jci.com	
<b>Contractor</b>	JOHNSON CONTROLS FIRE PROTECTION 12781 GATEWAY DR TUKWILA, WA 98168 yvonne.thompson@jci.com WA L&I #:	
<b>Description of Work</b>	Modify existing Fire Alarm System: Emergency Department Fast Track Remodel. Remove existing devices and add new as shown on sheets FA-LEV1-W and FA-LEV1-E	
<b>Permit Types</b>	Fire Alarms	
<b>Expiration Date:</b>	November 17, 2024	
<b>Total ESU's</b>		

**Building Components:**

Quantity	Units	Description
13	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration
		<b>Total Value of Work:</b> \$0.00

**Standard Conditions:**

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
    - Provide plans and permit on site for inspection.
    - Complete labor and industries inspections prior to requesting city inspection.
    - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
    - Fire alarm system shall be placarded per NFPA 72.
    - Pre-test shall be conducted with a printout for inspector at time of inspection.
    - Due to unforeseeable construction design, all device locations to be field verified for compliance.
- Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date

and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

**I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.**

**Applicant:**  
Janet Stebbins