



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 23, 2024                      **Inspection Result:**     **NOT READY**

**Permit Number:** B-20-0180

**Property Address:** 3601 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND  
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

**To construct:** HOMEWOOD SUITES SOUTH HILL MALL MOTEL \*FEE DEFERRAL-SWR\*  
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD  
PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 3 1.complete shear in corridor on fifth floor
2. provide blocking at hangers as discussed with contractor
- 3.contractor to have moisture reading device at time of next inspection to verify acceptable levels of moisture before coving

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590