



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 23, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221698

Property Address: 201 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

To construct: Remodel of existing office building to a medical/dental clinic - CHC
CANNERY * REVISION (1) - 1/26/2024 - CORRECT OCCUPANCY, FULL
RE-ROOF AND WALL ASSEMBLIES

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.zone 4 NE CORNER OF first floor grid line c 1-4 DWV approved
2.supply approved at 100 psi
- 2 2ND FLOOR
1. supply zones 1,2 and part of zone 3 approved at 100 PSI as marked up on city approved plans PS 2.02
2. DWV approved zones 1,2 and part of zone 3 approved as marked up on city approved plans PS 2.02
- 3 2ND FLOOR
1.zone 3 room 206 dental flex DWF approved no supply
2.zone 4 80% of framing was not done at time of inspection DWV approved no supply
- 4 inspection date 5/22/2024
2ND FLOOR
1.zone 3 room 206 dental flex supply approved
2.zone 4 supply approved at 100 PSI

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590