



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 24, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20231574

Property Address: 105 7TH ST SW, PUYALLUP, WA 98371;

Contractor: FORTRESS BUILDERS, INC 4320 E 57TH AVE SPOKANE, WA 99223 (509) 897-7374
NEELEY CONSTRUCTION COMPANY 111 23RD ST SE PUYALLUP, WA 98372-4163

To construct: Small Tenant Improvements at PHS, BLDG -01. At existing third floor existing chemistry classroom 3 new student lab stations will be added, along with a relocated fume hood and refrigerator from building-02. Existing third floor storage room near chemistry classroom will be converted to Science Prep room which includes relocated a fume hood, small refrigerator, hazardous materials storage cabinets, science utility sink, emergency eyewash, fire blanket, fire extinguisher, spill kits, neutralized chemical barrel, and installing a new emergency shower. No exterior work is building done except roof penetrations for fume hood exhaust. The existing building is currently in use, connected to public water and sewer. Work planned to take place over winter break, after contractor has been selected.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. this was partial inspection for room 325
2. provide insulation at hot water lines at sinks as discussed with contractor

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590