City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 28, 2024 Inspection Result: FAILED

Permit Number: PRCCP20221569

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT

NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

To construct: Extend utilities from 10th street SE on a site for purposes of construction

2- 6 plexus as well as provide infiltration on site. COPPERBERRY

CONDOMINIUMS

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: North building garage slabs were poured.

Concrete trucks were washed out on the ground with no containment.

See corrections.

Corrections:

- All concrete washout needs to be contained. No concrete washout on the ground without containment.
 - Maintain frontage cleanliness. (Gutter pan, road way, sidewalk, etc...)
 - Maintain construction entrance. (Cleanliness, track out, etc...)
 - Watch runoff during heavy rain events.


Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636