



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 28, 2024                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1 inspection of 4th floor framing complete.(except stairwell ,3' of south corridor, and all restrooms)

inspection of 3th floor framing .(except stairwell ,3' of south corridor, and all restrooms)

1 ; unit 360 - complete firestop at north wall.

2; 357 tighten nut on hold down

3 ; complete firestop at south wall.

4 ; insulate all hot water lines as discussed with contractor.

inspection of 2th floor framing .(except stairwell ,3' of south corridor, and all restrooms)

1 ; complete anchor bolts in corridor. (min. 2 bolts per plate)

2 ; 253 provide positive attachment og beam to wall.

2 ; provide squash blocks at beam



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684