

5th Review
PRCCP20230970
May 2024

Add the following note: "Maintain minimum 10ft separation between landscape trees and underground wet utilities and fire hydrants."
[Landscape Plans Sht L1.0; Pg 1 of 17]

Added note to L1.1, L.2, L1.3, and L1.4

Provide a landscape plan with all underground wet utilities overlaid on the plan per City Standards.
[Landscape Plans Sht L1.0; Pg 1 of 17]

Overlaid underground wet utilities on plans

PERMIT SET




East Town Crossing
Phase One
Pioneer Way & Shaw Road
Puyallup, WA

LYON
LANDSCAPE ARCHITECTS
2111 South C Street, Tacoma, WA 98402
253-678-4173 | Eric@LyonLA.com

Overall Landscape Plan

SCALE: 1" = 20'-0"	DESIGN: ML
DATE: May 16, 2024	DRAWN: ML
PROJECT: East Town Crossing	CHECKED: EW
PROJECT NO: LLA0222.20	REVISION NUMBER:
	APPD:



PROJECT