

FREDERICK J. GOGLIA

ARCHITECT, NCARB, ISP

May 31, 2024

City of Puyallup, WA Development and Permitting Services
333 S. Meridian
Puyallup, WA 98371

RE: Boot Barn
South Hill Center
4102D S. Meridian, Space D-1
ArcVision Project NO. 230665
Permit App NO. PRCT120240669

To Whom It May Concern,

This letter is in response to your plan review of the above project dated 05/24/24.

Building Division

1. Please provide the WSEC Mechanical Compliance Summary Worksheet for the alterations to the existing HVAC system shown on the Mechanical sheets:
www.waenergycodes.com

Response: per conversation with Brian Snowden – “The new 2021 WSEC does allow the exception per C503.4 Building Mechanical Systems exception #4 to remove and replace existing ductwork. The City's Building Official, Ray Cockerham, will also allow this exception for new and rerouted ductwork serving existing equipment.”

2. Elevations 8 does not exist on sheet A62. Appears to be Elevations 2. [PLAN SET, sheet A40]

Response: Elevation callout updated.

3. Please confirm this elevation call-out. Appears to be Elevations 4. [PLAN SET, sheet A40]

Response: Elevation callout updated.

4. Please verify the vision lites on these doors meet the minimum requirements of section 404.2.10 of the 2017 ICC A117.1 or the section's exemption. [PLAN SET, sheet A62]

Response: Note added to Stockroom door in Door Schedule on T10 and dimension added to 1B/A62.

If you have any questions, comments or need any additional information regarding this letter please contact Cindy Acton-Blackburn at ArcVision Inc. 800-489-2233.

Sincerely,

Cynthia Acton-Blackburn

Cindy Acton-Blackburn
Project Manager
CC: File