



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 05, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20221569

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

To construct: Extend utilities from 10th street SE on a site for purposes of construction 2- 6 plexus as well as provide infiltration on site. COPPERBERRY CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 5/3 - JL - Drive by, no civil work.

5/4 - JL - Drive by, no civil work. Street light approved today.

5/5 - JL - Drive by, no civil work. Spoke with GC and utility contractor about air testing the storm.

Note: FDC's were backfilled, they are not straight, and have no pressure in the lines.

Corrections:

- 1 Straighten FDC.
Pressure FDC.
Flush FDC after ALL underground has been completed.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the end of the signature to the right.

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636