



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 05, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20221555

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060

To construct: North Building of CopperBerry, R-2 Apartments 6 Plex CIVIL:
PRCCP20221569 / South building PRMU20221586 - REVISION (1) -
09/11/2023 - POURING A MAXIMUM 7' WALL IN PLACE OF 4' WALL ON
WEST SIDE OF FOUNDATION * REV (2) - 12/14/2023 - FOOTING &
FOUNDATION NOT NEEDED FOR WEST STAIRCASE LOAD AS PER
STURCTURAL ENGINEER. PEPLACE WITH PIERS AS PER DRAWINGS &
CALC * REC'D REV (3) - 5/24/2024 - REQEUSTED FIRE RATING FOR
INSPECTOR

On this day we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: gas pipe test approved at 15 psi. at all units. (except A204 failed)

Corrections:

- 1 gas pipe test failed at unit A204.

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684