



FIRE PROTECTION, INC.

PO BOX 12642
MILL CREEK, WA 98082

(425) 290-9600 OR 1-800-681-1125 FAX (425) 353-4546

May 2, 2024

CITY OF PUYALLUP – FIRE PREVENTION

RE; FACP Wireless Communicator Installation

1. THE EXISTING SINGLE-STORY BUILDING IS FULLY-SPRINKLED AND HAS AN EXISTING ADDRESSABLE FIRE ALARM CONTROL PANEL (SIEMENS CERBERUS PRO FC901 FIRE PANEL) LOCATED ON THE FIRST FLOOR IN THE IT SERVER ROOM.
2. A NEW UL LISTED WIRELESS CELLULAR COMMUNICATOR (HW-TG7LAF02/TG7LVF02) IS BEING INSTALLED AT THE FACP. ALL SIGNALS WILL BE TRANSMITTED BY ZONES TO THE UL LISTED SUPERVISING STATION.
3. THE NEW CELLULAR COMMUNICATOR SHALL TRANSMIT THE EXISTING FACP ZONES.
4. NO CHANGES TO THE EXISTING SYSTEM WILL BE MADE, NO ADDITIONAL WORK IS INCLUDED IN THIS SCOPE.

INSTALLATION COMPANY

Fire Protection, Inc.
14710 ASH WAY, STE 8. LYNNWOOD, WA. 98204
WSCL# FIREPI*021ML UL CERT #608242-002

SITE ADDRESS

OLD 911 COMMUNICATIONS CENTER
39TH AVE SE, PUYALLUP, WA 98374

APPROVED UL MONITORING COMPANY

Secure Pacific
8220 North Interstate Ave, Portland, OR 97217
1.800.934.9304

CONTRACTUAL RESPONSIBLE PARTIES

Installation; Monitoring
Fire Protection, Inc.

Should you have any further questions, please feel free to contact me directly.

DAVID MOW, SET
NICET-IV #120904
VP of OPERATIONS/Designer