



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 07, 2024

Inspection Result: PARTIAL PASS

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Drywall nailing inspection complete @ level 2 ceiling, and top 1' of walls at East - West corridor.

2 ; level 3 ceiling reinspection complete at corridor.

Corrections:

1 NORTH STAIRWELL

1. level 4 southwall hotel side 2nd layer approved

2. level 5 south and west wall provide min lap per UL listing hotel side at 2nd layer

3. level 4 west wall hotel side provide min lap per UL listing 2nd layer

SOUTH STAIRWELL

1. level 5 east wall hotel side 2nd layer approved

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large initial 'S' and 'K'.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684