



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 07, 2024

Inspection Result: PARTIAL PASS

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Level 3 - First layer of drywall nailing complete at Ceilings and Walls (except Bathroom, Stair, near expansion joint)

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org