



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 10, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20240469

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

**To construct:** NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT: WORK  
INCLUDES ADDING ROOF INSULATION TO EXISTING ROOF  
THROUGHOUT THE SUITE. - PROLOGIS Project is a resubmittal review.

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1.complete vapor barrier as discussed with contractor
- 2 1. complete vapor barrier as discussed with contractor  
2. provide head of wall detail at north end of office space at time of next inspection

Sincerely,

Kevin Spruell  
Building Inspector I  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590