



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 11, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20231772

**Property Address:** 401 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

**To construct:** Remodel of portion of emergency department to create spaces for treating lower acuity patients in open bays by removing some walls and installing wall mounted hand-wash sinks. Additionally will convert open room to become two separate rooms for holding patients requiring seclusion with enclosed workroom for staff to observe seclusion rooms. HVAC will be modified to serve the new spaces. Some electrical updates will also occur. - GOOD SAM HOSPITAL - ED

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 inspection date 6/11/2024
  - 1.DWV approved at 7 1/2 pounds air
  - 2.supply approved at 80 psi
  3. provide run test at DWV tie ins at time of next inspection

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)