



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 15, 2024

Inspection Result: **PASSED**

Permit Number: PRMH20230940

Property Address: 1007 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: DPR CONSTRUCTION INC 157 YESLER WAY, 2ND SEATTLE, WA 98104
To construct: REPLACE EXISTING RTU, LIKE -4- LIKE; IMPROVE THERMAL COMFORT & CONTROL OF STATEGIC AREAS W/IN MEDICAL CTR (3) MEDICATION RM;RETAIL PHARMACY & ADDED AREA (SEPARATE FROM MAIN SYSTEM)~ KAISER PERMENTE

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590