



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 17, 2024

**Inspection Result:** NOT READY

**Permit Number:** B-20-0180

**Property Address:** 3601 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND  
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

**To construct:** HOMEWOOD SUITES SOUTH HILL MALL MOTEL \*FEE DEFERRAL-SWR\*  
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD  
PERIMETER DRAINTILE

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 NORTH STAIRWELL
  1. level 4 southwall hotel side 2nd layer approved
  2. level 5 south and west wall provide min lap per UL listing hotel side at 2nd layer
  3. level 4 west wall hotel side provide min lap per UL listing 2nd layer
- SOUTH STAIRWELL
  1. level 5 east wall hotel side 2nd layer approved
- 2 date of inspection 6/17/2024
  1. discussed shaft designs

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)