



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 20, 2024

Inspection Result: NOT READY

Permit Number: PRCTI20240464

Property Address: 621 RIVER RD, PUYALLUP, WA 98371;

Contractor: SOUTHWESTERN SERVICES 2901 SUFFOLK DRIVE ST FORT WORTH, TX 76133-1152

To construct: Interior remodel of existing Tractor Supply store space and add interior pet wash area to that store also - NO new s.f. being added - TRACTOR SUPPLY CO PUYALLUP

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. complete plumbing as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590