



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 20, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCTI20240063

Property Address: 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;

Contractor: MARCO CONTRACTORS INC 100 COMMONWEALTH DR
WARRENDALE, PA 15095

To construct: retail tenant improvement project, designated as Group M (Mercantile).
Work to include but not limited to: Demolition of existing non-structural
tenant improvements and storefront; New interior partition walls,
ceilings, finishes; New storefront, new illuminated channel; New electrical
distribution and lighting; Existing HVAC unit with new distribution as
required; (1) one new restroom location using existing plumbing fixtures;
(1) one new sink in Staff Room. - JD SPORTS UNIT #530 * REV (1) -
5/17/2024 - FLOOR PLAN CHANGES, EXITS, EGRESS PATHWAYS, WALLS
AND MULTIPLE OTHER CHANGES FROM ORIGINAL PLANS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; complete insulation at hot water line in restroom.
2 ; provide detail from architect for support beam in restroom.

Corrections:

- 1 1 ; provide engineers fix or approval of no continuous special inspection of welding as required per plans.
- 2 ; approved new framing wall at staff break room.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684