



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 20, 2024

Inspection Result: NOT READY

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 inspection date 6/11/2024
 1. remove drywall in areas where covered with out energy/vapor barrier inspections
 2. complete fasteners per listing
 3. complete framing at shafts
 4. not a complete list / not ready
- 2 date of inspection 6/13/2024
 1. complete items 1 and 2 of previous list
 2. provide clarification on off sets
 3. complete log cabin at drywall corners
 4. not a complete list/not ready

LEVEL ONE

 1. areas in corridor where moisture was to high approved for cover
- 3 date of inspection 6/20/2024
framing of mech shaft at north east exterior wall
 1. remove drywall from concrete to roof to perform inspection at exterior wall



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590