



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 21, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRSG20240457

**Property Address:** 100 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** PLUMB SIGNS INC 909 S 28TH ST TACOMA, WA 98409 (253) 473-3323

**To construct:** Install of wall sign - KORUM FORD EV CHARGING STATION

On this day we have inspected your construction for **Sign Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide L&I electrical final prior to sign final.
- 2 ; provide sign attachment inspection approval prior to sign final approval.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684